

Haldor Topsøe A/S

**HAZOP**

**5000 MTPD Methanol  
plant, Bandar Assaluyeh,  
Iran**

July 2010

COWI A/S

Parallelsvej 2  
DK-2800 Kongens Lyngby  
Denmark

Tel +45 45 97 22 11  
Fax +45 45 97 22 12  
[www.cowi.com](http://www.cowi.com)

Haldor Topsøe A/S

## HAZOP

5000 MTPD Methanol plant,  
Bandar Assaluyeh, Iran

July 2010

Report no. 73506-A-1  
Issue no. 0  
Date of issue 30.07.2010

Prepared BRMA  
Checked FPN  
Approved FPN

## Table of Contents

<b>1</b>	<b>Executive summary</b>	<b>2</b>
<b>2</b>	<b>Background</b>	<b>3</b>
2.1	Basis of the study	3
2.2	Scope	3
2.3	Abbreviations	4
2.4	Nodes and deviations	5

**Appendix A: HAZOP sheets**

**Appendix B: List of recommendations**

## **1 Executive summary**

COWI has on request of Haldor Topsøe A/S facilitated a HAZOP study of a Methanol plant, designed by Haldor Topsøe A/S (HTAS). The unit is to be operated by Middle East Kimiaye Pars Company, Iran.

The study meetings were conducted in Haldor Topsøe A/S' office in Lyngby from the 9th until 28th of June 2010. The HAZOP participants represented three companies: MEKPCO, MJPC and HTAS

The HAZOP study was based upon process descriptions, PFD's, and P&ID's.

The objective of the HAZOP study was to identify scenarios leading to loss of containment or damage to equipment with potential to cause major shutdowns. Preventive and mitigating measures were identified.

Recommendations were given to improve the design. A full list of the 125 (19 are duplicates) recommendations is given in Appendix B of this report.

The HAZOP was generally based upon normal operation.

## 2 Background

COWI has on request of HTAS facilitated a HAZOP study of a Methanol plant, designed by HTAS. The unit is to be operated by Middle East Kimiaye Pars Company, Iran.

The objective of the study was to identify scenarios, which can lead to a) loss of containment, or b) substantial damage to process equipment leading to major unintended shutdowns. Consequences of the identified scenarios were qualitatively expressed and preventive and mitigating measures were identified.

Appendix A contains the HAZOP sheets. Appendix B contains a full list of the 125 (19 are duplicates) recommendations.

### 2.1 Basis of the study

Basis for the HAZOP study was:

Process description (No. 4338384 WBS 40, Rev.1)

Process Flow Diagram drawing numbers 1338092-1338098 rev. 1, 1343963 rev 0.

Piping and Instrument Diagram drawing numbers 1341582-1341626 rev 1, 1341630-1341646 rev 1, 1341647 rev 0 (U18).

### 2.2 Scope

The HAZOP study comprised the main process from battery limit to battery limit. Utility systems were also considered, mainly water and steam systems. The effect of external fires on process equipment was not considered, apart from pressure relief of equipment.

The meetings were conducted in Haldor Topsøe A/S office in Lyngby from the 9th until 28th of June 2010. The participants were:

HTAS: Hans Pedersen  
Lars Moerner  
Lone Johnsen (part time)  
Søren Toft (part time)

MJPC & MEKPCO:  
M. Mavadati  
M. Nabian  
S. Shaker  
H. Moayeri (part time)

COWI: Gunilla Kay Christiansen, HAZOP leader (9-16 June)  
Finn Pedersen, HAZOP leader (18-28 June)  
Birgitte Madsen, HAZOP secretary

### **2.3 Abbreviations**

HTAS	Haldor Topsøe A/S
MEKPCO	Middle eats Kimiaye Pars Company
MJPC	Marjan Petrochemical Company
PID	Piping and Instrument Diagrams
BL	Battery limit
FO	Fails open
FC	Fails close
BFW	Boiler feed water
MeOH	Methanol

## 2.4 Nodes and deviations

The table below lists the nodes to which records were made in the HAZOP sheets. The nodes are marked on PIDs.


No	Node
1	Natural gas knock out drum (D1001)
2	Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)
3	NG Saturation system (E6001, T6001, D6001)
4	S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)
5	Primary reformer (H2001)
6a	Secondary reformer (R2004)
6b	Waste heat boilers and steam super heaters (E2020, 2021 1/2/3)
7	Process gas cooling I (E2022 1/2 and D2002)
8	Process gas cooling II (E2023, D2003)
9	Process gas cooling III (E2024 1/2, D2004)
10	Process gas cooling IV (E2025, AE 2026, E2027, D2005)
11	Synthesis gas compressor (C3001/C3002)
12a	Synthesis loop (E3001 1, R3001 1)
12b	Synthesis loop (AE3002, E3003, D3001)
13	LP separator (D3002, X3001)
14	Raw methanol tank (TK5004)
15	Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B, E2024 1/2 P5002 A/B)
16	LP Methanol Column (T5002, P5005 A/B)
17	MP methanol column (T5003, E5002, D5003, P5006, E5012)
18	Product polisher (X5002 A/B)
19	Product buffer tank and product pump (TK5002, P5008A/B)
20	Liquid off stream (E 5011, TK 5003, P 5009 A/B)
21	Bottom product to wash column T5004 (AE 5006, E5007, T5004)
22	Fuel gas to primary reformer
23	Flue gas system
24	Oxygen system
25	Demin water system
26	Deaerator
27	BFW pumps and distribution
28	HHP boiler (D2001, E2022 1/2)
29	HHP steam header
30	HP steam header
31	MP steam header
32	LP steam header
33	MP steam drum (D3003)
34	Blow down system
35	H <sub>2</sub> recycle system
36	Start up blower

37	General
----	---------


High risk scenarios were identified along with the safeguards and has been marked with a \* in the HAZOP sheet in the column named SR. The consequences of failure of the safeguards marked with a \* will be evaluated at a later stage by HTAS.




# Appendix A: HAZOP sheets

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MJPC &amp; MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 1 Natural gas K.O. drum (D1001)	P&ID no.: P01	Intention: Knock out liquids	Date: 09.06.2010
	Design P/T: 60 barg, 85 C	Operating P/T: 52 barg ,40 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
No	Blocked inlet or blocked outlet	No consequences				
More (from BL)	Fully open outlet	No consequences				
Less		No consequences				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Failure of pressure control valve, PIC 1006	Exceeding design pressure downstream of drum D1001 due to blocked outlet  High pressure in drum due to external fire	PSV 1008 and 1009  PSV 1015	1. Maximum delivery pressure of NG at BL (60 barg) to be assured	MEKPCO / DAMAVAN D	
Low	Low pressure from BL	No consequences				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MJPC &amp; MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 1 Natural gas K.O. drum (D1001)	P&ID no.: P01	Intention: Knock out liquids	Date: 09.06.2010
	Design P/T: 60 barg, 85 C	Operating P/T: 52 barg ,40 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level in drum D1001</b>		<b>Intention:</b>				
High (in D1001)	Liquid in feed	<p>Liquid carry over to reactors, potentially damage of catalyst</p> <p>Liquid carry over to fuel gas system leading to malfunction of burners.</p>	<p>High level alarm, LI 1004</p> <p>Trip on high level (stop downstream unit) LSAH</p> <p>Trip on high level (stop downstream unit) LSAH</p>			<p>*</p> <p>*</p>
Low (in D1001)	Open drain valve	Gas break-through to drain system.	Procedure to ensure level gauge is checked while draining	2. Drain valve to be visible from level gauge.	MEKPCO/detailed engineering	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High flow (NG)	<p>Higher delivery pressure</p> <p>Down stream flow control failure (open)</p>	<p>Reduced sulphur conversion. No consequence for this node.</p>	<p>Upstream pressure control valve, PIC 1006</p> <p>Down stream flow control valve FIC 6070</p> <p>Sulphur analyser, AI 1045</p>			
High (H2)	<p>Failure of inlet flow valve, FV 2150</p>	<p>No consequences</p>				
No / Low (NG)	<p>Failure of control valve down stream, FV 6070</p> <p>Low pressure at BL</p>	<p>High temperature in coils, E2006 or E2004 (see high temp)</p>	<p>Temperature control, TIC 2220</p> <p>FSAL 6070, low flow will trip plant</p>	<p>3. Open false air dampers on IS-1trip (on shutdown of system)</p>	<p>HTAS</p>	<p>*</p>

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low flow during start up		High temperatures in coils	Venting during start up to create flow through system			
No / Low (H2/N2)	<p>Failure of flow valve, FV 2150</p> <p>Loss of H2 recycle gas pressure</p>	Insufficient sulphur conversion. Damaging catalyst	Analyser AI 1045 downstream reactor			
Reverse flow (NG into H2 system)	Low pressure of H2	NG into H2 system	<p>FIC 2150, low alarm on H2 inlet</p> <p>Check valve</p>			
Reverse flow (H2 into NG)	Low pressure of NG	H2 into NG system. No consequence	Check valve at inlet to KO drum, D1001			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse flow (liquid off stream into re- actors )	No flow through desulphurizer	Liquid off stream into reactors. No consequences  Evaporation of MeOH				
High (R1001)	See high flow above	Slip of sulphur from R1002	High margin on flow			
Low (R1001)		No consequences for the catalyst				
High (R1002)	See high flow above	More flow or more sulphur will change life time of the catalyst in R1002	Regular sampling for sulphur content in analysis point in bottom of R1002 1, AP 1039			
Low (R1002)		No consequences for the catalyst in R1002				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (inside and out of E2006)	Low NG flow Open bypass, TV 2220	Exceeding design temperature	High temperature alarm, TI 2148 (outlet of preheat coil E2006)			
	Closure of throttle valve at E2006 inlet	High temperature (not exceeding design temp)	Minimum stop at throttle valve Sufficient design temperature on pre-heat coil E2006 Temperature alarm, TI 2148 (outlet of preheat coil E2006)	4. Check minimum flow rate required	HTAS	
High (out of E2004)	Failure of temperature regulation and low flow of NG	Exceeding design temperature on piping after E2004	Increased temperature for short time does not damage catalyst	5. Add high temperature alarm on TIC 2220 (E2004 outlet)	HTAS	


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	Olefins in feed stock could increase temperature in hydrogenator R1001	Damage of catalyst	High temperature alarms, TI 1034 and TI 1035 on hydrogenator			
Low	Low flue gas temp	Insufficient sulphur conversion				
High (R1001)	See high temperature above	Damage of catalyst in hydrogenator	The catalyst in the hydrogenator is able to run up to 400 C			
Low(R1001)	See low temperature above	Decreasing catalyst activity in hydrogenator R1001, the activity decreases significantly at operation below 330 C, the activity is very low at temperatures below 300 C				
Low temp and no H2 (R1001)		Operating below 300 C without H2 will give sulphur slip and it will deactivate the catalyst in prereformer R2003				




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (R1002)	See high temperature above	Damage of catalyst	The catalyst in the sulphur absorber R1002 is able to run up to 400 C			
Low (R1002)	See low temperature above	Slower reactions, no short time consequences for the catalyst  Operating below 360 C will reduced catalyst life time				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (from H2 system)	Blocked outlet, FV 6070 closed	Pressure exceeding design pressure	High alarm on safety valve, PIC 1045  Vent capacity is larger than H2 flow			
High	External fire	High pressure in vessel	PSV 1031, 1038, 1043 are designed for fire case			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	<p>Low pressure at inlet  Open vent, PV 1045 (at R1002 2outlet)</p>	<p>Low flow to reformer, no safety consequence</p>	<p>Trip of reformer, IS-1  Low alarm, PIC 1045 (at R1002 2outlet)</p>			
High pressure drop (across reactor R1001)	<p>Dirt, piping not cleaned properly.</p>	<p>Reduced plant capacity</p>	<p>High differential alarm, PDAH 1032</p>			
High pressure drop (across R 1002 1/2)	<p>Dirt, piping not cleaned properly.</p>	<p>Reduced plant capacity</p>	<p>R1002 1/2 are protected by the first reactor (R1001)  Low alarm, PIC 1045 (at R1002 2outlet)</p>			
High (R1001)		<p>Operating pressures within design pressure have no consequences for the catalyst</p>				

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)	P&ID no.: P04, P12, P13	Intention: Preheating, hydrogenation and desulphurization of NG	Date: 09.06.2010
	Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C	Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (R1001)		No consequences for the catalyst				
High (R1002)		No consequences for the catalyst				
Low (R1002)		No consequences for the catalyst				
<b>Parameter: Composition</b>		<b>Intention:</b>				
High sulphur content from feed stock		Sulphur break-through, sulphur deposit on catalyst in prereformer	Sulphur analyser, AI 1035	6. Add high alarm on AI 1045  7. Consider procedure to ensure operator shut down plant on high alarm AI 1045	HTAS  HTAS	
Liquid in feed	Liquid carry over from KO drum D1001	Disintegration of hydrogenation catalyst	LI 1004, high alarm (on KO drum D1001)  LSAH 1004, IS 1 trip			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
H2	No H2	Carbon formation in hydrogenator R1001 will deactivate/damage catalyst	FIC 2150, deviation alarm on H2 flow (at H2 inlet)  (manual) shut down if H2 cannot be re-established shortly			
High sulphur (R1001)			High margin on catalyst activity  Sulphur analyser with high alarm, AI 1045 out of HDS section			
High sulphur (R1002)		Reduced life time of catalyst	AI 1035 high alarm on total sulphur			
No sulphur (R1001)	No sulphur in feed	Especially for new catalyst, deactiva- tion of cat in R1001 for long term op- eration with no sulphur	AI 1035 (total sulphur) inlet to R1002 1			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Iron to R1002	Very high content of iron in feed	Formation of iron carbide in the second reactor R1002 2 causing high pressure drop across reactor. Reduced performance of R1002 2	Iron in feed not expected			
Lean gas (R1001 and R1002)		No consequences for the catalyst				
Liquid (R1001 and R1002)	Carry over from KO drum (water)	No consequences for the catalyst				
	Carry over from KO drum (HC)	No consequences for the catalyst				
<b>Parameter: Reaction</b>		<b>Intention:</b>				
Run away reactions	Unsaturated hydrocarbons in hydrogenator R1001	High temperature in reactor (see high temperature)				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 2 Preheating (E2006/E2004), hydrogenation (R1001) and desulphurization (R1002 1/2)</p>	<p>P&amp;ID no.: P04, P12, P13</p>	<p>Intention: Preheating, hydrogenation and desulphurization of NG</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: 55 barg, 85 C upstream E2006, 375 C between E2006 and E2004, 410 C downstream E2004, H2 system: 60 barg, 100 C</p>	<p>Operating P/T: 50 barg, 40 C upstream E2006, 49.4 barg , 246 C between E2006 and E2004, 48.8 barg , 480 C downstream E2004 48.3 barg, 375 C between R1001 and R1002 2, 47.3 barg , 365 C out of R1002 2. H2 system: 55 barg, 48 C</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Run away (R1001)	Opening a warm reactor (shut down)  Pyrophoric	Temperature increases rapidly, run away reaction	Operating manual include procedure on cooling down (below 75 C) before opening reactor			
<b>Parameter: Other</b>		<b>Intention:</b>				
Poisoning (R1001)	No causes					


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 3 NG Saturation system (E6001, T6001, D6001) – gas system</p>	<p>P&amp;ID no.: P06, P07</p>	<p>Intention: Saturation of NG with water</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: P = 55 barg (gas system), 410 C Upstream E6001, 290 C between E6001 and T6001, 260 C upstream T6001, 290 C downstream E6001</p>	<p>Operating P/T: 43.8 barg, 358 C Upstream E6001, 43.3 barg, 265 C between E6001 and T6001, 42.8 barg, 226 C upstream T6001, 42.3 barg, 262 C downstream E6001</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (NG)	Flow valve FV 6070 fully open	<p>Evaporation of more condensate in E6001, no consequences for this note</p> <p>Reduced level in D6001</p> <p>Lower steam to carbon ratio into re-forming. See node 4</p>	<p>Increased steam pressure in saturator and added BFW, controlled by LIC 6051, FIC 6031 and PIC 6025</p> <p>Additional steam is added to adjust S/C ration</p>			
Low NG	Failure of FV 6070	<p>Water level increases in D6001 and temperature will then increase.</p> <p>S/C ratio increases, no consequences</p>	Controlled by LIC 6051, FIC 6031, PIC 6025			
Reverse flow (NG into off stream liquid)		Gas into liquid off steam tank TK 5003. Venting to safe location	<p>Check valve</p> <p>Reciprocating pumps prevent back flow to tank</p>			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 3 NG Saturation system (E6001, T6001, D6001) – gas system</p>	<p>P&amp;ID no.: P06, P07</p>	<p>Intention: Saturation of NG with water</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: P = 55 barg (gas system), 410 C Upstream E6001, 290 C between E6001 and T6001, 260 C upstream T6001, 290 C downstream E6001</p>	<p>Operating P/T: 43.8 barg, 358 C Upstream E6001, 43.3 barg, 265 C between E6001 and T6001, 42.8 barg, 226 C upstream T6001, 42.3 barg, 262 C downstream E6001</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High/low flow of off stream liquid		No consequences				
NG into Steam system	Pipe rupture in T6001	Pressure control valve PIC 6025 closes if pressure increases in T6001 (back flow not possible)	FI 2065 low alarm (water added in the saturator)			




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 3 NG Saturation system (E6001, T6001, D6001) – gas system	P&ID no.: P06, P07	Intention: Saturation of NG with water	Date: 09.06.2010
	Design P/T: P = 55 barg (gas system), 410 C Upstream E6001, 290 C between E6001 and T6001, 260 C upstream T6001, 290 C downstream E6001	Operating P/T: 43.8 barg, 358 C Upstream E6001, 43.3 barg, 265 C between E6001 and T6001, 42.8 barg, 226 C upstream T6001, 42.3 barg, 262 C downstream E6001	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (T6001 NG)	Loss of process condensate	Saturator will heat up  Hammering in D6001	FI 6068, low condensate circulation alarm	8. Increase design temperature to 290 C  9. (If design temperature is not increased then consider temperature alarms out of T6001)  10. Consider low level alarms on LI 6033 and LI 6034	HTAS  HTAS  HTAS	
Low	Interrupted steam supply  Low pressure of steam	Reduced evaporation in T6001 giving low S/C ratio and increased level in D6001.	FI 2065 low saturated steam alarm			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 3 NG Saturation system (E6001, T6001, D6001) – gas system</p>	<p>P&amp;ID no.: P06, P07</p>	<p>Intention: Saturation of NG with water</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: P = 55 barg (gas system), 410 C Upstream E6001, 290 C between E6001 and T6001, 260 C upstream T6001, 290 C downstream E6001</p>	<p>Operating P/T: 43.8 barg, 358 C Upstream E6001, 43.3 barg, 265 C between E6001 and T6001, 42.8 barg, 226 C upstream T6001, 42.3 barg, 262 C downstream E6001</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Blocked outlet, closure of FIC 2061 downstream E6001	High pressure due to liquid off stream filling the system upstream and downstream (low flow)	<p>PV 1045 vent downstream desulphurization</p> <p>PSVs 1031, 1038, 6053</p> <p>Reformer will trip due to no flow and stop liquid off stream pump</p>	11. Consider high alarm on PIC 2073	HTAS	
High	Fire below vessel D6001 or E6001	Rupture of vessel	PSV 6053 (common)			
Low	Fully open outlet valve	Increased flow for a period (see flow)	<p>PIC 2073 (downstream) closes outlet valve FV 2061</p> <p>PIC 2073 (downstream) opens outlet valve FV 2061</p>			
	Blocked inlet	Loose flow (see flow)				
	Low pressure from inlet	Low flow, no safety consequence				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 3 NG Saturation system (E6001, T6001, D6001) – gas system</p>	<p>P&amp;ID no.: P06, P07</p>	<p>Intention: Saturation of NG with water</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: P = 55 barg (gas system), 410 C Upstream E6001, 290 C between E6001 and T6001, 260 C upstream T6001, 290 C downstream E6001</p>	<p>Operating P/T: 43.8 barg, 358 C Upstream E6001, 43.3 barg, 265 C between E6001 and T6001, 42.8 barg, 226 C upstream T6001, 42.3 barg, 262 C downstream E6001</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Chloride in water (process water makeup)	Regeneration of ion exchanger with HCL	Chloride in saturator, stress corrosion in saturator	H2SO4 for regeneration of ion exchanger. HCL is not allowed	12. Ensure operating manual covers H2SO4 is used as re-generator.	HTAS	
Dirt	Dirt in gas/liquid system	Blockage of holes in top of tubes in saturator	Filter on process water makeup LI 6033, high alarm	13. Check / clean tubes to be included in detailed procedure  14. To be highlighted in operating manual	MEKPCO  HTAS	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 3 NG Saturation system (E6001, T6001, D6001) – gas system</p>	<p>P&amp;ID no.: P06, P07</p>	<p>Intention: Saturation of NG with water</p>	<p>Date: 09.06.2010</p>
	<p>Design P/T: P = 55 barg (gas system), 410 C Upstream E6001, 290 C between E6001 and T6001, 260 C upstream T6001, 290 C downstream E6001</p>	<p>Operating P/T: 43.8 barg, 358 C Upstream E6001, 43.3 barg, 265 C between E6001 and T6001, 42.8 barg, 226 C upstream T6001, 42.3 barg, 262 C downstream E6001</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
Leaks	Leaks in E6001	<p>Reduced evaporation in saturator T6001</p> <p>Level increases in D6001. Surplus of condensate will go to BL</p>	FV 6081 opens			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 3 NG saturation system (E6001, T6001, D6001) – Liquid system	P&ID no.: P06 and P07	Intention: Saturate feed gas with water	Date: 10.06.2010
	Design P/T: P = 55 barg (gas system), 410 C before E6001, 290 after E6001, 260 C after saturator, 290 C out of E6001	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
More liquid (process water)	Increased S/C ratio Malfunction of upstream level control valves, LIC 2441, LIC 2403 or LIC 2474.	High level in D6001  Potentially carry over (see level)	Level control LIC 6051 (high alarm ) PIC 6025 will control steam pressure FV 6081 will open (excess liquid to BL)			
More liquid (BFW)	Malfunction of flow valve FV 6031	High level in D6001  Potentially carry over (see level)	Level control LIC 6051 (high alarm) PIC 6025 will control steam pressure FV 6081 will open (excess liquid to BL)			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 3 NG saturation system (E6001, T6001, D6001) – Liquid system	P&ID no.: P06 and P07	Intention: Saturate feed gas with water	Date: 10.06.2010
	Design P/T: P = 55 barg (gas system), 410 C before E6001, 290 after E6001, 260 C after saturator, 290 C out of E6001	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
More distillation water	Malfunction of flow control FIC 5367	High level in D6001  Potentially carry over (see level)	Level control LIC 6051 (high alarm )  PIC 6025 will control steam pressure  FV 6081 will open (excess liquid to BL)			
Less (liquid into system)	Closed inlets	Reduced S/C ratio	Direct steam addition downstream controlled by FV 2072 (system designed for 100% )			
Less (liquid in system)	Open outlet valve ,FV 6081	Low level in D6001 (see level)  Reduced S/C ratio	Direct steam addition downstream controlled by FV 2072 (system designed for 100% )			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 3 NG saturation system (E6001, T6001, D6001) – Liquid system</p>	<p>P&amp;ID no.: P06 and P07</p>	<p>Intention: Saturate feed gas with water</p>	<p>Date: 10.06.2010</p>
	<p>Design P/T: P = 55 barg (gas system), 410 C before E6001, 290 after E6001, 260 C after saturator, 290 C out of E6001</p>	<p>Operating P/T:</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Less (circulation)	Failure of circulation pump 6001 A/B	<p>Reduced S/C ratio</p> <p>Potentially high level in D6001</p>	<p>Autostart of standby pump</p> <p>Direct steam addition downstream controlled by FV 2072 (system designed for 100% )</p> <p>FI 6068 (low alarm on circulation flow)</p> <p>See high level</p>			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
See node 3 gas system						
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Pump failure		Discharge pressure cannot exceed design pressure			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 3 NG saturation system (E6001, T6001, D6001) – Liquid system	P&ID no.: P06 and P07	Intention: Saturate feed gas with water	Date: 10.06.2010
	Design P/T: P = 55 barg (gas system), 410 C before E6001, 290 after E6001, 260 C after saturator, 290 C out of E6001	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (from BFW)	Failure UV 6035 (FC).	High pressure from BFW between FV6031 and UV 6035. Exceeding design pressure		15. Install PSV downstream FV 6031	HTAS	
High (process condensate / distillation water)	Failure of UV 6035 (FC).	Potential of exceeding design pressure	Design pressure to be checked against maximum possible shut off pressure given by pump vender. Is noted on pump spec, instrument data sheet and line number registration.	16. Design pressure out of process water streams to be checked against maximum shut off pressure from P2001, P2002, P2003, P5010.	MEKPCO	
Low	See gas system					
<b>Parameter: Level</b>		<b>Intention:</b>				
High (top of T6001)	Blocked holes in top of tubes	Lower S/C ratio	LI 6033 (high alarm)			
High (bottom of T6001, steam side)	See steam node					




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 3 NG saturation system (E6001, T6001, D6001) – Liquid system	P&ID no.: P06 and P07	Intention: Saturate feed gas with water	Date: 10.06.2010
	Design P/T: P = 55 barg (gas system), 410 C before E6001, 290 after E6001, 260 C after saturator, 290 C out of E6001	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (in D6001)	Failure of level control, LIC 6051 or  Blocked outlet valve, FV 6086 is closed	Liquid carry over to gas system. Potential damage of equipment and catalyst.	High level trip, LSAH 6051 (separate from LIC 6051)  LIC 6051 high alarm			*
Low (top of T6001)	Low circulation flow (see low flow)	Gas break-through to blow down system. Potentially over pressuring of blow down system.	Atmospheric vent on D6002 to safe location (simultaneous loss of process water, BFW, distillation and circulation pump gives the consequence).			
Low (D6001)	Failure of LIC 6051 (BD opens) or  Blocked inlet (no BFW or process water or distillation)	Cavitation of circulation pump, potential pump damage  Gas into blow down system. Potential overpressure of blow down system	LALL 6051  Interlock stops circulation pump and closes blow down	17. Add LSAL and USV on blow down at D6002 inlet	HTAS	*  *

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p> <p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p> <p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	Date: 10.06.2010


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
S/C ratio (low)	<p>Loss of direct steam by failure of FIC 2072.</p> <p>Failure of flow transmitters (FST 2061 A/B/C, FST 6070 A/B/C, FST 2072 A/B/C )</p> <p>Wrong input from operator on carbon number and Mw.</p> <p>Failure of specific gravity analyser (AST 1001 A/B/C) if installed</p>	C on prereformer catalyst. Potential damage of catalyst.	<p>FI 2069 low alarm (total steam), IS 1 trip on low S/C ration FFSAL 2064.</p> <p>2 out of 3, discrepancy alarm, IS 1 trip on low S/C ration FFSAL 2064.</p> <p>IS 1 trip on low S/C ration FFSAL 2064</p>	<p>18. Consider additional flow meters for reference</p> <p>19. Consider installing specific gravity analyser (2 out of 3) with discrepancy alarm and automatic input to S/C ratio calculation (AST)</p>	<p>HTAS</p> <p>HTAS</p>	*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)</p>	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p>	<p>Date: 10.06.2010</p>
	<p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Start up				20. Assure correct installation, calibration and function of flow elements and meters for S/C ratio during commissioning		
S/C ratio (high)	<p>Failure of FIC 2072.</p> <p>Failure of flow transmitters (FST 2061 A/B/C, FST 6070 A/B/C, FST 2072 A/B/C )</p>	<p>Surplus of process condensate (limited possibility of discharge)</p> <p>Other module into synthesis loop. This may affect production.</p>	<p>Long term correction has to be made by operators.</p> <p>Long term correction has to be made by operators.</p>	<p>21. Consider additional flow meters for reference (previously added, see action no 18)</p>	HTAS	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p> <p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p> <p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	Date: 10.06.2010


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	<p>Wrong input from operator on carbon number (HSIC 2063) and Mw (HIC 6068).</p> <p>Failure of specific gravity analyser (AST 1001 A/B/C) if installed (see ration low above)</p>			<p>22. Consider installing specific gravity analyser (2 out of 3) with discrepancy alarm and automatic input to S/C ratio calculation (AST) (previously added, see action no. 19)</p>	HTAS	
<b>Parameter: Flow</b>		<b>Intention:</b>				
High	Failure of control loops, FV 2061 opens	Initially reduced S/C ratio	See S/C ratio low			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)</p>	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p>	<p>Date: 10.06.2010</p>
	<p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
		<p>Reduced inlet temperature to prereformer R2003 (see temperature)</p> <p>High delta P across prereformer R2003. Reduced conversion of HC in R2003. Operational upsets downstream</p>	<p>PDI 2252, high alarm</p>			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)</p>	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p>	<p>Date: 10.06.2010</p>
	<p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low/no	<p>Failure of FV 2061</p> <p>Failure of direct steam controlled by FIC 2072</p> <p>Loss of upstream pressure</p>	<p>Overheating prereformer and coils (see high temperature)</p> <p>Incorrect S/C ratio</p>	<p>FIC 2061, low alarm</p> <p>FSAL 6070 IS 1, low NG</p> <p>FSAL 2062 IS 1, low total steam flow</p> <p>FI 2069, total steam flow low alarm</p> <p>FFI 2069 low S/C ratio alarm</p> <p>FFSAL 2064 going to IS 1, low S/C ratio</p>			<p>*</p> <p>*</p> <p>*</p>
Reverse flow	<p>Open upstream vent, PIC 2073</p>	<p>Stream, BFW or process condensate into vent system.</p> <p>Back flow in prereformer</p>	<p>Check valve</p> <p>Forced closed (PV 2073) when secondary reformer is in operation</p>			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)</p>	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p>	<p>Date: 10.06.2010</p>
	<p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	<p>Low flow</p> <p>High flue gas temperature (see node 23)</p>	<p>Exceeding design temperature of coils E2002 and E2001 and prereformer R2003.</p> <p>Carbon on catalyst in prereformer and higher delta P across prereformer</p>	<p>TIC 2253 adds process condensate (or BFW)</p> <p>TI 2268, high alarm</p> <p>TI 2234, high alarm</p> <p>FIC 2061, low alarm</p> <p>FSAL 6070 IS 1, low NG flow</p> <p>FSAL 2062 IS 1, low total steam flow</p> <p>FI 2069, total steam flow low alarm</p> <p>PDI 2252, high alarm</p>			<p>*</p> <p>*</p>


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)</p>	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p>	<p>Date: 10.06.2010</p>
	<p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	<p>To much quench ( FV 2233 1/2 FC, failure of TIC 2232, 2233) or liquid carry over</p> <p>Low flue gas temperature (see node 23)</p>	<p>Reduced conversion of HC in pre-reformer R2003</p> <p>Liquid carry over (or condensation) may damage catalyst</p>	<p>TIC 2253 low alarm</p> <p>TI 2268 and TI 2234 low alarms</p> <p>Normal operations well above dew point</p> <p>Start up procedure ensures operating temperature well above dew point during start up</p>	<p>23. Consider adding low alarm on TIC 2232</p>	HTAS	
High (R2003)		<p>No consequences for the catalyst if operated within design temp</p>				
High R2003		<p>Risk of carbon formation on catalyst in R2003 when temp is high (above 520 C) combined with rich gas. This will damage the catalyst</p>	<p>TI 2253 high alarm at performer inlet</p>			




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)	P&ID no.: P07, P09, P10, P13, P14	Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003	Date: 10.06.2010
	Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001	Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Blocked outlet or stop of synthesis compressor C3001	Potentially exceeding design pressure	PSV 2354 to 2359 after steam super heater (110% capacity)  PIC 2481 will open vent to flare			
Low	Open vent, PV 2481 or  Loss of feed (e.g. PV 2073 opens)	Low or no production.  Low flow (see low flow)	PIC 3007, low alarm at synthesis. gas compressor inlet			
High (R2003)		No consequences for the catalyst				
Low (R2003)		No consequences for the catalyst				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 4 S/C ratio control, preheating (E2002) and pre-reformer (R2003), preheating (E2001)</p>	<p>P&amp;ID no.: P07, P09, P10, P13, P14</p>	<p>Intention: S/C ratio control, preheating of process gas and conversion of higher HC in pre-reformer R2003</p>	<p>Date: 10.06.2010</p>
	<p>Design P/T: 55 barg , 290 C 46 barg, 550 C after E2002 46 barg, 500 C after R2003, 46 barg, 675 C after E2001</p>	<p>Operating P/T:42.3 barg, 262 C before mixing 41.1 barg, 267 C after mixing 38.4 barg, 496 inlet R2003, 37.7 barg, 441 C inlet E2001, 36.3 barg, 638 C outlet E2001</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Reaction</b>		<b>Intention:</b>				
Reaction	heavy gas	Temperature increases in R2003. Potential of carbon formation on catalyst which will reduce catalyst life time.	<p>Specific gravity analyser AI 1001, high alarm</p> <p>TI 2268, high alarm</p> <p>FHIC 2070, increase S/C ratio manually</p>			
Runaway	Pyrophoric	See run away reactions for R1001 in node R1001				
Poisoning	Sulphur	Sulphur will reduce life time	Deactivation plot (temperature profile as function of time)			
	Silica, Sodium, Potassium	Dependent on cat history, reduces life time	Ensure clean steam			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T: 36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (process gas)	Failure of control loop, valve FV 2061 opens	Initially reduced S/C ratio  Lower inlet and outlet temp will increase slip of CH <sub>4</sub> . Lower efficiency of plant.  Increased pressure drop	See S/C ratio low  TI 2268 low alarm out of prereformer  PDI 2283, high alarm			
Low flow (process gas)	Failure of valve FV 2061  Failure of direct steam controlled by FIC 2072  Loss of upstream pressure	Overheating of reformer tubes (see high temperature)  Incorrect S/C ratio	FIC 2061, low alarm  FSAL 6070 IS 1, low NG  FSAL 2062 IS 1, low total steam flow  FI 2069, total steam flow low alarm  FFI 2069 low S/C ratio alarm  FFSAL 2064 going to IS 1, low S/C ratio			*  *  *

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T: 36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low flow (local process gas)	Uneven distribution of gas due to poor catalyst loading	Local overheating of reformer tube	Catalyst is loaded in accordance with manual  Regularly measurements of tube skin temperature  Visual inspection			
Low (purge gas)	Failure of FIC 2536  Trip of synthesis, IS 3	Low total fuel gas to reformer. Under firing	QIC 2535 will increase NG fuel.  FALL 2536, interlock alarm I 14, closes purge gas valve, FV 2536  See safeguards for under firing			*
Low/no (NG fuel)	Failure of PIC 1011 or FIC 2531  Closure of manual valves	Low total fuel gas to reformer. Under firing	PI 2540 (NG fuel)  PIC 2554 low alarm (total fuel gas)  PSAL 2554, IS 1 (total fuel gas)			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH4 to H2, CO, CO2	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T:36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (combustion air)	Failure of dampers or FD fan	<p>Increased pressure in waste heat section (flue gas section)</p> <p>Risk to personnel during visual inspection</p> <p>Lower temperature of flue gas (radiant section)</p> <p>Air in flue gas and potential explosive atmosphere if HC ingress to flue gas (see flue gas node 23)</p>	<p>PIC 2224, high alarm (maintain flue gas pressure by increasing speed of flue gas blower F 2001)</p> <p>PAHH 2224 interlock, I 15, opens the false air dampers and gives visual alarm (hazard flasher), XAL 2284</p> <p>PSAH 2224, gives IS 1 trip</p> <p>AI 2223 1 and AI 2224 (O<sub>2</sub> in flue gas)</p>	24 Consider high alarm on AI 2223 1 and AI 2224	HTAS	<p>*</p> <p>*</p>

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T: 36.3 barg, 638 C inlet, 742 C outlet	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (combustion air)	Failure of dampers or FD fan	<p>Under firing</p> <p>Incomplete combustion, HC in flue gas, potential explosive atmosphere if air ingress to flue gas (see flue gas node 23)</p>	<p>FIC 2111, low alarm (comb air flow)</p> <p>PIC 2163, low alarm (ensuring minimum combustion air pressure)</p> <p>PSAL 2163, IS 1 trip (comb air)</p> <p>AI 2223 2, high alarm (combustibles)</p> <p>AI 2223 1, low alarm (O<sub>2</sub>)</p> <p>AI 2224, low alarm (O<sub>2</sub>)</p> <p>Autostart of motor drive in case of turbine trip</p>			*
High (H2001)		No consequences for the catalyst				
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Over firing (operator error or failure of FIC 2531 (NG) or FIC 2536 (purge gas))	Damage of reformer tubes	<p>TI 2295, TI 2297, high alarm (flue gas)</p> <p>TSAH 2221, IS 1 trip (flue gas)</p> <p>TI 2305, TI 2303, TI 2304 high alarm (pro-</p>			*


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH4 to H2, CO, CO2	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T: 36.3 barg, 638 C inlet, 742 C outlet	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	<p>Composition of fuel (LHV)</p> <p>Lean feed gas</p> <p>Low process gas flow (see</p>		<p>cess gas)</p> <p>TSAH 2305, IS 1 trip (process gas)</p> <p>QIC 2535 (duty control by manual set point)</p> <p>AI 2531 (LHV analyser on NG)</p> <p>AI 2532 (LHV analyser on purge gas)</p>	<p>25. Consider installing deviation alarm and high alarm on QIC 2535</p> <p>26. Consider LTM (load and temperature management) system for duty control. LTM will include input from LHV analysers.</p>	<p>HTAS</p> <p>HTAS</p>	*


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T:36.3 barg, 638 C inlet, 742 C outlet	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	above)					
High (local)	Some of the burners are damaged  Uneven fuel distribution	Damage of reformer tubes	Regularly measurements of tube skin temperature  Visual inspection	27. Procedure to be included in operating manual	HTAS	
Low	Under firing (operator error or failure of FIC 2531 (NG), FIC 2536 (purge gas), insufficient air supply)  Composition of fuel (LHV)	Down stream disturbances  CH <sub>4</sub> slip increases	AI 2479 (CH <sub>4</sub> analyser)  Operator increase heat input  AI 2531 (LHV analyser on NG)  AI 2532 (LHV analyser on purge gas)	28. Add high alarm on AI 2479 (is added, see a	HTAS	
High (combustion air)	High flue gas temperature in E2007  Low flow of combustion air (see low flow)	More production of NO <sub>x</sub> , no serious consequences  Exceeding design temperature of coil E2007	Normal operation temperature below critical NO <sub>x</sub> formation temperature  Design temperature of E2007 (280 C) and flue gas blower (250 C) is selected with sufficient margin			




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T:36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (combustion air)		More fuel consumption. No consequences				
High (fuel gas)	No causes					
High (purge)	No causes					
Low (fuel gas)	Low temperature at BL	Hydrate formation after pressure reduction	Fuel gas temperature after depressurization PV1011 is above hydrate formation temperature			
Low (purge)	Not possible					
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (process gas)	Blocked outlet or stop of synthesis compressor C3001	Potential exceeding design pressure	PSV 2354 to 2359 after steam super heater (110% capacity)  PIC 2481 will open vent to flare			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T:36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (process gas)	Open vent, PV 2481	High flow (see high flow)	PIC 3007, low alarm at synthesis gas compressor inlet P3001			
	Loss of feed (e.g. PV 2073 opens)	Low flow (see low flow)				
High (fuel gas)	Malfunction of PIC 1011	Exceeding design pressure of down stream piping  Over firing (see high flow)	PSV 1013 and 1014  FIC 2531 will regulate flow/pressure down stream  PIC 2454 high alarm, total fuel gas  PI 2540 (NG fuel gas)  PSAH 2554, IS 1 trip			*
High (purge)	Failure of FIC 2536 (closed)	Exceeding design pressure	PIC 2536 B, (purge gas vent)  PSVs 3173, 3174			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T:36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (purge)	Failure of upstream control FIC 3169, FIC 3171	Exceeding design pressure	PIC 2536 B, (purge gas vent)  PSVs 3173, 3174  PSAH 2554, IS 1 trip  PIC 2454 high alarm, total fuel gas			*
High (comb air)	Maloperation of combustion air dampers for burners	Potentially limitations of combustion air supply, less combustion air, see low flow of combustion air.	Combustion air duct designed for stalling pressure of combustion air blower.			
Low (NG fuel gas)	Loss of NG fuel (see low flow)					
Low (purge)	Loss of purge gas (see low flow)					
Low (comb Air)	Loss of combustion air (see low flow)					

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO, CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T:36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Composition of feed gas	Higher HC not converted in prereformer	Potential carbon laydown in primary reformer H2001. Destruction of catalyst.	AP 2267 out of prereformer according to analysis schedule.  PDI 2283 (delta P across H2001 reactor)			
High / low HV	Composition of NG feed from BL	High /low temperature (see temperature)				
Reducing atmosphere in radiant camber	Low combustion air flow	Damage of reformer tubes due to reducing flue gas	See low flow of combustion air above  Assure uniform distribution of fuel and combustion air to individual burners			
<b>Parameter: Reaction</b>		<b>Intention:</b>				
Less reaction	Reduced activity of catalyst (poisoning or end of life)	Increased CH <sub>4</sub> slip to secondary reformer.	AP 2306 sample point for regular sampling of CH <sub>4</sub> content downstream H2001			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 5 Primary reformer (H2001)	P&ID no.: P15	Intention: Conversion of CH4 to H2, CO, CO2	Date: 11.06.2010
	Design P/T: 40.2 barg, 675 C inlet, 34.7 barg, 800 C outlet	Operating P/T:36.3 barg, 638 C inlet, 742 C outlet	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
Tube rupture	High temperature	<p>Damage of primary reformer</p> <p>Sudden increased flue gas temperature</p> <p>Reduced oxygen content in flue gas</p> <p>Potentially fire outside primary reformer</p>	<p>TI 2295, TI 2297, high alarm (flue gas)</p> <p>TSAH 2221, IS 1 trip (flue gas)</p>	29. Add rate of change alarm on temperature TI 2295 and TI 2297.	HTAS	*
Poisoning	<p>Sulphur</p> <p>Silica, Sodium, Potassium</p>	<p>Sulphur will reduce life time</p> <p>Dependent on cat history, reduces life time</p>	Ensure clean steam. Steam is added before pre-reformer and the problem will occur in the pre-reformer			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (reformed gas)	Failure of control loop, FV 2061 opens	Reduced O/C ratio  Reduced outlet temperature from R2004, No consequences  Increased CH <sub>4</sub> slip	AI 2479 (CH <sub>4</sub> analyser)  PDI 2323 high alarm	30. Add high alarm on AI 2479. (previously added, see action no. 28)	HTAS	


	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (reformed gas)	Loss of feed	Increased O/C ratio (see high temperature)  Increased reformer temperatures (see high temperature)  Potential damage of cat and equipment (see temperature)	FFI 2020, high O/C ratio alarm  Operator reduces O <sub>2</sub> flow by FIC 2007  FFSAH 2008, high O/C ratio, trip of secondary reformer (IS 2)  TI 2333 high temperature alarm  TSAH 2333 (outlet)  TI 2325 (temperature in combustion zone)  TSAH 2325 (temperature in combustion zone)	31. Consider automatic O/C ratio control as part of LTM	HTAS	*  *  *
No (reformed gas)	No feed  Tube rupture in primary reformer H2001	Increased reformer temperatures (see high temperature)  Potential damage of cat and equipment (see temperature)	FSAL 6070, IS1 trip which will trip IS 2  Tube rupture in H2001 should initiate IS 1.			*


	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (O <sub>2</sub> )	Malfunction of flow control FIC 2007	Increased O/C ratio  Increased reformer temp in R2004. Potential damage of cat, reformer and downstream equipment.	FFI 2020, high O/C ratio alarm  FFSAH 2008, high O/C ratio, trip of secondary reformer (IS 2)  TI 2333 high temperature alarm  TSAH 2333 (outlet)  TI 2325 (temperature in combustion zone)  TSAH 2325 (temperature in combustion zone)			*  *  *
Low (O <sub>2</sub> )	Malfunction of flow control FIC 2007  Upstream blockage, failure of O <sub>2</sub> supply (e.g. O <sub>2</sub> filer)	Low O/C ratio  Reduced outlet temperature from R2004, no consequences  Increased CH <sub>4</sub> slip	AI 2479 (CH <sub>4</sub> analyser)	32. Add high alarm on AI 2479. (previously added, see action no. 28)	HTAS	




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse ( HC in O <sub>2</sub> /steam)	Simultaneous failure of O <sub>2</sub> and steam supply	Explosion in O <sub>2</sub> -piping	Check valves  FIC 2040 low alarm on steam flow  FSAL 2040, trip, IS 2 steam flow			*
Reverse (O <sub>2</sub> into HC)	No feed flow	Explosion	IS 1 will activate IS 2 which will stop O <sub>2</sub> flow			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (inside R2004)	<p>Malfunction of flow control FIC 2007</p> <p>Increased O/C ratio</p>	<p>Increased reformer temperature in R2004. Potential damage of catalyst reformer and downstream equipment</p> <p>Increased HHP steam production</p> <p>Burner damage</p>	<p>FFI 2020, high O/C ratio alarm</p> <p>FFSAH 2008, high O/C ratio, trip of secondary reformer (IS 2)</p> <p>TI 2333 high temp alarm</p> <p>TSAH 2333 (outlet)</p> <p>TI 2325 (temp in comb zone)</p> <p>TSAH 2325 (temp in comb zone)</p> <p>TI 2329 high alarm internally in burner</p> <p>TSAH 2329, trip IS 2</p> <p>PDI 2320 (O<sub>2</sub> part of burner)</p>			<p>*</p> <p>*</p> <p>*</p> <p>*</p>

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (outside R2004)	Refractory damaged	Hot spots, damage of R2004	Visual inspection of reactor R2004 (thermal indicative paint)  Deluge (manually activated water spray) outside surface of reactor  Skin temp alarms TI 2328, 2326, 2327 2330, 2331, 2332 high alarms	33. Add note to PID defining water system	HTAS	
Low (inside R2004)	Low oxygen/steam flow (see above)					
Low (gas temperature out of primary reformer)		Increased CH <sub>4</sub> slip, no consequences  Reduced stream production	AI 2479 (CH <sub>4</sub> analyser)			
Low (O <sub>2</sub> )	Loss of steam to O <sub>2</sub> pre-heater, malfunction of PIC 2015	Condensate into burner. Potential damage of burner and refractory	TI 2047 low alarm on O <sub>2</sub> temp  TSAL 2047, trip IS 2 on low O <sub>2</sub> temp			*

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (gas)	Blocked outlet or stop of synthesis compressor C3001	Potential exceeding design pressure	PSV 2354 to 2359 after steam super heater (110% capacity)  PIC 2481 will open vent to flare			
Low (gas)	Open vent, PV 2481 or  Loss of feed (e.g. PV 2073 opens)	High flow (see high flow)  Low flow (see low flow)	PIC 3007, low alarm at synthesis gas compressor inlet			
High (O <sub>2</sub> supply)	High delivery pressure from BL	High O <sub>2</sub> flow (see high flow)				
Low (O <sub>2</sub> supply)	Low delivery pressure from BL  Failure of O <sub>2</sub> feed control	Low O <sub>2</sub> flow (see low flow)				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High pressure drop	Ruby formation (caused by impurities in refractory)	High pressure drop across R2004 and potentially hot spots.  Blockages of catalyst	PDI 2323 high alarm	34. Skimming of cat (change top layer) according to operating manual	MEKPCO	
<b>Parameter: Reaction</b>		<b>Intention:</b>				
Side reaction	See ruby formation			35. When replacing tiles ensure high quality of tiles to avoid ruby formation	MEKPCO	

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Slow reaction	Deactivated catalyst  Low temperature (see low temperature)	Increased temperature  Increased CH <sub>4</sub> slip	Catalyst volume is selected with ample surplus (has been considered by HTAS)  TI 2333, high alarm out of reformer  TSAH 2333, trip  AI 2479 (CH <sub>4</sub> )	36. High alarm on AI 2479 (previously added, see action no. 28)		*
Reaction	Soot formation	Soot formation during start up, black condensate, blockage of filters X6001 A/B	Soot filters  Start up procedure ensures short time operation in soot formation range			
<b>Parameter: Mixing</b>		<b>Intention:</b>				
O <sub>2</sub> and process gas	Burner damage	High temperature (see high temperature)				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Liquid in gas feed	NA					
Poisoning		No consequences for catalyst				
Liquid in O <sub>2</sub>	<p>Pockets of condensate in piping during start up</p> <p>Insufficient heating of steam and O<sub>2</sub></p>	<p>Damage of equipment</p> <p>Damage of refractory lining</p> <p>Damage of catalyst</p>	<p>Preheating of steam and O<sub>2</sub> according to manual</p> <p>TI 2047 Low temperature alarm</p> <p>TSAL 2047 trip</p> <p>Double block and bleed valve to prevent steam in O<sub>2</sub>. The bleed is from the bottom of the pipe</p> <p>No pockets (slope)</p> <p>Heat tracing to 250 C</p>	37. MEKPCO should supervise detailed design of piping layout according to HTAS requirements as indicated on the PIDs.	MEKPCO	*
Low S/C	See node 4	No consequences in this node				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 6a Secondary reformer (R2004)	P&ID no.: P16	Intention: Conversion of CH <sub>4</sub> to H <sub>2</sub> , CO and CO <sub>2</sub>	Date: 11.06.2010
	Design P/T: 34.7 barg (reactor R2004)	Operating P/T: 1600 C above catalyst in R2004 1000 C out of reactor R2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High S/C	See node 4	No consequences in this node				




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6b Waste heat boilers and steam super heaters (E2020, 2021 1/2/3)	P&ID no.: P 16, P17	Intention: Cooling of reformed gas	Date: 14.06.2010
	Design P/T: 31.0 barg, 575 C outlet E2020 1/2, 29.0 barg ,290 C outlet E2021 3	Operating P/T: 26.7 barg, 544 C outlet E2020 1/2, 26.3 barg ,260 C outlet E2021 3	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
Mal distributed flow	Mal distribution of flow  Incorrect position of damper out of waste heat boiler, THIC 2360 1/2/3/4.	Uneven temperature out of boilers E2020 1/2.  Exceeded design temp in E2021 1 or 2	Refractory lined in waste heat boilers  TI 2335, TI 2336 high alarm, inlet to E2021 1/2	38 Check mechanical design of E2021 1/2 for consequences of high temperature, alternatively include trip on high temp	HTAS	
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Mal distributed flow (see above)  Failure of TIC 2360 (on the super heated steam)	Uneven temperature out of boilers E2020 1/2.  Exceeding design temp in E2021 1 or 2	TI 2335, TI 2336 high alarm, inlet to E2021 1/2  TIC 2360 high alarm (super heated steam)  TSAH 2360, IS 1 (do not detect all failure modes, potential overheating of one train does not cause high temp of super heated steam)	39. Consider one THIC on each boiler operating both sets of dampers, TV 2360 1 and 2 and one THIC for TV 2360 3 and 4. <b>(Post HAZOP meeting HTAS decision as per 08.07.2010: Not recommended)</b>  40. Consider high temp alarm on TI 2351 and 2353 (gas	HTAS  HTAS	*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 6b Waste heat boilers and steam super heaters (E2020, 2021 1/2/3)	P&ID no.: P 16, P17	Intention: Cooling of reformed gas	Date: 14.06.2010
	Design P/T: 31.0 barg, 575 C outlet E2020 1/2, 29.0 barg ,290 C outlet E2021 3	Operating P/T: 26.7 barg, 544 C outlet E2020 1/2, 26.3 barg ,260 C outlet E2021 3	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
				<p>out of E2021 1/2) and TI 2355 and 2358 (steam out of E2021 1/2)</p> <p>41. Add failure modes of TV 2360 1/2/3/4 on PID and correct node 8</p> <p>42. Consider cascade control for TIC 2360 and TI 2335 and TI 2336 to prevent un- even flows</p>	HTAS  HTAS	
High	<p>Loss of S steam to E2021 1/2/3 by lifting PSVs on steam drum D2001</p> <p>Loss of steam to E2021 1/2/3 by closure of PV 2363 out of E2021 1/2</p>	Potential overheating of E2021 1/2/3	<p>If only one S steam PSV opens PIC 2361 vent will supply sufficient steam</p> <p>PIC 2361, high alarm (steam vent)</p> <p>TIC 2360 high alarm (super heated steam)</p> <p>TSAH 2360, IS 1</p>	<p>43. Correct FLO in- stead of FLC on PV 2363</p> <p>44. Consider LO on block valves before automatic vents</p>	HTAS  HTAS	*

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6b Waste heat boilers and steam super heaters (E2020, 2021 1/2/3)	P&ID no.: P 16, P17	Intention: Cooling of reformed gas	Date: 14.06.2010
	Design P/T: 31.0 barg, 575 C outlet E2020 1/2, 29.0 barg ,290 C outlet E2021 3	Operating P/T: 26.7 barg, 544 C outlet E2020 1/2, 26.3 barg ,260 C outlet E2021 3	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	Loss of circulating boiler water to E2020 1/2. Not possible  Mal distribution of steam between 2021 1/2 by un-symmetrical piping  Increasing pressure drop due to mechanical problems	High temperature, exceeding design temperature	TI 2352 high alarm (on process gas)  TI 2355 and TI 2356 (on the steam side)	45. Consider high alarm on TI 2355 and TI 2356 (previously added, see action no. 40)	HTAS	
Low (gas side)	Dampers in wrong position	Low steam temperature. Operational problems in the steam turbines. No consequences on gas side.				
Low (from reformer)	Low temp out of reformer	Low steam production, no consequence				

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6b Waste heat boilers and steam super heaters (E2020, 2021 1/2/3)	P&ID no.: P 16, P17	Intention: Cooling of reformed gas	Date: 14.06.2010
	Design P/T: 31.0 barg, 575 C outlet E2020 1/2, 29.0 barg ,290 C outlet E2021 3	Operating P/T: 26.7 barg, 544 C outlet E2020 1/2, 26.3 barg ,260 C outlet E2021 3	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	See node 6a					
Low	See node 6a					
<b>Parameter: composition</b>		<b>Intention:</b>				
Composition of gas	Low S/C ratio	Potential metal dusting causing equipment failure (super heaters)	See S/C in node 4			
Composition of gas	Low S/C ratio	Potential metal dusting causing equipment failure (waste heat boilers)	No potential problem as covered by design			
Impurities	Impurities in refractory lining	Fouling of waste heat boilers  High temp of process gas out of boilers (see high temperature)				

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 6b Waste heat boilers and steam super heaters (E2020, 2021 1/2/3)	P&ID no.: P 16, P17	Intention: Cooling of reformed gas	Date: 14.06.2010
	Design P/T: 31.0 barg, 575 C outlet E2020 1/2, 29.0 barg ,290 C outlet E2021 3	Operating P/T: 26.7 barg, 544 C outlet E2020 1/2, 26.3 barg ,260 C outlet E2021 3	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
Leakages (steam to gas side)	Tube rupture  Corrosion	Lower steam production, higher process condensate.  Increasing pressure (see high pressure)  Damage to refractory in boilers E2020 1/2				
Dust	Failure of refractory lining of tube sheet on waste heat boilers	Metal dusting on tube sheet  Dust carried over to downstream equipments (liquid side)	Waste heat boilers are supplied by prequali- fied vendor  Visual inspection of tube sheet during turn around			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 7 Process gas cooling I (E2022 1/2 and D2002)	P&ID no.: P19	Intention: Cooling of reformed gas by BFW preheaters	Date: 14.06.2010
	Design P/T: 29 barg, 390 C inlet E2022 1, 200 C downstream E2022 2	Operating P/T:26.3 barg ,260 C inlet E2022 25.8 barg 65 C down stream E2022 2	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (process gas)	Upstream failure	High temperature, see high temperature  Higher pressure  Higher pressure drop across E2022 1/2. Potential capacity restrictions  Minor liquid carry over from D2002, no critical consequence	See high flow in upstream nodes  PV 2406 (vent)  PIC 3007 high alarm at compressor suction side			
Low (process gas)	See reformer node	Low temperature, see low temperature				
Reverse flow	Upstream PSVs opens PV 2354-2359	No consequences				
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	High flow of gas	Exceeding design temperature	Sufficient margin in design temperature as			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 7 Process gas cooling I (E2022 1/2 and D2002)</p>	<p>P&amp;ID no.: P19</p>	<p>Intention: Cooling of reformed gas by BFW preheaters</p>	<p>Date: 14.06.2010</p>
	<p>Design P/T: 29 barg, 390 C inlet E2022 1, 200 C downstream E2022 2</p>	<p>Operating P/T:26.3 barg ,260 C inlet E2022 25.8 barg 65 C down stream E2022 2</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	<p>Loss/reduced of BFW</p> <p>High temperature in re-former</p> <p>Fouling, no consequence</p>		<p>condensation takes place in E2022 1/2</p> <p>TI 2352, high alarm, process gas to heat exchanger E2022 1/2</p> <p>FIC 2417 low flow alarm on BFW</p> <p>TI 2371 high alarm</p> <p>TI 2323 high alarm</p> <p>See high temperature alarms in reformer node</p>			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 7 Process gas cooling I (E2022 1/2 and D2002)</p>	<p>P&amp;ID no.: P19</p>	<p>Intention: Cooling of reformed gas by BFW preheaters</p>	<p>Date: 14.06.2010</p>
	<p>Design P/T: 29 barg, 390 C inlet E2022 1, 200 C downstream E2022 2</p>	<p>Operating P/T:26.3 barg ,260 C inlet E2022 25.8 barg 65 C down stream E2022 2</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Running at low capacity	Condensate in first shell E2022 1, which will result in corrosion (requires long time period with low temperature)	Normal operation is 50 C above dew point			
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Blocked outlet see node 6a and 6b  High pressure from pump and blocked outlet from pump	Exceeding design pressure	Design pressure corresponds to max shut off pressure			
Low (process gas)	Down stream or upstream vent is open	Low suction pressure for pump, pump cavitations, maybe damaged pump  Pumps cannot transfer liquid which results in high level in D2002 (see level)	Sufficient margin on NPSH			




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 7 Process gas cooling I (E2022 1/2 and D2002)	P&ID no.: P19	Intention: Cooling of reformed gas by BFW preheaters	Date: 14.06.2010
	Design P/T: 29 barg, 390 C inlet E2022 1, 200 C downstream E2022 2	Operating P/T:26.3 barg ,260 C inlet E2022 25.8 barg 65 C down stream E2022 2	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Dust from gas stream		Dust in liquid part of D2002.  Dust in gas part has no consequence in this node.	Strainer in pump inlet and downstream pressure gauge for the pump			
<b>Parameter: Level</b>		<b>Intention:</b>				
High	Stop of pumps  Failure of LIC 2403	Liquid carry over	LIC 2403 high alarm  Autostart of spare pump			
Low/no	Failure of LIC 2403	Cavitation and potential damage of pumps.  Stagnant gas in pumps as downstream pressure is higher than upstream pressure. Gas breakthrough not possible	LIC 2403 low alarm  LALL 2404 low level trip of pumps			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 7 Process gas cooling I (E2022 1/2 and D2002)	P&ID no.: P19	Intention: Cooling of reformed gas by BFW preheaters	Date: 14.06.2010
	Design P/T: 29 barg, 390 C inlet E2022 1, 200 C downstream E2022 2	Operating P/T:26.3 barg ,260 C inlet E2022 25.8 barg 65 C down stream E2022 2	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
Leakages (BFW into gas)	Tube rupture	High level in D2002 (see high level)  Exceeding design pressure of E2022 1/2 and D2002	Upstream PSVs 2354-2359  Vent 2406 downstream D2002 (50% of gas flow)  Vent PIC 2481 (full flow of gas)			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 8 Process gas cooling II (E2023, D2003)	P&ID no.: P19, P38	Intention: Cooling by MP column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.8 barg, 165 C inlet E2023 25.3 barg, 159 C downstream E2023	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (E2023)	Failure of TIC 5277	Increased duty transfer in re-boiler E2023, no consequence  Decreasing temp in D2023, no consequence				
High (total flow)		High temperature, see high temp  Higher pressure  Higher pressure drop across E2023. Potentially capacity restrictions  Minor liquid carry over from D2003, no critical consequence	See high flow in upstream nodes  PV 2406 (vent)  PIC 3007 high alarm at compressor suction side			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 8 Process gas cooling II (E2023, D2003)	P&ID no.: P19, P38	Intention: Cooling by MP column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.8 barg, 165 C inlet E2023 25.3 barg, 159 C downstream E2023	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (E2023)	Failure open of bypass valve TV 2577	Less transferred duty, no consequence  Higher outlet temperature of E2023, no consequence  Upsets in MP column T5003 (see node 17)				
Low total flow		No consequences				
Reverse flow	NA					
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Bypass fully open TV 5277 or  no MeOH	No consequence, temp is always below design temp.				
Low	Failure of TIC 5277	Increased duty transfer in re-boiler E2023, no consequence  Decreasing temp in D2003, no consequence				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 8 Process gas cooling II (E2023, D2003)	P&ID no.: P19, P38	Intention: Cooling by MP column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.8 barg, 165 C inlet E2023 25.3 barg, 159 C downstream E2023	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (E2023)	Blocked outlet see node 6a and 6b	Exceeding design pressure	Vent PV 2406  Vent PIC 2481  PSV 2354-2359			
Low (process gas)	Down stream or upstream vent is open	Less condensation in E2023, no critical consequence				
<b>Parameter: Level</b>		<b>Intention:</b>				
High (D2003)	Failure of LIC 2419	Liquid carry over to downstream nodes	LIC 2419 high level alarm			
Low (D2003)	Failure of LIC 2419	Gas break-through to D2004, no consequence	Same design pressure for D2003 and D2004  LIC 2419 low level alarm			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 8 Process gas cooling II (E2023, D2003)	P&ID no.: P19, P38	Intention: Cooling by MP column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.8 barg, 165 C inlet E2023 25.3 barg, 159 C downstream E2023	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
Leak	Gas into MeOH	Exceeding design pressure of MeOH side	PSV 5251 and PSV 5250 on top of MP column (designed for loss of reflux)	46. Consider installing PSV on shell side on E2023 for tube rupture as the current PSV 5250, 5251 are on the top of the MP column. <b>(Post HAZOP meeting HTAS decision as per 08.07.2010: Not recommended)</b>	HTAS	


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 9 Process gas cooling III (E2024 1/2, D2004)	P&ID no.: P20, P30	Intention: Cooling by stabilizer column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.3 barg, 159 C inlet E2024, 24.8 barg, 136 C inlet D2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (reboilers E2024)	Failure of TIC 5064	Increased duty transfer in re-boiler E2024, no consequence  Decreasing temp in D2004, no consequence				
High (total flow)		High temp, see high temp  Higher pressure  Higher pressure drop across E2024. Potential capacity restrictions  Minor liquid carry over from D2004, no critical consequence	See high flow in upstream nodes  PV 2406 (vent upstream)  PIC 3007 high alarm at compressor suction side			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 9 Process gas cooling III (E2024 1/2, D2004)	P&ID no.: P20, P30	Intention: Cooling by stabilizer column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.3 barg, 159 C inlet E2024, 24.8 barg, 136 C inlet D2004	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (E2024)	Failure open of bypass valve TV 5064	Less transferred duty, no consequence  Higher outlet temp of E2024, no consequence  Upsets in stabilizer column T5001 (see node 15)				
Low total flow		No consequence				
Reverse flow	NA					
Mal distributed flow between E2024 1 and 2	Uneven pressure drop	Decreased efficiency of tower T5001	Symmetrical piping specified by HTAS			
High flow from upstream separator D2003	Failure of level control FV 2419	High level in drum D2004 (see high level)				




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 9 Process gas cooling III (E2024 1/2, D2004)	P&ID no.: P20, P30	Intention: Cooling by stabilizer column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.3 barg, 159 C inlet E2024, 24.8 barg, 136 C inlet D2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Bypass fully open TV 5064 or no MeOH/water	No consequences, temperature is always below design temperature.  Upsets in T 5001				
Low	Failure of TIC 5064	Increased duty transfer in reboiler E2024 1/2, no consequence  Decreasing temp in D2004, no consequence				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (E2024 1/2)	Blocked outlet see node 6a and 6b	Exceeding design pressure	Vent PV 2406  Vent PIC 2481  PSV 2354-2359			
Low (process gas)	Down stream or upstream vent is open	Less condensation in E2024 1/2, no critical consequence				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 9 Process gas cooling III (E2024 1/2, D2004)	P&ID no.: P20, P30	Intention: Cooling by stabilizer column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T: 25.3 barg, 159 C inlet E2024, 24.8 barg, 136 C inlet D2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
High (D2004)	Failure of LIC 2441  Liquid from D2003 by failure of LV 2419	Liquid carry over to downstream nodes	LIC 2441 high level alarm  Potential liquid carry over is handled in the final separator. Normal condensate flow from D2003 is significant lower than normal condensate flow from D2004. Pumps are able to handle both.			
Low (D2004)	Failure of LIC 2441	Cavitation and potential damage of pumps.  Stagnant gas in pumps as downstream pressure is higher than upstream pressure. Gas breakthrough not possible	LIC 2441 low alarm  LALL 2442 low level trip of pumps			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 9 Process gas cooling III (E2024 1/2, D2004)	P&ID no.: P20, P30	Intention: Cooling by stabilizer column reboilers	Date: 14.06.2010
	Design P/T: 29 barg, 200 C	Operating P/T:25.3 barg, 159 C inlet E2024, 24.8 barg, 136 C inlet D2004	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
Leak	Gas into MeOH/water	Exceeding design pressure of MeOH/water side	PSV 5058 and PSV 5059 and 5060 on top of stabilizer column T5001 (designed for loss of reflux)	47. Consider installing PSV protecting shell side on E2024 for tube rupture as the current PSV 5058, 5059 and 5060 are on the top of the stabilizer column. <b>(Post HAZOP meeting HTAS decision as per 08.07.2010: Not recommended)</b>	HTAS	

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 10 Process gas cooling IV (E2025, AE 2026, E2027, D2005)	P&ID no.: P20, P21	Intention: Cooling in DMW preheater, air cooler and water cooler	Date: 14.06.2010
	Design P/T: 29 barg, 200 C upstream AE2026, 120 C inlet E2027, 100 C downstream E2027	Operating P/T: 24.8 barg, 138 C inlet E2025, 24.4 barg, 132 C inlet AE2026, 24.2 barg 65 C inlet E2027 24.0 barg, 48 C outlet D2005	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter:</b>	Flow	<b>Intention:</b>				
High ( E2025)	Failure of TIC 2457	Increased preheat temperature of demin water, See demin water node  Lower inlet temperature to AE 2026, no consequence				
High (total flow)	Open vent downstream, PV 2481  Upstream failure	High temp, see high temperature  Higher pressure  Higher pressure drop across E2025, AE2026, E2027. Potential capacity restrictions  Minor liquid carry over from D2005, potential damage to compressor.	See high flow in upstream nodes  PV 2481 (vent downstream)  PI C 3007 high alarm at compressor suction side  FT 2476 high flow alarm  PSV 2354-2359			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 10 Process gas cooling IV (E2025, AE 2026, E2027, D2005)	P&ID no.: P20, P21	Intention: Cooling in DMW preheater, air cooler and water cooler	Date: 14.06.2010
	Design P/T: 29 barg, 200 C upstream AE2026, 120 C inlet E2027, 100 C downstream E2027	Operating P/T: 24.8 barg, 138 C inlet E2025, 24.4 barg, 132 C inlet AE2026, 24.2 barg 65 C inlet E2027 24.0 barg, 48 C outlet D2005	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (E2025)	Failure open of bypass valve TV 2457	Less transferred duty, no consequence  Higher outlet temp of E2025, no consequence  Upsets in demin water for deaerator due to low demin water temperature (see node 26)				
Low total flow		No consequence				
Reverse flow of condensate	Back flow through LV 2474 or FV 2233	High level in D2005, liquid carry over, damage of compressors	Check valves at pump outlet (combined check valve and minimum flow)  LIC 2474 high alarm  LSAH 2474, trip of compressor IS40			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 10 Process gas cooling IV (E2025, AE 2026, E2027, D2005)	P&ID no.: P20, P21	Intention: Cooling in DMW preheater, air cooler and water cooler	Date: 14.06.2010
	Design P/T: 29 barg, 200 C upstream AE2026, 120 C inlet E2027, 100 C downstream E2027	Operating P/T: 24.8 barg, 138 C inlet E2025, 24.4 barg, 132 C inlet AE2026, 24.2 barg 65 C inlet E2027 24.0 barg, 48 C outlet D2005	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Failure of cooling flows (E2025, AE 2026, E2027)  High gas flow  High temperature upstream	Reduce capacity of compressor, C3001, No consequence	TI 2476 high alarm, out of D2005			
Low	Low gas flow  Low temperature upstream  Low temperature of cooling media  High flow of cooling media	No consequences				


	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 10 Process gas cooling IV (E2025, AE 2026, E2027, D2005)	P&ID no.: P20, P21	Intention: Cooling in DMW preheater, air cooler and water cooler	Date: 14.06.2010
	Design P/T: 29 barg, 200 C upstream AE2026, 120 C inlet E2027, 100 C downstream E2027	Operating P/T: 24.8 barg, 138 C inlet E2025, 24.4 barg, 132 C inlet AE2026, 24.2 barg 65 C inlet E2027 24.0 barg, 48 C outlet D2005	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Blocked outlet, e.g. at comp C3001  High pressure upstream  External fire below vessels	Potentially exceeding design pressure	PV 2481 (vent downstream)  PI C 3007 high alarm at compressor suction side  PSV 2354-2359	48. Change design pressure of comp C3001 inlet to 29 barg	HTAS	
High (out of pump P2003)	Blocked outlet	Exceeding design pressure	Design pressure is higher than max shut off pressure  Minimum flow (recycle)			
Low	Open vent downstream  Low pressure upstream	Capacity limitations  Compressor surge (see node 11)	PIC 3007 low alarm on compressor suction			
Low suction pressure to pump P2003	Low level in D2005	Cavitation	Large margin on NPSH  LIC 2474 low level alarm  Interlock LALL 2474, I35 trip of pumps P2003 A/B			


	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 10 Process gas cooling IV (E2025, AE 2026, E2027, D2005)	P&ID no.: P20, P21	Intention: Cooling in DMW preheater, air cooler and water cooler	Date: 14.06.2010
	Design P/T: 29 barg, 200 C upstream AE2026, 120 C inlet E2027, 100 C downstream E2027	Operating P/T: 24.8 barg, 138 C inlet E2025, 24.4 barg, 132 C inlet AE2026, 24.2 barg 65 C inlet E2027 24.0 barg, 48 C outlet D2005	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low discharge pressure at pumps P2003	Stop of pumps	High level in D2005 (see high level)				
<b>Parameter: Composition</b>		<b>Intention:</b>				
Liquid	Liquid carry over from upstream node	No consequence				
<b>Parameter: Level</b>		<b>Intention:</b>				
High	Stop of pumps P2003	Liquid carry over, damage to compressor	LIC 2474 high alarm LSAH 2474, trip of compressor IS40 Autostart of standby pump			*
Low (D2005)	Failure of level control LV 2474	Cavitation of pumps Gas break-through, not possible as pressure downstream is higher than upstream pressure	LIC 2474 low alarm LALL 2474, trip of pumps P2003 IS35			*




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 10 Process gas cooling IV (E2025, AE 2026, E2027, D2005)	P&ID no.: P20, P21	Intention: Cooling in DMW preheater, air cooler and water cooler	Date: 14.06.2010
	Design P/T: 29 barg, 200 C upstream AE2026, 120 C inlet E2027, 100 C downstream E2027	Operating P/T: 24.8 barg, 138 C inlet E2025, 24.4 barg, 132 C inlet AE2026, 24.2 barg 65 C inlet E2027 24.0 barg, 48 C outlet D2005	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
Leaks in E2025	Tube rupture	Process gas to demin water, potentially exceeding design pressure	PSV 2458 on demin water side, designed for tube rupture			
Leaks in E2027	Tube rupture	Process gas to cooling water, potentially exceeding design pressure	PSV 2494 on cooling water side, designed for tube rupture			
Leaks in AE 2026	Tube rupture	Synthesis gas release to atmosphere (toxic and flammable)	Fire and gas detection system  Located in classified area	49. Fire and gas detection system (entire plant) to be considered by detailed engineering	MEKPCO	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 11 Synthesis gas compressor (C3001/C3002)	P&ID no.: P22	Intention: Compression of synthesis gas	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter:</b>		<b>Intention:</b>				
				50. Detailed HAZOP on compressor C3001/C3002 to be made when documentation is available from compressor vendor (PIDs) for compliance with HTAS process specifications.	MEKPCO/detailed engineering contractor	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 12a Synthesis loop (E3001 1, R3001 1)	P&ID no.: P22, P24, P25 Design P/T:	Intention: conversion of H <sub>2</sub> , CO and CO <sub>2</sub> into crude MeOH and H <sub>2</sub> O Operating P/T:	Date: 15.06.2010


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (discharge compressor)	High flow from compressor discharge	Increased pressure drop  Low temperature in tube sheet  Increased conversion in R3001 1/2/3.	Flow limited by compressor performance			
Low	Low flow from compressor	High temperature in tube sheet, exceeding design temperature, see high temp  Reduced conversion and capacity, low steam production and low MeOH production				
Mal distributed flow	Uneven pressure drop  Restricted flow from reactor R3001 1/2/3	High temperature in one reactor, potential exceeding design temperature (see high temperature)	Symmetrical piping  Pressure drop across reactors are high (about 2 bars) – higher than pressure drop in piping/exchangers			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 12a Synthesis loop (E3001 1, R3001 1)	P&ID no.: P22, P24, P25	Intention: conversion of H <sub>2</sub> , CO and CO <sub>2</sub> into crude MeOH and H <sub>2</sub> O	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Low flow through reactor R3001 1/2/3  Insufficient cooling for catalyst tubes in R3001 1/2/3	Overheating of catalyst, exceeding design temperature of reactor R3001 and downstream equipment.  Long term operation at higher temperature will reduce catalyst life time	TI 3081 high alarm (reactor outlet)  TI 3080 high alarm (top of upper tube sheet)  TAHH 3080 (top of upper tube sheet), trip I47, reduces set point of TIC 3113 by 10 degrees, and thereby opens bypass  TSAH 3080, trip IS 3, trip compressor and stops synthesis (top of upper tube sheet)  PIC 3042 high alarm, steam pressure			*  *
High (out of E3001 1/2/3)	High temp out of E3001 1/2/3 due to high temperature in R3001 1/2/3	Increasing temperature  Potentially overheating of cat.  Potentially exceeding design temperature	Bypass around E3001 1/2/3 controlled by TIC 3113	51. Add high alarm on TIC 3113 and TIC 3116 and TIC 3118	HTAS	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 12a Synthesis loop (E3001 1, R3001 1)	P&ID no.: P22, P24, P25	Intention: conversion of H <sub>2</sub> , CO and CO <sub>2</sub> into crude MeOH and H <sub>2</sub> O	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (out of E3001 1/2/3)	<p>Low reactor R3001 outlet temperature</p> <p>Malfunctioning of bypass</p> <p>Low pressure in steam drum D3003</p>	<p>Increased wax production (impurities (corrosion products) in synthesis gas) when temperature is below 200 C (deposited downstream)</p> <p>Less reaction</p> <p>Affects evaporation in saturation T6001 (see node 33)</p>	<p>TI 3081 (reactor outlet) low alarm</p> <p>PIC 3042, low alarm, low steam pressure</p>			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 12a Synthesis loop (E3001 1, R3001 1)	P&ID no.: P22, P24, P25	Intention: conversion of H <sub>2</sub> , CO and CO <sub>2</sub> into crude MeOH and H <sub>2</sub> O	Date: 15.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Insufficient conversion in R3001  Blockages downstream  External fire	High pressure from compressor discharge  Exceeding design pressure	Full flow PSV within vendor scope for C3001/C3002 package  PIC 3166 A high alarm at HP separator outlet, controlling the purge rate  PIC 3166 B, venting to flare  PSV 3163 located on D3001  PSV 3021 upstream E3001			
Low	Lower discharge pressure from compressor  High purge rate by failure of FIC 3169  Vent open, PIC 3166 B	Reduced efficiency  Reduced conversion	PIC-3166 A low alarm at HP separator outlet			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 12a Synthesis loop (E3001 1, R3001 1)	P&ID no.: P22, P24, P25	Intention: conversion of H <sub>2</sub> , CO and CO <sub>2</sub> into crude MeOH and H <sub>2</sub> O	Date: 15.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High delta P	Blocked catalyst  High flow	Reduced circulation rate and reduced capacity. Potential damage of internals in R3001  Potential damage of catalyst	PDI 3112 high alarm			
<b>Parameter: Composition</b>		<b>Intention:</b>				
Carbonyls	Synthesis gas in combination with carbon steel above 150 C can form carbonyls	Carbonyls catalyse wax formation in R3001	Selection of stainless steel in synthesis loop  Proper precommissioning (cleaning of pipes and equipment from iron dust)			
Low module (2.05)	Improper operation of reformer section	Operation below stoichiometric ratio 2.0 will cause module at inlet at reactor to drop further and increase byproduct formation	AFI 3004 1, low alarm for module, makeup gas inlet  AFI 3004 2, low alarm for module, outlet E3001 1			
High module	Improper operation of reformer section	Lower loop efficiency, more purge, less production, no consequence				


	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 12a Synthesis loop (E3001 1, R3001 1)	P&ID no.: P22, P24, P25 Design P/T:	Intention: conversion of H <sub>2</sub> , CO and CO <sub>2</sub> into crude MeOH and H <sub>2</sub> O Operating P/T:	Date: 15.06.2010

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Liquid	Condensation in MeOH reactor R3001 during shut down	Damage of catalyst	Temperature in R3001 below values given in operating manual, purge with N <sub>2</sub> is required			
<b>Parameter: Reactions</b>		<b>Intention:</b>				
Run away (R3001 1/2/3)		No run away reaction				
By products	High temperature High partial pressure of CO	Increases formation of : Ethanol and higher alcohols Ketones e.g. MEK acetone, methyl formation DME Low quality product?				
<b>Parameter: Other</b>		<b>Intention:</b>				
Leaks (E3001)	Tube rupture	Reduced production				
Leaks (R3001)	Tube rupture	Gas into steam system, potential exceeding design pressure	PIC 3042 high alarm on steam pressure PSV 3047, PSV 3048, designed for max production of steam			




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 12a Synthesis loop (E3001 1, R3001 1)	P&ID no.: P22, P24, P25	Intention: conversion of H <sub>2</sub> , CO and CO <sub>2</sub> into crude MeOH and H <sub>2</sub> O	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Poisoning	e.g. Sulphur chlorine, arsenic	Deactivation of catalyst	See node 2  Chlorine and arsenic are not expected  Impurities in steam is handled in prere- former			
	Condensation on catalyst	Weakening of catalyst				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 12b Synthesis loop (AE3002, E3003, D3001)	P&ID no.: P26, P27	Intention: Cooling of synthesis gas and separation of crude MeOH from recycle gas.	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High	See above (12a)	Less cooling (see high temp)  Entrainment in D3001 (liquid to comp causing comp damage)	FI 3167 high alarm  D3001 equip with demister			
Low	See above	More cooling (see low temp)  Problems with transfer of gas from FE exchanger to air cooler. Air cooler located high causing fluctuation in flow due to slugs	Reduced pipe size to increase flow velocity			
Mal distribution	Uneven pressure drop	See high / low flow				

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 12b Synthesis loop (AE3002, E3003, D3001)	P&ID no.: P26, P27	Intention: Cooling of synthesis gas and separation of crude MeOH from recycle gas.	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Loss of cooling media  High gas flow  Wax deposit in E3003	Exceeding design temperature	Sufficient margin on design temperature  Cannot loose two coolers simultaneous, air cooler will always provide some cooling  TI 3142, high alarm, outlet air cooler  TI 3164, high alarm outlet HP separator			
Low	Low gas flow  Low temp out of E3001/reactor R3001	More condensation, no consequences				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	See above					
Low	See above					
High pressure drop	Wax deposits in demister in D3001, on LV 6133 ( liquid outlet of HP separator ) and in loop water cooler	Poor performance of recycle compressor C3002, reduced production	Water cooler designed for maintenance (cleaning of wax)  PDI 3024, across synthesis loop			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 12b Synthesis loop (AE3002, E3003, D3001)	P&ID no.: P26, P27	Intention: Cooling of synthesis gas and separation of crude MeOH from recycle gas.	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High	External fire		PSV 3163 on D3001			
<b>Parameter: Level</b>		<b>Intention:</b>				
High in D3001	Mal function of LIC 3161  Wax deposits on LST 3161	Liquid carry over  Damage to compressor C3001/2	Traced the impulse lines, LST are with dia- phragm seals  Spare control valve LV 3161 A/ 3161 B for cleaning during operation  LIC 3161 high alarm  LSAH high alarm, IS 3 trip			*
Low	Mal function of LIC 3161	Gas break-through to D3002 (low pressure separator)  Exceeding design pressure downstream	LIC 3161 low alarm  LSAL 3161, trip IS 42 (closes downstream valves to prevent gas break-through)			*
<b>Parameter: Other</b>		<b>Intention:</b>				
Leaks in E3003	Tube rupture	Process gas to cooling water, potentially exceeding design pressure	PSV 3143 on cooling water side, designed for tube rupture			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 12b Synthesis loop (AE3002, E3003, D3001)	P&ID no.: P26, P27	Intention: Cooling of synthesis gas and separation of crude MeOH from recycle gas.	Date: 15.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Leaks in AE 3002	Tube rupture	Synthesis gas release to atmosphere (toxic and flammable)	<p>Fire and gas detection system</p> <p>Located in classified area</p>	52. Fire and gas detection system (entire plant) to be considered by detailed engineering (previously added, see action 49)	MEKPCO	

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 13 LP separator (D3002, X3001)	P&ID no.: P28	Intention: Partly degassing of crude MeOH	Date: 16.06.2010
	Design P/T: 10.0 barg, 100 C at inlet D3002 8.0 barg, 100 C downstream D3002	Operating P/T: 4.0 barg, 48 C	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High	Failure of upstream level control LIC 3161	High level D3002, potential gas break-through from D3001 causing high pressure (see high pressure)	LIC 3161 low alarm  LSAL 3161, trip IS 42 (closes downstream valves to prevent gas break-through)			*
Low	Failure of upstream level control LIC 3161	No consequence				
Reverse flow	PSV not closing after relief	Back flow of gases from flare header creating stagnant atmosphere in separator D3002 during shut down		53. Assure blockages of all connecting pipes including PSVs before entering vessel, see node 37	MEKPCO	
<b>Parameter: Temp</b>		<b>Intention:</b>				
High (out of HP sep)	High inlet temp.	More flashing  More wax to raw MeOH tank, TK5001	TI 3164 high alarm  See upstream node			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 13 LP separator (D3002, X3001)	P&ID no.: P28	Intention: Partly degassing of crude MeOH	Date: 16.06.2010
	Design P/T: 10.0 barg, 100 C at inlet D3002 8.0 barg, 100 C downstream D3002	Operating P/T: 4.0 barg, 48 C	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Low inlet temp	Less flashing  More dissolved gas in MeOH stream				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Failure of PIC 3194 (gas to fuel)  Gas break-through        Failure of LIC 3192 (blocked outlet)	Increased inerts in raw MeOH  Exceeding design pressure       High level (see high level)	PSV 3196, 3197  FO3191 (on LP sep inlet line), restricting the gas break-through flow     PIC 3194 (opens vent)  PIC 3194 high alarm  PSV 3196, 3197			


	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 13 LP separator (D3002, X3001)	P&ID no.: P28	Intention: Partly degassing of crude MeOH	Date: 16.06.2010
	Design P/T: 10.0 barg, 100 C at inlet D3002 8.0 barg, 100 C downstream D3002	Operating P/T: 4.0 barg, 48 C	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	Blocked filters, X3001 A/B/C  External fire	Exceeding design pressure of vessel	PSV 3196, 3197			
Low	Failure of PIC 3194	No consequences (D3002 float- ing on fuel gas header pressure)				
High pressure drop across fil- ter	Wax deposits in filters X3001 A/B/C	High level in D3002	PDI 3200 high alarm  Automatic switching between filters X3001 A/B/C on high delta P  PDAHH 3200 causing I48, which opens bypass valve UV 3199 on high delta P, I48	54. Filters are still under evaluation. HTAS has to specify details	HTAS	*




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 13 LP separator (D3002, X3001)	P&ID no.: P28	Intention: Partly degassing of crude MeOH	Date: 16.06.2010
	Design P/T: 10.0 barg, 100 C at inlet D3002 8.0 barg, 100 C downstream D3002	Operating P/T: 4.0 barg, 48 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Wax on instrumentation	Impurities in synthesis gas (corrosion products). Was deposits at low temperature	Mal function of instruments	Diaphragm seals on level transmitters and PDT 3200	55. Add heat tracing on instrument piping to/from level transmitters, level gauges and PDT 3200.  56. Add note on PIDs on Shortening instrument piping as much as possible	HTAS  HTAS	
Wax on valves	Impurities in synthesis gas (corrosion products). Was deposits at low temperature	Mal function of valve LV 3192  Mal function of valve UV3199 or blockage of bypass	Upstream wax filters	57. Consider tracing of bypass piping	HTAS	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 13 LP separator (D3002, X3001)	P&ID no.: P28	Intention: Partly degassing of crude MeOH	Date: 16.06.2010
	Design P/T: 10.0 barg, 100 C at inlet D3002 8.0 barg, 100 C downstream D3002	Operating P/T: 4.0 barg, 48 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
High (D3002)	Failure of upstream level control  Failure of level control LIC 3192   Blockages of filets	Liquid to purge/fuel system	LIC 3129 high alarm  LSAH 3192, trip IS 42 (closes inlet to D3002)   See high delta P			*
Low	Failure of level control LIC 3192	Gas into raw MeOH tank TK5001, potentially over pressurising tank (see node 14)	LIC 3129 low alarm  LALL 3192, I43 (closes outlet valve LV 3192)			*

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 14 Raw methanol tank (TK5004)	P&ID no.: P29	Intention: Storage of raw MeOH	Date: 16.06.2010
	Design P/T: 4.5 barg, 100 C	Operating P/T: 1.0 barg, 47 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High	More MeOH from separator, Failure of LIC 3192	High level, high pressure	LI 5001 High alarm  LAHH 5002 high alarm, interlock I44 (closes upstream valve LV 3192)  PSV 5006			*
High	Recycle from MeOH polisher X5001  Recycle from MeOH product tank via transfer pump, P5008	High level, high pressure	LI 5001 High alarm  LAHH 5002 high alarm, interlock I44 (closes upstream valve LV 3192)  PSV 5006			*
Low (total)		Low level in tank, low suction pressure for pumps P5001 A/B	LI 5001 low alarm  LALL 5002, I53 trip (stop of pumps)			*
Low ( from morpholine dosing pump)	Blocked outlet	Exceeding design pressure of discharge line	PSV 7235, 7238			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 14 Raw methanol tank (TK5004)	P&ID no.: P29	Intention: Storage of raw MeOH	Date: 16.06.2010
	Design P/T: 4.5 barg, 100 C	Operating P/T: 1.0 barg, 47 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse		Raw MeOH into upstream piping	Inlet pipe located high to prevent back flow from tank			
Reverse	Dosing pump failure, P7080 A/B	Back flow of MeOH into morpholine system	Check valves (at pump discharge and at mixing point)  Reciprocating pump			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	High inlet temperature from D3002 by failure of water cooler E3003	Increased evaporation from tank TK 5001.  Slip of MeOH vapour	Washing of vapour from T 5004  TI 3146 high alarm (out of HP separator D3001)  Vapour is used as combustion air in the reformer (not during reformer shut down)			
Low	Not possible					

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 14 Raw methanol tank (TK5004)	P&ID no.: P29	Intention: Storage of raw MeOH	Date: 16.06.2010
	Design P/T: 4.5 barg, 100 C	Operating P/T: 1.0 barg, 47 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention: Atmospheric conditions</b>				
High	Blocked outlet from T5004 by failure of vent valve UV 5021  Failure of valve UV 2125 (FC)  Gas break-through from separator D3002  External fire  PCV 5009 FO	Exceeding design pressure	PI 5004 high alarm (On TK 5001)  PSV 5007 ( breather valve)  PSV 5006 (relief valve)  See node 13 low level  PSV 5006 (relief valve)  PSV 5006 (relief valve), vent line dimensions are sufficient			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 14 Raw methanol tank (TK5004)	P&ID no.: P29	Intention: Storage of raw MeOH	Date: 16.06.2010
	Design P/T: 4.5 barg, 100 C	Operating P/T: 1.0 barg, 47 C	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Emptying tank TK 5001 and simultaneous failure of PCV 5009	Vacuum during emptying tank TK5001  Air ingress, flammable atmosphere	PI 5004 low alarm  PCV 5009 which will open at low pressure, N2 make up  PSV 5007 (breather)  Tank internal/external is classified			
<b>Parameter: Composition</b>		<b>Intention:</b>				
High concentration of MeOH	Recycle of MeOH to TK 5001 and distillation water to saturator	No consequences				
By products	Upstream wax formation	Wax in tank TK5001	Upstream wax filter X3001			
No morpholine injection	Failure of dosing pump	Potentially increased corrosion due to formic acid in distillation and product sections  Too low pH	AP 5019, manual analysis to be made according to analytical manual  AP 5010, upstream raw MeOH tank			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 14 Raw methanol tank (TK5004)	P&ID no.: P29	Intention: Storage of raw MeOH	Date: 16.06.2010
	Design P/T: 4.5 barg, 100 C	Operating P/T: 1.0 barg, 47 C	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
High	No liquid draw from tank (pump failure P5001 A/B)	Static head build up (high static pressure at the PSVs)  Tank rupture	LI 5001 high alarm  LAHH 5002, I44 block of product from separator D3002	58. Check PSV 5006 layout to avoid static pressure build up	HTAS	*
Low	Shut down of upstream section (synthesis)	Pump cavitation P5001 A/B	LI 5001 low alarm  LALL 5002, trip I53 (shut down of pumps)			*


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B, E2024 1/2 P5002 A/B)</p>	<p>P&amp;ID no.: P29, P30, P31, P32, P33</p>	<p>Intention: Stripping of volatile compounds and dissolved gases</p>	<p>Date: 16.06.2010</p>
	<p>Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B</p>	<p>Operating P/T: 1 barg, 47 C inlet to pump P5001 A7B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (inlet to T5001)	Failure of LIC 5041 (open)	Level build up in T5001, damage to column trays, operational disturbances in distillation sections	LIC 5041 high alarm PDI 5048 high alarm LI 5042, indicator	59. Consider adding high alarm on LI 5042	HTAS	
High (reflux)	Failure of FV 5093	Low level in overhead separator, only operational disturbances				
High (steam flow in reboiler)	Steam valve opens from closed position	Much more reboiling Increasing flow in column, and ultimately increasing pressure Damage of trays in column	See reverse flow	60. Check if system can handle three reboiler in operation at same time alternative consider blocking in E5001	HTAS	




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B, E2024 1/2 P5002 A/B)</p>	<p>P&amp;ID no.: P29, P30, P31, P32, P33</p>	<p>Intention: Stripping of volatile compounds and dissolved gases</p>	<p>Date: 16.06.2010</p>
	<p>Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B</p>	<p>Operating P/T: 1 barg, 47 C inlet to pump P5001 A7B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (inlet to T5001)	Failure of LIC 5041 (closed)	Small increased vapour flow from top of column T5001				
Low (reflux)	<p>Closure of valve FV 5093</p> <p>Stop of reflux pump P5003 A/B</p>	<p>Liquid level will build up</p> <p>Pressure will increase</p> <p>Liquid carry over to coolers and fuel system</p> <p>Liquid into fuels system could disturb burner performance</p>	<p>LIC 5093 high alarm (on separator D5001)</p> <p>FIC 5093 low alarm (on reflux)</p> <p>PSV 5059, 5058, 5060 designed for loss of reflux</p> <p>Autostart of standby reflux pump</p> <p>Separator can contain loss of reflux for 8 minutes (based on empty drum)</p> <p>LI 5094, indicator</p>	61. Consider adding high alarm on LI 5094	HTAS	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B, E2024 1/2 P5002 A/B)</p>	<p>P&amp;ID no.: P29, P30, P31, P32, P33</p>	<p>Intention: Stripping of volatile compounds and dissolved gases</p>	<p>Date: 16.06.2010</p>
	<p>Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B</p>	<p>Operating P/T: 1 barg, 47 C inlet to pump P5001 A/B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
No flow from pumps (P5001 A/B, P5002 A/B or P5003 A/B)	Blocked outlet	Cavitation, potential damage of pump	Minimum flow valves protects pumps (P5001 A/B, P5002 A/B, P5003 A/B)			
Reverse (off gas to fuel header)	Ejector switches off	Back flow of fuel from header to D5001.  Potentially exceeding design pressure	Check valve  PIC 5091 high alarm  PIC 5109, Vent to flare  PSV 5058, 5059, 5060			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (overhead system)	Failure of air cooler AE 5004	Low reflux flow  High pressure	(see reverse flow)			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B, E2024 1/2 P5002 A/B)</p>	<p>P&amp;ID no.: P29, P30, P31, P32, P33</p>	<p>Intention: Stripping of volatile compounds and dissolved gases</p>	<p>Date: 16.06.2010</p>
	<p>Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B</p>	<p>Operating P/T: 1 barg, 47 C inlet to pump P5001 A7B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (tube inside reboiler)	No liquid to reboiler	Exceeding design temperature	Design temperature selected accordingly			
Low		Reduced stripping efficiency, no consequences				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	<p>Failure of air cooler AE 5004</p> <p>Loss of reflux flow</p> <p>Tube rupture in E2024 1/2</p> <p>External fire</p>	Exceeding design pressure	<p>PIC 5091 high alarm</p> <p>PIC 5109, Vent to flare</p> <p>PSV 5058, 5059, 5060</p>			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B,E2024 1/2 P5002 A/B)</p>	<p>P&amp;ID no.: P29, P30, P31, P32, P33</p>	<p>Intention: Stripping of volatile compounds and dissolved gases</p>	<p>Date: 16.06.2010</p>
	<p>Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B</p>	<p>Operating P/T: 1 barg, 47 C inlet to pump P5001 A7B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	No N2	Operational disturbances				
	Shut in of tower during cooling	Vacuum	Tower is designed for full vacuum			
<b>Parameter: Composition</b>		<b>Intention:</b>				
Pure water in tower	start up, mistake	Increasing boiling temperature	Tower is designed for boiling point of water			
Pure MeOH	Recycle of off-spec MeOH	Operating at lower temperature, no off gasses, decreasing pressure, N2 make up required				

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B,E2024 1/2 P5002 A/B)	P&ID no.: P29, P30, P31, P32, P33	Intention: Stripping of volatile compounds and dissolved gases	Date: 16.06.2010
	Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B	Operating P/T: 1 barg, 47 C inlet to pump P5001 A7B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
High (in T5001)	Blocked outlet, closure of FIC 5161	Increasing level in T5001  Potential damage of trays	LIC 5041 high alarm  PDI 5048 high alarm  LI 5042			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B, E2024 1/2 P5002 A/B)</p>	<p>P&amp;ID no.: P29, P30, P31, P32, P33</p>	<p>Intention: Stripping of volatile compounds and dissolved gases</p>	<p>Date: 16.06.2010</p>
	<p>Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B</p>	<p>Operating P/T: 1 barg, 47 C inlet to pump P5001 A7B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (D5001)	<p>Closure of valve FV 5093</p> <p>Stop of reflux pump P5003 A/B</p>	<p>Liquid level will build up</p> <p>Pressure will increase</p> <p>Liquid carry over to coolers and fuel system</p> <p>Liquid into fuels system could disturb burner performance</p>	<p>LIC 5093 high alarm (on separator D5001)</p> <p>FIC 5093 low alarm (on reflux)</p> <p>PSV 5059, 5058, 5060 designed for loss of reflux</p> <p>Autostart of standby reflux pump</p> <p>Separator can contain loss of reflux for 8 minutes (based on empty drum)</p> <p>LI 5094, indicator</p>	<p>62. Consider adding high alarm on LI 5094 (previously added, see action no. 61)</p>	HTAS	
High (E5010 over head gas condenser)		Liquid to fuel system	Designed for self draining			
High (reboiler)	Not possible					


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 15 Methanol stabilizer (P5001 A/B, T5001, AE 5004, D5001, P5003 A/B,E2024 1/2 P5002 A/B)</p>	<p>P&amp;ID no.: P29, P30, P31, P32, P33</p>	<p>Intention: Stripping of volatile compounds and dissolved gases</p>	<p>Date: 16.06.2010</p>
	<p>Design P/T: 4.5 barg, 100 C inlet to pump P5001 A/B 11.0 barg, 100 C inlet T5001 3.5 barg, 150 C out of top T5001 4.5 barg, 150 after LP separator 5.0 barg 150 C after P5003 A/B 5.0 barg, 160 C out of bottom T5001 8.0 barg, 160 C after P5002 A/B</p>	<p>Operating P/T: 1 barg, 47 C inlet to pump P5001 A7B 5.0 barg, 47 C inlet T5001 0.7 barg, 78 C out of top T5001 0.6 barg, 65C after air cooler 2.7 barg, 65 C after P5003 A/B 1.0 barg, 88 C out of bottom T5001 2.5 barg, 88 C after P5002 A/B</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (in T5001)	Failure of valve FV 5161 (opens)	Pump cavitation, P5002 A/B	LIC 5041 low alarm  LALL 5042, I54 (stop of pump, P5002 A/B)			*
Low (D5001)	Failure of reflux valve FV 5093 (open)	Pump cavitation, P5003 A/B	LIC 5093 low alarm  LALL 5094, I56 (stop of pump, P5003 A/B)			*
Low (reboilers)	Loss of liquid inlet from take off tray	Operational upsets, decreasing duty		63. Check design temperature of tubes in reboiler E5001 (dry running)	HTAS	


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 16 LP Methanol Column (T5002, P5005 A/B)	P&ID no.: P27, P34, P 36, P37, P40	Intention: Distillation of MeOH	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B	Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (inlet to T5002)	Failure of LIC 5161 (open)	Level build up in T5002, damage to column trays, operational disturbances in distillation sections	LIC 5161 high alarm PDI 5167 high alarm LI 5162, indicator	64. Consider adding high alarm on LI 5162	HTAS	
High (reflux)	Failure of FIC 5203 (open)  Failure of FV 5337 (closed)	Low level in overhead separator, pump cavitation P5004 A/B (see low level)  Disturbances in separation				
High (vapour outlet to atmosphere)	Open vent, PV 5207	Increased N2 consumption				




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 16 LP Methanol Column (T5002, P5005 A/B)</p>	<p>P&amp;ID no.: P27, P34, P 36, P37, P40</p>	<p>Intention: Distillation of MeOH</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B</p>	<p>Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (bottom product)	Failure of valve FV 5239 (open)	See low level				
Low (inlet to T5002)	Failure of LIC 5161 (closed)	Minor increasing overhead vapour flow from top of column T5002, no consequences				
Low (reflux)	Closure of valve FV 5203  Stop of reflux pump P5004 A/B	Liquid level will build up  Off-spec MeOH  Minor pressure increase  Liquid carry over to atmosphere (venting) See high level	LIC 5203 high alarm (on separator D5002)  FIC 5203 low alarm (on reflux)  Autostart of standby reflux pump  LI 5204, indicator	65. Consider adding high alarm on LI 5204	HTAS	
Low (product)	Failure of FV 5337 (closed)	Increased reflux flow, more MeOH in T5002  High level in D5002 (see high level)				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 16 LP Methanol Column (T5002, P5005 A/B)	P&ID no.: P27, P34, P 36, P37, P40	Intention: Distillation of MeOH	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B	Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (column bottom)		See high level				
No flow from pumps (P5005 A/B)	Blocked outlet	Cavitation, potential damage of pump, P5005 A/B	Minimum flow valve protects pumps, P5005 A/B			
No flow from P5004	Closure of FV 5203 and FV 5337	Cavitation, potential damage of pump P5004 A/B	Minimum flow valve protects pumps, P5004 A/B			
Low (reboiler)	Low level in column	Exceeding design temperature of reboiler (not possible)				
Reverse ( of column bottom)	Pump failure	Gas break-through from T5003.  Potentially exceeding design pressure	Check valve  Normal back pressure does not exceed design pressure of T5002			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 16 LP Methanol Column (T5002, P5005 A/B)	P&ID no.: P27, P34, P 36, P37, P40	Intention: Distillation of MeOH	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B	Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (overhead system)	Failure of air cooler AE 5005	Low reflux flow  High pressure	PV 5207 (open vent)  PIC 5207 high alarm  PSAH 5207(on D5002), IS 4, shut down of distillation section (to prevent large releases to atmosphere)  The maximum pressure possible at reboiler temperature at 102 C is below 3.5 barg			*
High (to storage)	Loss of cooling	Increased evaporation from storage	TI 5381 high alarm (on combined product run down)			
High (tube inside reboiler)	No liquid to reboiler	Exceeding design temperature	Design temperature selected accordingly			
Low	Low temperature of heating media to reboiler	Potential reduced reboiler duty  Reduced capacity of column				

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 16 LP Methanol Column (T5002, P5005 A/B)	P&ID no.: P27, P34, P 36, P37, P40	Intention: Distillation of MeOH	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B	Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Failure of air cooler AE 5005  Loss of reflux flow  Tube rupture in E5002 1/2/3/4  External fire	Increasing pressure	PIC 5207 high alarm  PSAH 5207, IS 4 trip, stop of distillation  PSV 5179			*
Low	No N2   Shut in of tower during cooling	Operational disturbances   Vacuum	Tower is designed for full vacuum			
<b>Parameter: Composition</b>		<b>Intention:</b>				
Pure water in tower	start up, mistake	Increasing boiling temperature	Tower is designed for boiling point temperature of water			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 16 LP Methanol Column (T5002, P5005 A/B)	P&ID no.: P27, P34, P 36, P37, P40	Intention: Distillation of MeOH	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B	Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Pure MeOH	Recycle of off-spec MeOH	Operating at lower temperature, no off gasses, decreasing pressure, N2 make up required				
<b>Parameter: Level</b>		<b>Intention:</b>				
High (in T5002)	Blocked outlet, closure of FIC 5239	Increasing level in T5002  Potentially damage of trays	LIC 5161 high alarm  PDI 5167 high alarm  LI 5162, indicator			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 16 LP Methanol Column (T5002, P5005 A/B)	P&ID no.: P27, P34, P 36, P37, P40	Intention: Distillation of MeOH	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B	Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (D5002)	<p>Closure of FV 5203 and FV 5337</p> <p>Stop of reflux pump P5004 A/B</p>	<p>Liquid level will build up</p> <p>Pressure will increase</p> <p>Liquid carry over to atmosphere, release of liquid MeOH</p>	<p>LIC 5203 high alarm (on separator D5002)</p> <p>FIC 5203 low alarm (on reflux)</p> <p>PSAH 5207 IS 4 trip, trip of distillation section</p> <p>Autostart of standby reflux pump</p> <p>Separator can contain loss of reflux for 8 minutes (based on empty drum)</p> <p>LI 5204 indicator</p>	<p>66. Consider adding high alarm on LI 5204 (previously added, see action 65)</p> <p>67. Check set pressure of PSAH 5207 to prevent release of liquid from PV 5207 B (static head)</p>	<p>HTAS</p> <p>HTAS</p>	*
High (reboiler)	Not possible					
Low (in T5002)	Failure of valve FV 5239 (opens)	Pump cavitation, P5005 A/B	<p>LIC 5161 low alarm</p> <p>LALL 5162, I57 (stop of pump, P5005 A/B)</p>			*


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 16 LP Methanol Column (T5002, P5005 A/B)	P&ID no.: P27, P34, P 36, P37, P40	Intention: Distillation of MeOH	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 3.5 barg, 160 C out of top T5002 5.0 barg, 160 C out of bottom T5002 15.0 barg, 160 C after pumps, P5005 A/B	Operating P/T: 2.5 barg, 88 C inlet 0.1 barg, 67 C out of top T5002 0.7 barg, 86 C out of bottom T5002 6.5 barg, 86 C after pumps, P5005 A/B	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (D5002)	Failure of reflux valve, FIC 5203 and FIC 5337 (open)	Pump cavitation, P5004 A/B	LIC 5203 low alarm  LALL 5204, I58 (stop of pump, P5004 A/B)			*
Low (reboilers)	Not possible					


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (inlet to T5003)	Failure of FIC 5239 (open)	Level build up in T5003, damage to column trays, operational disturbances in distillation sections	<p>LIC 5270 high alarm PDI 5259 high alarm TIC 5266, 5267, 5268 low alarms LI 5271, indicator</p>	68. Consider adding high alarm on LI 5271	HTAS	
High (reflux)	<p>Failure of FIC 5321 (open)</p> <p>Failure of FV 5336 (closed)</p>	<p>Low level in overhead separator, pump cavitation P5006 A/B (see low level)</p> <p>Disturbances in separation</p>				




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (vapour outlet to flare)	Open vent (HIC xx)	No consequences				
High (bottom product to wash water)	Failure of FV 5020 (open)	No consequences				
High (bottom product to saturator)	Failure of FV 5367 (open)	Loss of level in column T5003, consequently pump P5010 cavitation	LIC 5270 low alarm LALL 5271, I59 trip of pumps			*
High (liquid off stream)	Failure of FIC 5441 (open)	Better removal of impurities (higher alcohols)  Loss of MeOH		69. Consider deviation alarm on FIC 5441	HTAS	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (final product to polisher)	Failure of FV 5336 (open)	Reduced reflux  Water in MeOH product	FIC 5336 high flow alarm  FIC 5321 low alarm (on reflux)  TI 5280 high alarm (overhead vapour temperature)			
High (final product to polisher)	Failure of LIC 5321 (reflux flow and product flow valves fully open)	Low level in D5003  Cavitation of P5006	LIC 5321 low alarm  LALL 5322, I60 trip of pump P5006			*
Low (inlet to T5003)	Failure of FV 5239 (closed)	Low level in bottom of T5003 (see low level)  Increased off-spec MeOH (more water)  Increasing temperature in overhead vapour	High alarm on all TIs in T5003  Reduced steam input by operator and operating in 100% reflux mode  Trip of pumps P5007, P5010 by I59 (see low level)			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (reflux)	<p>Closure of FV 5321 (with or without simultaneous closure of FV 5336)</p> <p>Stop of reflux pump P5006 A/B</p>	<p>Liquid level will build up in overhead separator D5003</p> <p>Increased product flow</p> <p>Off-spec MeOH</p> <p>Flooding condenser</p> <p>Pressure increases, potentially exceeding design pressure</p>	<p>FIC 5321 low alarm (on reflux)</p> <p>High alarm on all TIs in T5003</p> <p>LIC 5321 high alarm</p> <p>PI 5260 high alarm (bottom of column)</p> <p>PSVs 5250, 5251</p> <p>Autostart of spare pump P5006 A/B</p>			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (product)	<p>Failure of FV 5336 (closed)</p> <p>Pump failure, P5006 A/B</p>	<p>Increased reflux flow, more MeOH in T5003 bottom water</p> <p>Increasing pressure</p> <p>Decreasing temperature</p> <p>Build up level in column</p> <p>Flooding of column</p>	<p>PI 5260 high alarm (bottom of column)</p> <p>PSVs 5250, 5251</p> <p>Autostart of spare pump P5006 A/B</p> <p>Reduced feed flow, TIC 5266, 5267, 5268</p> <p>PDI 5253, 5255, 5257, 5259 high alarm</p>			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<p>Low (column bottom to wash water)</p>	<p>Failure of valve FV 5020 (closed)</p> <p>Pump failure, P5007 A/B</p>	<p>Increased flow to saturator</p> <p>Loss of water washing in raw MeOH tank</p> <p>Dry running of reboiler E5003, potentially exceeding design temperature of shell side</p>		<p>70. Check design temperature of re- boiler E5003 (dry running)</p>	<p>HTAS</p>	
<p>Low (column bottom to satu- rator)</p>	<p>Failure of FV 5367 (closed)</p> <p>Pump failure, P5010 A/B</p>	<p>Level build up in column</p> <p>Potentially damage of trays</p> <p>Less evaporation in saturator</p>	<p>LIC 5270 high alarm</p> <p>PDI 5259 high alarm</p> <p>LI 5271, indicator</p> <p>Autostart of spare pump, P5010</p>	<p>71. Consider adding high alarm on LI 5271 (previously added, see action no. 68)</p>	<p>HTAS</p>	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
No flow from pumps (P5007, P5010 A/B, P5006)	Blocked outlet	Cavitation, potential damage of pumps	<p>Minimum flow valve protects pumps (P5010 A/B, P5006)</p> <p>Low head of P5007 and open recycle line</p>			
Low (reboiler)	Low level in column	Exceeding design temperature of reboiler (see low flow of column bottom to wash water)				
Low (liquid off stream)	Failure of FV 5441 (closed)	Higher alcohols in MeOH product		72. Consider deviation alarm on FIC 5441 (previously added, see action no. 69)	HTAS	


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse ( process condensate from saturator into T5003 )	Pump failure, P5010	Increasing level in column, potentially damage of trays  Potentially increasing pressure	2 check valves series  LIC 5270 high alarm  LI 5271, indicator  PSVs 5250, 5251			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (overhead system)	Failure of overhead condenser E5002 1/2/3/4 (loss of cooling)	Low/no reflux flow  High pressure	PI 5260 high alarm  High temperature alarms on all TIs in T5003  PSVs 5250, 5251			
High (to polisher)	Loss of cooling in E5012	Increased evaporation from storage	TI 5381 high alarm (on combined product run down)			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (tube in-side reboiler)	No liquid to reboiler	See low flow				
Low	Low steam flow to re-boiler	Potentially reduced reboiler duty  Reduced capacity of column				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	<p>Loss of condenser cooling in E5002</p> <p>Loss of reflux flow (determines the size of PSVs)</p> <p>Tube rupture in E2023</p> <p>See above deviations</p> <p>External fire</p>	<p>Increasing pressure, potentially exceeding design pressure</p>	<p>PI 5260 high alarm</p> <p>High temperature alarms on all TIs in T5003</p> <p>PSVs 5250, 5251</p>			




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Pure water in column and cooling down of column	Slight vacuum	Tower is designed for full vacuum			
<b>Parameter: Composition</b>		<b>Intention:</b>				
Pure MeOH	Recycle of off-spec MeOH	Higher pressures	PI 5260 high alarm (bottom of column) PSVs 5250, 5251			
Low pH value in column due to byproducts	Insufficient injection of morpholine into upstream raw MeOH tank TK5001	Potentially corrosion Off-spec product (amines)	Manual analysis of acidity of raw MeOH and distillation water out of bottom of column T5003 according to operating manual			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)	P&ID no.: P34, P35, P38, P39, P40, P41	Intention: Water and higher alcohols are removed from methanol	Date: 18.06.2010
	Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012	Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
High (in T5003)	Blocked outlet, closure of FV 5367  Failure of pump, P5010	Increasing level in T5003  Potentially damage of trays	LIC 5270 high alarm  PDI 5259 high alarm  LI 5271, indicator  Autostart of spare pump, P5010			
High (D5003)	Failure of LIC 5321  Failure of pump P5006	Liquid level will build up in overhead separator D5003  Flooding condenser  Pressure increases, potentially exceeding design pressure	High alarm on all TIs in T5003  LIC 5321 high alarm  PI 5260 high alarm (bottom of column)  PSVs 5250, 5251  Autostart of spare pump P5006 A/B			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 17 MP methanol column (T5003, E5002, D5003, P5006, E5012)</p>	<p>P&amp;ID no.: P34, P35, P38, P39, P40, P41</p>	<p>Intention: Water and higher alcohols are removed from methanol</p>	<p>Date: 18.06.2010</p>
	<p>Design P/T: 8.0 barg, 160 C inlet 6.0 barg, 165 C out of top T5003 7.5 barg, 175 C out of bottom T5003 6.0 barg, 165 inlet to D5003 18.0 barg, 165 C after pumps, P5006 A/B 18.0 barg, 75 C after E5012</p>	<p>Operating P/T: 3.5 barg, 86 C inlet 2.7 barg, 102 C out of top T5003 3.6 barg, 149 C out of bottom T5003 2.6 barg, 101 inlet to D5003 6.0 barg, 101 C after pumps, P5006 A/B 3.0 barg, 48 C after E5012</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (in re-boiler E5003)	Not possible (controlled by weir)					
Low (in T5003)	Failure of valve FV 5367 (opens)	Loss of level in column T5003, consequently pump P5010 cavitation	LIC 5270 low alarm LALL 5271, I59 trip of pumps			*
Low (D5003)	Failure of reflux valve LIC 5321	Low level in D5003 Cavitation of P5006	LIC 5321 low alarm LALL 5322, I60 trip of pump P5006			*
Low (reboiler)	Stop of recycle pump P5007 A/B	Dry running of reboiler E5003, potentially exceeding design temperature of shell side (see low flow of wash water)				
<b>Parameter: Other</b>		<b>Intention:</b>				
Uncondensables		Increasing pressure	Manual venting from D5003 (HIC xx)			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 18 Product polisher (X5002 A/B)	P&ID no.: P42	Intention: Removal of impurities (amines)	Date: 22.06.2010
	Design P/T: 18.0 barg, 75 C	Operating P/T: 3.0 barg, 48 C	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High	Failure of FV 5336 (open)	No consequences				
Low	Failure of FV 5336 (closed)	No consequences				
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Failure of upstream cooling E5012 or E5008	Exceeding design temperature Evaporation of MeOH	TI 5381 high alarm (inlet) Higher mass flow of low temperature MeOH from E5008 than potential high temperature flow (loss of cooling) from E5012. Prevents exceeding design temperature			
Low		No consequences				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 18 Product polisher (X5002 A/B)	P&ID no.: P42 Design P/T: 18.0 barg, 75 C	Intention: Removal of impurities (amines) Operating P/T: 3.0 barg, 48 C	Date: 22.06.2010


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Blocked outlet  External fire	Operating at maximum pump shut off pressure which is less than 18 barg  Pressure build up in demin water line (leaking manual block valve)	Design pressure is 18 barg (product line)  PSVs 5384, 5386	73. Install blinds at individual inlet to polishers.  74. Consider installing common PI and PG on inlet to polishers	HTAS  HTAS	
High pressure drop across strainer	Absorber dust	Blocked strainer  Higher upstream pressure (see above)	PDI 5385 high alarm			
Low		No consequences				
<b>Parameter: Composition</b>		<b>Intention:</b>				
Higher concentration of impurities	Loss of morpholine injection	Reduction of life time (see raw MeOH tank node 14)				

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 18 Product polisher (X5002 A/B)	P&ID no.: P42	Intention: Removal of impurities (amines)	Date: 22.06.2010
	Design P/T: 18.0 barg, 75 C	Operating P/T: 3.0 barg, 48 C	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
No level in pol- isher						


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 19 Product buffer tank and product pump (TK5002, P5008A/B)	P&ID no.: P43, P44	Intention: Storage of methanol and pumping to product tank (BL)	Date: 22.06.2010
	Design P/T: 18.0 barg, 75 C inlet 3.5 barg, 75 C TK5002 4.5 barg, 75 C after TK5002 17.0 barg, 75 C after P5008	Operating P/T: 3.0 barg, 48 C 0.0 barg, 40 C TK5002 0.0 barg, 48 C after TK5002 5.0 barg, 48 C after P5008	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High	More MeOH from T5002/3, separators, fail- ure of level control	High level (see high level)				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 19 Product buffer tank and product pump (TK5002, P5008A/B)	P&ID no.: P43, P44	Intention: Storage of methanol and pumping to product tank (BL)	Date: 22.06.2010
	Design P/T: 18.0 barg, 75 C inlet 3.5 barg, 75 C TK5002 4.5 barg, 75 C after TK5002 17.0 barg, 75 C after P5008	Operating P/T: 3.0 barg, 48 C 0.0 barg, 40 C TK5002 0.0 barg, 48 C after TK5002 5.0 barg, 48 C after P5008	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (to product tank at BL)	Blocked outlet	Pump cavitation	Minimum flow valve returning to tank	<p>75. Consider installing a three way control valve on the return line to ensure direct connection to at least one tank</p> <p>76. Consider installing common PI with high alarm on discharge line of pump P5008</p> <p>77. Consider thermal expansion valve on run down line (note on PID)</p>	HTAS  HTAS  HTAS	
Reverse	Back flow of MeOH from run down line when pump P5008 is out of operation	Back flow of MeOH to buffer tank	Check valves on pump discharge			




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 19 Product buffer tank and product pump (TK5002, P5008A/B)	P&ID no.: P43, P44	Intention: Storage of methanol and pumping to product tank (BL)	Date: 22.06.2010
	Design P/T: 18.0 barg, 75 C inlet 3.5 barg, 75 C TK5002 4.5 barg, 75 C after TK5002 17.0 barg, 75 C after P5008	Operating P/T: 3.0 barg, 48 C 0.0 barg, 40 C TK5002 0.0 barg, 48 C after TK5002 5.0 barg, 48 C after P5008	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	High inlet temperature from D5003 by failure of water cooler E5012	Increased evaporation from tank TK 5002 1/2.  Slip of MeOH vapour	Washing of vapour from T 5002  TI 5381 high alarm (inlet of polisher)  Vapour is used as combustion air in the reformer (not during reformer shut down)			
Low	Not possible					
<b>Parameter: Pressure</b>		<b>Intention: Atmospheric conditions</b>				
High	Blocked outlet from T5002 by failure of vent valve UV 5021 (FO)  Failure of valve UV 2125 (FC)  External fire  PCV 5412 or 5395 (opens N2 blanketing)	Exceeding design pressure	PI 5398, 5415 high alarm  PSV 5419 ( breather valve, common for both tanks, opens to the wash column)  PSV 5400, 5417 (relief valves)			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 19 Product buffer tank and product pump (TK5002, P5008A/B)	P&ID no.: P43, P44	Intention: Storage of methanol and pumping to product tank (BL)	Date: 22.06.2010
	Design P/T: 18.0 barg, 75 C inlet 3.5 barg, 75 C TK5002 4.5 barg, 75 C after TK5002 17.0 barg, 75 C after P5008	Operating P/T: 3.0 barg, 48 C 0.0 barg, 40 C TK5002 0.0 barg, 48 C after TK5002 5.0 barg, 48 C after P5008	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Emptying tank TK 5002  Failure of PCV 5412 or PCV 5395	Vacuum during emptying tank TK5002  Air ingress, flammable atmos- phere	PI 5398, 5415 low alarm  PCV 5412 or 5395 which will open at low pressure, N2 make up  PSV 5401, 5418 (breather)  Tank internal/external is classified	78 Consider separate breather valves on tank TK5002 1/2	HTAS	
<b>Parameter: Composition</b>		<b>Intention:</b>				
Off-spec MeOH	Mistake	Requirement of recycle of off- spec MeOH to TK5001				
<b>Parameter: Level</b>		<b>Intention:</b>				
High	Liquid not pumped from tank TK 5002  Pump failure, P5008	Static head build up (high static pressure at the PSVs)  Tank rupture	LI 5396, 5413 high alarm  LAHH 5397, 5414, I62, I63 block inlet to tank and put the other tank in service	79. Check PSV 5400, 5417 layout to avoid static pressure build up	HTAS	*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 19 Product buffer tank and product pump (TK5002, P5008A/B)	P&ID no.: P43, P44	Intention: Storage of methanol and pumping to product tank (BL)	Date: 22.06.2010
	Design P/T: 18.0 barg, 75 C inlet 3.5 barg, 75 C TK5002 4.5 barg, 75 C after TK5002 17.0 barg, 75 C after P5008	Operating P/T: 3.0 barg, 48 C 0.0 barg, 40 C TK5002 0.0 barg, 48 C after TK5002 5.0 barg, 48 C after P5008	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Shut down of upstream section (distillation)	Pump cavitation P5008 A/B	LI 5396, 5413 low alarm  LALL 5397, 5414, trip I64, I65 (shut down of pumps)			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 20 Liquid off stream (E 5011, TK 5003, P 5009 A/B)	P&ID no.: P01, P07, P32, P45	Intention: Storage of higher alcohol	Date: 23.06.2010
	Design P/T: 7.5 barg, 175 C inlet E5011 7.5 barg, 75 C inlet TK5003 4.5 barg, 75 C outlet TK5003 60.0 barg, 75 C outlet P5009	Operating P/T: 2.6 barg, 115 C inlet E5011 2.0 barg, 48 C inlet TK5003 0.0 barg, 48 C outlet TK5003 50.0 barg, 50 C outlet P5009	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (from T5003)		No consequences				
High (from P5003)		No consequences				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 20 Liquid off stream (E 5011, TK 5003, P 5009 A/B)	P&ID no.: P01, P07, P32, P45	Intention: Storage of higher alcohol	Date: 23.06.2010
	Design P/T: 7.5 barg, 175 C inlet E5011 7.5 barg, 75 C inlet TK5003 4.5 barg, 75 C outlet TK5003 60.0 barg, 75 C outlet P5009	Operating P/T: 2.6 barg, 115 C inlet E5011 2.0 barg, 48 C inlet TK5003 0.0 barg, 48 C outlet TK5003 50.0 barg, 50 C outlet P5009	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (D1001)	Manual valve left open	Gas break through  Exceeding design pressure of tank TK5003, tank rupture	PI 5448 high alarm  PSV 5450	80. PSV 5450 to be designed for gas break through from D1001  81. Consider changing manual drain valve from KO D1001 from 2" to 1"  82. Consider installing separate shut off valve at low level in D1001	HTAS  HTAS  HTAS	
High (from P5009)	Fail open of FV 6057	Decreasing level in tank, potentially cavitation of pump P5009	LI 5446 low alarm  LALL 5447 low alarm, I52( trip of pump P5009)			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 20 Liquid off stream (E 5011, TK 5003, P 5009 A/B)	P&ID no.: P01, P07, P32, P45	Intention: Storage of higher alcohol	Date: 23.06.2010
	Design P/T: 7.5 barg, 175 C inlet E5011 7.5 barg, 75 C inlet TK5003 4.5 barg, 75 C outlet TK5003 60.0 barg, 75 C outlet P5009	Operating P/T: 2.6 barg, 115 C inlet E5011 2.0 barg, 48 C inlet TK5003 0.0 barg, 48 C outlet TK5003 50.0 barg, 50 C outlet P5009	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (from T5003)	Fail close of FV 5441	No consequence for the tank				
Low (from P5003)	Fail close of FV 5107	No consequence for the tank				
Low (from P5009)	Fail close of FV 6057	Pumping against blocked outlet High level in tank TK5003 (see high level)	Minimum flow protection			
Reverse (from saturator into tank)	Pump failure, P5009	Exceeding design pressure Tank rupture	One check valve and reciprocating pump PSV 5450 PI 5448 high alarm	83. PID to be updated to actual pump type (reciprocating pump)	HTAS	


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 20 Liquid off stream (E 5011, TK 5003, P 5009 A/B)	P&ID no.: P01, P07, P32, P45	Intention: Storage of higher alcohol	Date: 23.06.2010
	Design P/T: 7.5 barg, 175 C inlet E5011 7.5 barg, 75 C inlet TK5003 4.5 barg, 75 C outlet TK5003 60.0 barg, 75 C outlet P5009	Operating P/T: 2.6 barg, 115 C inlet E5011 2.0 barg, 48 C inlet TK5003 0.0 barg, 48 C outlet TK5003 50.0 barg, 50 C outlet P5009	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (to tank)	Failure of cooling water	Increasing evaporation Exceeding boiling point Increasing pressure in tank TK5003	PI 5448 high alarm  PSV 5450	84. Consider adding high alarm on TI 5443	HTAS	
Low		No consequences				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 20 Liquid off stream (E 5011, TK 5003, P 5009 A/B)	P&ID no.: P01, P07, P32, P45	Intention: Storage of higher alcohol	Date: 23.06.2010
	Design P/T: 7.5 barg, 175 C inlet E5011 7.5 barg, 75 C inlet TK5003 4.5 barg, 75 C outlet TK5003 60.0 barg, 75 C outlet P5009	Operating P/T: 2.6 barg, 115 C inlet E5011 2.0 barg, 48 C inlet TK5003 0.0 barg, 48 C outlet TK5003 50.0 barg, 50 C outlet P5009	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (in tank)	Loss of cooling water(see flow)  Gas break through from D1001(see flow)  Back pressure from saturator (see flow)  External fire  Fail close of breather valve  Fail open of PCV 5445 (N2 blanketing)	Increasing pressure in tank TK5003, potentially tank rupture	PI 5448 high alarm  PSV 5450			
Low (in tank)	Fail close of PCV 5445 (N2 blanketing)	Vacuum in tank TK5003	Vacuum breaker PSV 5451  PI 5448 low alarm			




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 20 Liquid off stream (E 5011, TK 5003, P 5009 A/B)	P&ID no.: P01, P07, P32, P45	Intention: Storage of higher alcohol	Date: 23.06.2010
	Design P/T: 7.5 barg, 175 C inlet E5011 7.5 barg, 75 C inlet TK5003 4.5 barg, 75 C outlet TK5003 60.0 barg, 75 C outlet P5009	Operating P/T: 2.6 barg, 115 C inlet E5011 2.0 barg, 48 C inlet TK5003 0.0 barg, 48 C outlet TK5003 50.0 barg, 50 C outlet P5009	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
High (in tank)	Pump failure, P5009 Operator mistake	Static head build up (high static pressure at the PSVs)  Tank rupture	LI 5446 high alarm  LAHH 5447, I51 trip (blockages of all inlets)	85. Check PSV 5450 layout to avoid static pressure build up	HTAS	*
Low (in tank)	Fail open of FV 6057	Decreasing level in tank, potential cavitation of pump P5009	LI 5446 low alarm  LALL 5447 low alarm, I52( trip of pump P5009)			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 21 Bottom product to wash column T5004 (AE 5006, E5007, T5004)	P&ID no.: P29, P41	Intention:	Date: 23.06.2010
	Design P/T: 7.5, 175 C inlet 10.0 barg, 175 C outlet P5007 7.5 barg, 120 C outlet AE5006 7.5 barg, 100 C outlet E5007	Operating P/T: 3.8, 149 C inlet 4.5 barg, 149 C outlet P5007 4.3 barg, 65 C outlet AE5006 4.0 barg, 48 C outlet E5007	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (wash water)	Fail open of control valve FV 5020	Reduced strength of raw MeOH  Level build up in wash water T5004(not possible, drain pipe sufficient for full flow)				
Low	Fail close of FV 5020	Loss of washing  Increased MeOH loss  Slight increase in MeOH concentration in T5001	FIC 5020 low alarm			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (wash water to T5004)	Failure of cooling water	Slightly reduced washing capacity, consequently more loss of MeOH				
Low		No consequences				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
<p>Node: 21 Bottom product to wash column T5004 (AE 5006, E5007, T5004)</p>	<p>P&amp;ID no.: P29, P41</p>	<p>Intention:</p>	<p>Date: 23.06.2010</p>
	<p>Design P/T: 7.5, 175 C inlet 10.0 barg, 175 C outlet P5007 7.5 barg, 120 C outlet AE5006 7.5 barg, 100 C outlet E5007</p>	<p>Operating P/T: 3.8, 149 C inlet 4.5 barg, 149 C outlet P5007 4.3 barg, 65 C outlet AE5006 4.0 barg, 48 C outlet E5007</p>	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High		See node 14				
Low		No consequences				

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 22 Fuel gas to primary reformer	P&ID no.: U01, P01, P15, P27	Intention:	Date: 23.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High/low		See node 5				
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High/low		No consequences				
<b>Parameter: Level</b>		<b>Intention:</b>				
High		See node 1 and 12				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (after de-pressurization of NG)	Fail open of pressure control valve PIC 1011	Exceeding design pressure	PSV 1013			
High (after de-pressurization of purge gas)	Fail open of pressure control valve	Exceeding design pressure	PSV 3173 PIC 2536 B (vent)			
High (during N2 purge)	Supply pressure of N2 is high	Exceeding design pressure of mixer	PSV 2546			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 23 Flue gas system	P&ID no.: P12, P13, P15	Intention: Preheating of NG feed and combustion air	Date: 23.06.2010
	Design P/T:	Operating P/T: 1090 C outlet H2001, 790 C outlet E2001, 436 C outlet E2002, 348 C outlet E2004, 234 C outlet E2006, 150 C outlet E2007	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High flue gas flow at unaffected temperature	Higher combustion air flow due to combustion/air control is leading to over firing of the reformer H2001	More heat available for the coils Increased flue stack temperature	Outlet temperature from reformer will increase and give alarm TI 2303, 2304, 2305 (on common outlet)  TSAH 2305, IS1 trip of reformer  TI 2295 2297 high alarm  Sufficient margin on coil design temperatures			*
High process flow in flue gas coils		No consequences				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 23 Flue gas system	P&ID no.: P12, P13, P15	Intention: Preheating of NG feed and combustion air	Date: 23.06.2010
	Design P/T:	Operating P/T: 1090 C outlet H2001, 790 C outlet E2001, 436 C outlet E2002, 348 C outlet E2004, 234 C outlet E2006, 150 C outlet E2007	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (flue gas)	<p>Maloperation of PIC 2224</p> <p>Trip of flue gas fan</p>	<p>Increasing pressure in flue gas duct</p> <p>Potential harm to operators affected by hot flue gasses</p> <p>Heat accumulation causing damage to reformer</p>	<p>PIC 2224 high alarm</p> <p>PAHH 2224, I15 trip (opens dampers)</p> <p>PSAH 2224, IS1 trip of reformer section</p> <p>Motor driver with autostart</p> <p>IS12 trip of flue gas fan will cause IS 1</p>			<p>*</p> <p>*</p>


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 23 Flue gas system	P&ID no.: P12, P13, P15	Intention: Preheating of NG feed and combustion air	Date: 23.06.2010
	Design P/T:	Operating P/T: 1090 C outlet H2001, 790 C outlet E2001, 436 C outlet E2002, 348 C outlet E2004, 234 C outlet E2006, 150 C outlet E2007	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low process flow in flue gas coils	Partly loss of process stream	Increased temperature in H2001 and increased temperature profile in flue gas duct. Potentially exceeding design temperature	<p>Outlet temperature from reformer will increase and give alarm TI 2303, 2304, 2305 (on common outlet)</p> <p>TSAH 2305, IS1 trip of reformer</p> <p>TI 2295 2297 high alarm (flue gas)</p> <p>TSAH 2221, IS1 trip of reformer (flue gas)</p> <p>Sufficient margin on coil design temperatures (see process specification for design temperature)</p>	86. Ensure design temperature of the coils take reduced process gas flow into account	HTAS	*  *
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (flue gas from H2001)	Over firing	Exceeding design temperatures	<p>TI 2295 2297 high alarm (flue gas)</p> <p>TSAH 2221, IS1 trip of reformer (flue gas)</p>			*
Low (flue gas from H2001)	Under firing	Operational disturbances	TI 2155 low alarm (stack temperature)			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 23 Flue gas system	P&ID no.: P12, P13, P15	Intention: Preheating of NG feed and combustion air	Date: 23.06.2010
	Design P/T:	Operating P/T: 1090 C outlet H2001, 790 C outlet E2001, 436 C outlet E2002, 348 C outlet E2004, 234 C outlet E2006, 150 C outlet E2007	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (flue gas)	<p>Failure of PIC 2224</p> <p>Trip of flue gas fan</p>	<p>Increasing pressure in flue gas duct</p> <p>Potential harm to operators affected by hot flue gasses</p> <p>Heat accumulation causing damage to reformer</p>	<p>PIC 2224 high alarm</p> <p>PAHH 2224, I15 trip (opens dampers)</p> <p>PSAH 2224, IS1 trip of reformer section</p> <p>Motor driver with autostart</p> <p>IS12 trip of flue gas fan will cause IS 1</p>			<p>*</p> <p>*</p>




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 23 Flue gas system	P&ID no.: P12, P13, P15	Intention: Preheating of NG feed and combustion air	Date: 23.06.2010
	Design P/T:	Operating P/T: 1090 C outlet H2001, 790 C outlet E2001, 436 C outlet E2002, 348 C outlet E2004, 234 C outlet E2006, 150 C outlet E2007	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (flue gas)	Failure of PIC 2224  Failure of combustion air FIC 2111	Increased vacuum in flue gas section  Potentially damage of insulation/casing	PIC 2224 low alarm (outlet of H2001)  PSAL 2224 low alarm (outlet of H2001), IS 1 trip of reformer  AI 2223 2, high alarm (combustibles)  AI 2223 1, low alarm (O <sub>2</sub> )  AI 2224, low alarm (O <sub>2</sub> )	87. Consider opening of false air damper at low pressure  88. Assure correct installation of atmospheric leg at pressure instruments according to HTAS hook up drawing J24	HTAS  MEKPCO	*

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 23 Flue gas system	P&ID no.: P12, P13, P15	Intention: Preheating of NG feed and combustion air	Date: 23.06.2010
	Design P/T:	Operating P/T: 1090 C outlet H2001, 790 C outlet E2001, 436 C outlet E2002, 348 C outlet E2004, 234 C outlet E2006, 150 C outlet E2007	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Leakages from coils	Coil rupture	Increasing pressure  Combustibles into flue gas  Increased temperature in the upper part of the flue gas duct	Proper material selection in design of coils  Fully welded coils inside flue gas duct  Coil rupture is unlikely to happen due to coil dimensions (wall thickness)			
Condensation of flue gas	Low temperature	Potential corrosion in combustion air preheater E2007	TI 2155 low alarm  Bypass of combustion air preheater can control stack temperature			
<b>Parameter: Other</b>		<b>Intention:</b>				
Operating at no combustion air surplus	Maloperation of combustion air control	Post combustion when air is leaking into flue gas system, increasing temperature	Design has taken into account minimisation of air leaks  AI 2223 2, high alarm (combustibles)  AI 2223 1, low alarm (O <sub>2</sub> )  AI 2224, low alarm (O <sub>2</sub> )			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 24 Oxygen system	P&ID no.: P02, P03	Intention:	Date: 24.06.2010
	Design P/T: 47.0 barg, 85 C inlet 47.0 barg, 255 C after E2008	Operating P/T: 40.0 barg, 35 C inlet 34.0 barg, 230 C after E2008	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (O <sub>2</sub> )	Malfunction of flow control FIC 2007	Increased O/C ratio  Increased reformer temp in R2004. Potential damage of cat, reformer and downstream equipment.	FFI 2020, high O/C ratio alarm  FFSAH 2008, high O/C ratio, trip of secondary reformer (IS 2)  TI 2333 high temperature alarm  TSAH 2333 (outlet)  TI 2325 (temperature in combustion zone)  TSAH 2325 (temperature in combustion zone)			*  *  *
Low (O <sub>2</sub> )	Malfunction of flow control FIC 2007  Upstream blockage, failure of O <sub>2</sub> supply (e.g. O <sub>2</sub> filter)	Low O/C ratio  Reduced outlet temperature from R2004, no consequences  Increased CH <sub>4</sub> slip	AI 2479 (CH <sub>4</sub> analyser)	89. Add high alarm on AI 2479 (previously added see action 28)	HTAS	


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 24 Oxygen system	P&ID no.: P02, P03	Intention:	Date: 24.06.2010
	Design P/T: 47.0 barg, 85 C inlet 47.0 barg, 255 C after E2008	Operating P/T: 40.0 barg, 35 C inlet 34.0 barg, 230 C after E2008	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (steam)	Fail open of flow control FV 2040	No consequences				
Low (steam)	Fail close of flow control FV 2040	Low steam/O <sub>2</sub> ratio  Potential overheating of burner  Risk of auto ignition of stainless steel piping downstream mixing point	FIC 2040 low alarm  FSAL 2040, IS 2 trip of secondary reformer  Filters on O <sub>2</sub> and HP steam flows			*
Reverse ( HC in O <sub>2</sub> /steam)	Simultaneous failure of O <sub>2</sub> and steam supply	Explosion in O <sub>2</sub> -piping	Check valves  FIC 2040 low alarm on steam flow  FSAL 2040, trip, IS 2 steam flow			*


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 24 Oxygen system	P&ID no.: P02, P03	Intention:	Date: 24.06.2010
	Design P/T: 47.0 barg, 85 C inlet 47.0 barg, 255 C after E2008	Operating P/T: 40.0 barg, 35 C inlet 34.0 barg, 230 C after E2008	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse (O <sub>2</sub> into Steam)	No steam pressure	O <sub>2</sub> into steam system  Corrosion  Risk of auto ignition of piping in steam system	Check valve  FIC 2040 low alarm on steam flow  FSAL 2040, trip, IS 2 steam flow  PDI 2036 low alarm (across steam valve)  PDSAL 2036, IS 21, blocks steam line			*       *




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 24 Oxygen system	P&ID no.: P02, P03	Intention:	Date: 24.06.2010
	Design P/T: 47.0 barg, 85 C inlet 47.0 barg, 255 C after E2008	Operating P/T: 40.0 barg, 35 C inlet 34.0 barg, 230 C after E2008	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (O <sub>2</sub> )	Fail open of pressure control, PIC 2015 (HP steam)	Increased O <sub>2</sub> temperature Increased temperature of the combined stream	Temperature is limited to temperature level of the steam			
Low (O <sub>2</sub> )	Loss of steam to O <sub>2</sub> pre-heater, malfunction of PIC 2015	Condensate into burner. Potential damage of burner and refractory	TI 2047 low alarm on O <sub>2</sub> temp TSAL 2047, trip IS 2 on low O <sub>2</sub> temp			*
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (O <sub>2</sub> supply)	High delivery pressure from BL	High O <sub>2</sub> flow (see high flow)				
High (O <sub>2</sub> )	External fire Tube rupture in E2008	Exceeding design pressure Condensate in O <sub>2</sub> , potentially damage of burner	PSV 2014 TI 2047 low alarm	91. Consider if PSV 2014 is necessary	HTAS	
Low (O <sub>2</sub> supply)	Low delivery pressure from BL Failure of O <sub>2</sub> feed control	Low O <sub>2</sub> flow (see low flow)				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 24 Oxygen system	P&ID no.: P02, P03	Intention:	Date: 24.06.2010
	Design P/T: 47.0 barg, 85 C inlet 47.0 barg, 255 C after E2008	Operating P/T: 40.0 barg, 35 C inlet 34.0 barg, 230 C after E2008	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Impurities in O <sub>2</sub> from supplier				92. Consider if local analysis point on incoming O <sub>2</sub> line is possible from safety point of view	HTAS	
<b>Parameter: Other</b>		<b>Intention:</b>				
Liquid in O <sub>2</sub>	<p>Pockets of condensate in piping during start up</p> <p>Insufficient heating of steam and O<sub>2</sub></p>	<p>Damage of equipment</p> <p>Damage of refractory lining</p> <p>Damage of catalyst</p>	<p>Preheating of steam and O<sub>2</sub> according to manual</p> <p>TI 2047 Low temperature alarm</p> <p>TSAL 2047 trip</p> <p>Double block and bleed valve to prevent steam in O<sub>2</sub>. The bleed is from the bottom of the pipe</p> <p>No pockets (slope)</p> <p>Heat tracing to 250 C</p>	93. MEKPCO should supervise detailed design of piping layout according to HTAS requirements as indicated on the PIDs (is added, see action no. 37).	MEKPCO	*




	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 24 Oxygen system	P&ID no.: P02, P03	Intention:	Date: 24.06.2010
	Design P/T: 47.0 barg, 85 C inlet 47.0 barg, 255 C after E2008	Operating P/T: 40.0 barg, 35 C inlet 34.0 barg, 230 C after E2008	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Operating manual valves (non monel) with differential pressure	Maloperation	Risk of auto ignition due to high O <sub>2</sub> velocity		<p>94. Ensure correct opening sequence of valve in detailed operating manual</p> <p>95. Alternatively change system to monel</p>	<p>MEKPCO</p> <p>HTAS</p>	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 25 Demin water system	P&ID no.: U18, P20	Intention:	Date: 24.06.2010
	Design P/T: 4.5 barg, 65 C out of TK7001 7.0 barg, 65 C after P7002 7.0 barg, 130 C after E2025	Operating P/T: 0.0 barg, 35 C out of TK7001 5.0 barg, 35 C after P7002 4.5 barg, 72 C after E2025	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (inlet to TK7001)	Fully open butterfly valve	Overfilling of tank (see high level)				
High (from TK7001)	Failure of FV 7091	No consequences in this node (see node 26)				
Low (from pump P7002)	Blocked outlet	Pump damage if running for long time with no flow	Loss of demin water in the deaerator will be detected before pump damage  FIC 7091 low alarm			
Reverse (from deaerator)	Pump failure	Not likely	2 check valves (at inlet to deaerator and at pump discharge)  Open overflow line			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 25 Demin water system	P&ID no.: U18, P20	Intention:	Date: 24.06.2010
	Design P/T: 4.5 barg, 65 C out of TK7001 7.0 barg, 65 C after P7002 7.0 barg, 130 C after E2025	Operating P/T: 0.0 barg, 35 C out of TK7001 5.0 barg, 35 C after P7002 4.5 barg, 72 C after E2025	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Failure of TIC 2457 which is controlling the bypass of process gas	Increased temperature of demin water (see node 26)  Potentially increased pressure in the deaerator (see node 26)	TIC 2457 high alarm  Operating pressure is sufficient to avoid boiling			
Low (to deaerator)	Fail open of TIC 2457	Operational disturbances in deaerator, increased steam consumption in deaerator				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Tube rupture in E2025	Exceeding design pressure in E2025, piping and TK7001	Tank open overflow  Check valves at pump discharge  PSV 2458 (down stream E2025, designed for tube rupture)			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 25 Demin water system	P&ID no.: U18, P20	Intention:	Date: 24.06.2010
	Design P/T: 4.5 barg, 65 C out of TK7001 7.0 barg, 65 C after P7002 7.0 barg, 130 C after E2025	Operating P/T: 0.0 barg, 35 C out of TK7001 5.0 barg, 35 C after P7002 4.5 barg, 72 C after E2025	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Level</b>		<b>Intention:</b>				
High (tank)	Fully open butterfly valve	Increased level	LI 7001 and 7002 high alarm  Open overflow			
Low (tank)	Fully open butterfly valve	Pump cavitation	LI 7001 and 7002 low alarm			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 26 Deaerator	P&ID no.: U09, U13, U14	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (demin water)	Failure of control valve FV 7091 (open)	High level	LIC 7091 high alarm FIC 7091 high alarm			
High (steam)	Fail open of PV 7094	High pressure	PIC 7094 high alarm PIC 7101 venting from deaerator PSVs 7095, 7096			
High (condensates)	Fail open of valve in condensate line	High level High pressure due to flashing stream	LIC 7091 high alarm PIC 7094 high alarm PIC 7101 venting from deaerator PSVs 7095, 7096			
High (Amine)	Set point mistake Failure of analyser AIC 7099	Higher pH value, corrosion in waste heat boiler	AIC 7099 high alarm Overconsumption to be seen by operator Regular analysis of BW			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 26 Deaerator	P&ID no.: U09, U13, U14	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (O2 scavenger)	Set point mistake	Increased chemical consumption, no consequence				
High (BFW recycle)	Fail open of HV 2371 during normal operation	Increased generation of flash steam High pressure	PIC 7094 high alarm PIC 7101 venting from deaerator PSVs 7095, 7096			
Low (demin water)	Fail close of valve FV 7091	Loss of cooling Increasing pressure Low level in D7001 (see level)	PIC 7094 high alarm PIC 7101 venting from deaerator PSVs 7095, 7096 (probably design case) FIC 7091 low alarm (on demin water)			
Low (condensates)	Fail close of upstream valves	No consequences	LIC 7091 will compensate			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 26 Deaerator	P&ID no.: U09, U13, U14	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (amine)	Dosing pump failure  Blocked outlet	Corrosion in boiler  Exceeding dosing pump discharge pressure	AIC 7099 low alarm  Regular analysis of BW  PSVs 7195, 7198			
Low (O2 scavenger)	Dosing pump failure  Blocked outlet	Corrosion in boiler  Exceeding dosing pump discharge pressure	Regular analysis of BW  PSVs 7215, 7218			
Low (BFW to boiler)	Failure of level control for the boiler, FIC 2417	Increasing level in D7001	LIC 7091 high alarm  LIC will close demin water make up  Hold up volume in deaerator greater than hold up volume in boiler  PSVs 7095, 7096			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 26 Deaerator	P&ID no.: U09, U13, U14	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Back flow of BFW	Pump failure	Potentially vapour break through  High pressure	2 check valves  2 pumps running in parallel  Auto start of spare pump  Pumps are specified with anti reversing device  LSAL 2372, IS1 trip			*
Reverse flow of demin water to demin tank	Pump failure	See node 25				
Reverse flow to chemical injection		Not possible (check valves and reciprocating pumps)				
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High		See high pressure				
Low	No cause					




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 26 Deaerator	P&ID no.: U09, U13, U14	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High		See flow				
Low	Missing heat input from steam or condensate  Failure of demin water preheating due to fully open bypass on preheater TV 2457	Decreasing temperature, potentially below 100 C, air ingress from vent line resulting in reduced stripping efficiency  Corrosion in boiler system	PIC 7094 low alarm			
<b>Parameter: Level</b>		<b>Intention:</b>				
High (D7001)	Failure of level control LIC 7091	Increasing level  Level build up  High pressure  Release through open vent (two phase)	LIC 7091 high alarm (2 out of 3)  PIC 7094 high alarm  PIC 7101 venting from deaerator  PSVs 7095, 7096			
Low (D7001)	Failure of level control LIC 7091	Pump cavitation of P7001	LIC 7091 low alarm  LSAL 7091, IS70 trip, stop of BFW pumps			*

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 27 BFW pumps and distribution	P&ID no.: U10, U11	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (HHP BFW)	Failure of FIC 2417 on the boiler	Reduced discharge pressure Operational disturbances	PI 7127 low alarm Autostart of spare pump			
High (HP BFW)	Failure of FIC 3041	Increased extraction flow Reduced pump discharge pressure HHP	PI 7127 low alarm (HHP BFW) PI 7125 low alarm (HP BFW) Autostart of spare pump Pumps (two pumps running) designed for maximum extraction of HP BFW flow			
Low (HHP BFW)	Failure of boiler level control	Flow from pump close to zero Increasing pressure	Minimum flow protection			
Low (HP BFW)	Failure of boiler level control	Flow from pump close to zero Increasing pressure	Covered by minimum flow protection for HHP BFW			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 27 BFW pumps and distribution	P&ID no.: U10, U11	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Back flow		See node 26				

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 28 HHP boiler (D2001, E2022 1/2)	P&ID no.: P17, P18, P19  Design P/T:	Intention:  Operating P/T:	Date: 24.06.2010


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (BFW)	Fail open of control valve FV 2417	High level in D2001  Liquid carry over to super heater, consequently liquid to turbines	LIC 2372 high alarm  LI 2373 high alarm	96. Consider adding low alarm on TIC 2360	HTAS	
High (steam flow)	Opening of vent, PIC 2361	Decreasing pressure  Increased evaporation  Loss of steam	Stop of steam export to BL (see HHP steam control)			
High (blow down)	Unintended full open valve HV 2385	No consequences				
High (deaerator recycling)	Fail open of HV 2371	Reduced BFW temperature  Reduced steam production				
High (phosphate)	Wrong adjustment of dosing pump	Increased chemical consumption  No significant consequences	Overconsumption to be seen by operator  Regular analysis of BW			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 28 HHP boiler (D2001, E2022 1/2)	P&ID no.: P17, P18, P19	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (intermit- tent blow down)	Mechanical failure of valve (valve cannot be left open due to spring and lever operation)	Reduced steam production				
Low (BFW)	Fail close of control valve FV 2417	Low level in D2001  Overheating of waste heat boiler E2020	LIC 2372 low alarm  LI 2373 low alarm  LSAL 2372, IS 1 trip of reformer			*
Low (phos- phate)	Wrong adjustment of dos- ing pump  Blocked outlet	Increased scale formation  Exceeding dosing pump dis- charge pressure	Regular analysis of BW  PSVs 7165, 7168			
Low (blow down)	Unintended closure of valve HV 2385	Build up of impurities	Regular analysis of BW  AI 2348 high alarm (conductivity)			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 28 HHP boiler (D2001, E2022 1/2)	P&ID no.: P17, P18, P19  Design P/T:	Intention:  Operating P/T:	Date: 24.06.2010

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (blocked outlet)	Closure of PIC 2363	Increasing pressure in the boiler  Potentially exceeding design pressure	PIC 2361 alarm high (opens vent)  PI 2372 high alarm  PSVs 2376-2379			
Reverse flow to chemical injection		Not possible (check valves and reciprocating pumps)				
Reverse flow (into phosphate system)		Back flow of BFW	2 check valves (before injection point and at pump discharge)  Reciprocating dosing pump			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Failure of TIC 2360 (open bypass on the super heated steam)  Loss of S steam to E2021 1/2/3 by lifting PSVs on steam drum D2001	Exceeding design temp in E2021 1 or 2	TIC 2360 high alarm (super heated steam)  TSAH 2360, IS 1 (do not detect all failure modes, potential overheating of one train does not cause high temp of super heated steam)	97. Consider adding high alarm on TI 2355 and TI 2356 (previously added, see action no. 40)	HTAS	*


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 28 HHP boiler (D2001, E2022 1/2)	P&ID no.: P17, P18, P19	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
	<p>Loss of steam to E2021 1/2/3 by closure of PV 2363 out of E2021 1/2</p> <p>Loss of circulating boiler water to E2020 1/2. Not possible</p> <p>Mal distribution of steam between 2021 1/2 by un-symmetrical piping</p> <p>Increasing pressure drop due to mechanical problems</p>	<p>Potential overheating of E2021 1/2/3</p> <p>High temperature, exceeding design temperature</p>	<p>If only one S steam PSV opens PIC 2361 vent will supply sufficient steam</p> <p>PIC 2361, high alarm (steam vent)</p> <p>TIC 2360 high alarm (super heated steam)</p> <p>TSAH 2360, IS 1</p> <p>TI 2352 high alarm (on process gas)</p> <p>TI 2355 and TI 2356 (on the steam side)</p>	<p>98. Correct FLO instead of FLC on PV 2363. (previously added, see action no. 43)</p> <p>99. Consider LO on block valves before automatic vents. (previously added, see action no. 44)</p>	<p>HTAS</p> <p>HTAS</p>	*


	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 28 HHP boiler (D2001, E2022 1/2)	P&ID no.: P17, P18, P19 Design P/T:	Intention: Operating P/T:	Date: 24.06.2010

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (steam)	Closure of bypass TIC 2360	Increased condensation risk in turbine  Increased steam production	TIC 2360 (on combined stream)	100. Consider adding low alarm on TIC 2360 (previously added, see action no. 96)	HTAS	
Low (preheated BFW)		Reduced steam production				
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (in D2001)	Blocked outlet by closure of PIC 2363	Increasing pressure in the boiler  Potentially exceeding design pressure	PIC 2361 alarm high (opens vent)  PI 2372 high alarm  PSVs 2376-2379			
Low (in D2001)	Open vent  Increased consumption of HHP steam	Decreasing pressure  Increased evaporation  Loss of steam	Stop of steam export to BL (see HHP steam control)  PIC 2363 maintains pressure in D2001  PIC 2363 low alarm  PI 2372 low alarm (on D2001)			




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 28 HHP boiler (D2001, E2022 1/2)	P&ID no.: P17, P18, P19	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Composition</b>		<b>Intention:</b>				
Impurities in boiler water		See flow				
<b>Parameter: Level</b>		<b>Intention:</b>				
High	Fail open of control valve FV 2417	High level in D2001  Liquid carry over to super heater, consequently liquid to turbines	LIC 2372 high alarm  LI 2373 high alarm	101. Consider adding low alarm on TIC 2360 (previously added, see action no. 96)	HTAS	
Low	Fail close of control valve FV 2417	Low level in D2001  Overheating of waste heat boiler E2020	LIC 2372 low alarm  LI 2373 low alarm  LSAL 2372, IS 1 trip of reformer			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 29 HHP steam header	P&ID no.: U03, U04, U07	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (to turbine FT3001)	Over consumption in turbine	Less steam export  Low pressure in HHP header	PIC 2363 low alarm  PIC 2372 low alarm  PIC 7025 (export steam)			
High (to HP header)	Fail open of PIC 7002	Depressurize HHP steam header to HP steam header pressure  Less steam to turbine	PIC 2363 low alarm  PIC 2372 low alarm  PIC 7025 (export steam)			
High (export steam)	Fail open of PIC 7025	Low pressure in HHP header  Less steam to turbine	PIC 2363 low alarm  PIC 2372 low alarm			
High (through vent)	Fail open of vent	See node 28				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 29 HHP steam header	P&ID no.: U03, U04, U07	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (to turbine)	Trip of turbine FT3001	Increasing pressure in HHP header	PV 7002 (open letdown valve to preset position based on HP extraction steam flow prior to trip and activated by turbine trip)  PIC 7025 (export steam)  PIC 7002 (on HHP header which will force open PV 7002)  PIC 2363 high alarm (and venting (25% capacity))  PSV on D2001			
Low (export steam)	Fail close of PIC 7025	Increasing pressure in HHP header	PIC 7002 (on HHP header which will force open PV 7002)  PIC 2363 high alarm and venting (25% capacity)  PI 2372 high alarm			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	See high temperature in node 28					

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 29 HHP steam header	P&ID no.: U03, U04, U07	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (export steam)	Fail close of BFW, TIC 7026 or TIC 7027	High temperature of export steam	TIC 7026, 7027 high alarm  Design temperature of export steam line is higher than normal temperature in HHP header (470 C vs. 460 C)	102. Consider adding high alarm on TI 7021	HTAS	
Low (export steam)	Fail open of BFW, TIC 7026 or TIC 7027	Low temperature of export steam  Potentially liquid in export steam	TIC 7026, 7027 low alarm	103. Consider adding low alarm on TI 7021	HTAS	
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (HHP header)	See low flow					
High (HHP BFW quench line)	Expanding liquids in between blocked valves	Tube rupture	PSV (depending upon type of valve chosen)			
Low (HHP header)	See high flow					

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 30 HP steam header	P&ID no.: U02, U03, U05, U6, U07	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (from turbine)	Fail open of extraction steam valve	Increasing pressure in HP header  Condensing turbine FT3001/2 will be unloaded and the system will call for more HHP steam to extraction turbine	PIC 7004 venting of excess steam	104. Consider adding high alarm on PT 7003 or PT 7004	HTAS	
High (letdown flow)	Fail open of PIC 7002	Increasing pressure in HP header	PIC 7004 venting of excess steam			
High (steam to turbine)	Over consumption	Decreasing pressure in HP header	PIC 7001 (extraction steam)  PIC 7003 (letdown)	105. Consider adding low alarm on PT 7003 or PT 7004	HTAS	
Low (to header)	Fail close of extraction steam valve	Decreasing pressure in HP header	PIC 7003 (letdown)			
Low (steam to turbine)	Trip of turbine	Increasing pressure in HP header	PIC 7001 (extraction steam)  PIC 7004 venting of excess steam  PSVs 7010, 7011			

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 30 HP steam header	P&ID no.: U02, U03, U05, U6, U07	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse	No cause					
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (HHP let-down)	Fail close of BFW quench valve	Potentially exceeding design temperature (410 C)	TIC 7002, 7003, 7004 high alarms (on let-down line)  Operator has the opportunity to switch to spare letdown valve	106. Consider adding high alarm on TI 7007	HTAS	
High (BFW to import steam during start up)	Fail close of quench valve	Increased temperature in HP header	Normal temperature of import steam is 410 C which is corresponding to mechanical design temp of HP header			
Low (HHP let-down)	Fail open of BFW quench valve	Decreasing temperature of HP header  Potential condensation	TIC 7002, 7003, 7004 low alarms (on let-down line)  Operator has the opportunity to switch to spare letdown valve	107. Consider adding low alarm on TI 7007	HTAS	
Low (extraction steam temp)	Low temperature of HHP steam inlet to turbine	Decreasing temperature of HP header	TIC 2360 low alarm (superheated steam)	108. Consider adding low alarm on TI 7007 (previously added, see action no 107)	HTAS	


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 30 HP steam header	P&ID no.: U02, U03, U05, U6, U07	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (HP header)		See flow				
High (HHP BFW quench line)	Expanding liquids in between blocked valves	Tube rupture	PSV (depending upon type of valve chosen)			
Low (HP header)		See flow				


		HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 31 MP steam header	P&ID no.:		Intention:	Date: 25.06.2010
	Design P/T:		Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (letdown to LP header)	Fail open of PV 7031 C or D	Decreasing pressure in MP header	PIC 7031 A or B (letdown of HP steam)	109. Consider adding low alarm on PI 7034	HTAS	
High (letdown from HP header)	Fail open of PV 7031 A or B	Increasing pressure in MP header	PIC 7031 C or D (letdown to LP steam) PIC 7034 vent PSV 7036	110. Consider adding high alarm on PI 7034	HTAS	
High (through vent)	Fail open of PIC 7034	Decreasing pressure in MP header	PIC 7031 A or B (letdown of HP steam)			
Low (to LP header)	Fail close of PV 7031 C or D	Increasing pressure in MP header	PIC 7031 C or D (letdown to LP steam) PIC 7034 vent PSV 7036			
Low (from synthesis)	Trip of synthesis	Decreasing pressure in MP header	PIC 7031 A or B (letdown of HP steam)			




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 31 MP steam header	P&ID no.:	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Loss of BFW quench during letdown from HP header	Potentially exceeding design temperature	TIC 7033, 7032 high alarms  Operator has the opportunity to switch to spare letdown valve	111. Consider adding high alarm on TI 7031	HTAS	
Low	Fail open of BFW quench	Potential condensation (Steam is normally saturated)	TIC 7033, 7032 low alarms  Operator has the opportunity to switch to spare letdown valve			
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (MP header)	Letdown from HP header	See flow				
High (HP BFW quench line)	Expanding liquids in between blocked valves	Tube rupture	PSV (depending upon type of valve chosen)			
Low (MP header)		See flow				

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 32 LP steam header	P&ID no.:	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (inlet to LP header)	Fail open of extraction valve  Fail open of letdown valve from HP steam header  Fail open of letdown valve from MP steam header	Increasing pressure in LP header, potentially exceeding design pressure	PIC 7056 venting  PSVs 7056 - 7060	112. Consider adding high alarm on PIC 7056	HTAS	
Low (inlet to LP header)	Fail close of extraction valve  Fail close of letdown valve from HP steam header  Trip of HP to LP turbines	Decreasing pressure in LP header  Reduction of distillation capacity	PIC 7055 (extraction)  PIC 7051 (letdown from HP header)  PI 5307 low alarm (MP column reboiler)			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	Loss of BFW quench during letdown from HP header	Increasing temperature  Potential damage of reboiler tube sheet		113. Consider adding high alarm on TI 7056, 7052, 7053	HTAS	

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 32 LP steam header	P&ID no.:	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Fail open of BFW quench during letdown from HP header	Decreasing temperature, potentially condensation		114. Consider adding low alarm on TIC 7052, 7053		
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (LP header)		See flow				
High (HP BFW quench line)	Expanding liquids in between blocked valves	Tube rupture	PSV (depending upon type of valve chosen)			
Low (LP header)		See flow				

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 33 MP steam drum (D3003)	P&ID no.: P05, P23	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (BFW)	Fail open of control valve FV 3041	High level in D3003  Liquid carry over to MP steam header	LIC 3042 high alarm  LI 3034 high alarm			
High (condensate)	Fail open of control valve LV 6021 A	High level in D3003  Liquid carry over to MP steam header	LIC 3042 high alarm  LI 3034 high alarm			
High (steam flow)	Opening of MP steam header vent, PIC 7034	Decreasing pressure  Increased evaporation  Loss of steam	PIC 3042 low alarm (maintaining pressure in D3003)			
High (blow down)	Unintended full open valve HV 3054	No consequences				
High (phosphate)	Wrong adjustment of dosing pump	Increased chemical consumption  No significant consequences	Overconsumption to be seen by operator  Regular analysis of BW			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 33 MP steam drum (D3003)	P&ID no.: P05, P23	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (intermittent blow down)	Mechanical failure of valve (valve cannot be left open due to spring and lever operation)	Reduced steam production				
Low (BFW)	Fail close of control valve FV 3041	Low level in D3003 Overheating of reactor R3001	LIC 3042 low alarm LI 3043 low alarm LSAL 3042, IS3 trip of synthesis			*
Low (condensate)	Fail close of control valve LV 6021 A	Low level in D3003 Overheating of reactor R3001	LIC 3042 low alarm (adding BFW) LI 3034 low alarm LSAL 3042, IS3 trip of synthesis			*

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 33 MP steam drum (D3003)	P&ID no.: P05, P23	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (phosphate)	Wrong adjustment of dosing pump  Blocked outlet	Increased scale formation  Exceeding dosing pump discharge pressure	Regular analysis of BW  PSVs 7171, 7174			
Low (blow down)	Unintended closure of valve HV 3054	Build up of impurities	Regular analysis of BW  AI 3055 high alarm (conductivity)			
Low (steam)	Closure of PIC 3042	Increasing pressure in the boiler  Potentially exceeding design pressure	PIC 3042 high alarm (2 out of 3)  PSVs 3047, 3048			
Reverse flow to chemical injection		Not possible (check valves and reciprocating pumps)				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 33 MP steam drum (D3003)	P&ID no.: P05, P23	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse flow (into phosphate system)		Back flow of BFW	2 check valves (before injection point and at pump discharge)  Reciprocating dosing pump			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High	High operating pressure	Exceeding design temperature	Design temperature selected as boiling point at design pressure			
Low	Low operating pressure	Reduced reaction temperatures in R3001 (see temperature node 12a)	PIC 3042 low alarm (maintaining pressure in D3003)			
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (in D3003)	Closure of PIC 3042  Tube rupture in R3001	Increasing pressure in the boiler  Potentially exceeding design pressure  Inert build up in steam condensers reducing performance	PIC 3042 high alarm (2 out of 3)  PSVs 3047, 3048  Check of inerts in MP steam AP 3049 and MeOH in MP blow down AP 3054 and pressure temperature relation in steam in case tube leaks is suspected	115. Check PSV for R3001 tube rupture case	HTAS	


	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 33 MP steam drum (D3003)	P&ID no.: P05, P23	Intention:	Date: 25.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low (in D3003)	Opening of MP steam header vent, PIC 7034	Decreasing pressure  Increased evaporation  Loss of steam	PIC 3042 low alarm (maintaining pressure in D3003)			
<b>Parameter: Composition</b>		<b>Intention:</b>				
Impurities in boiler water		See flow				
<b>Parameter: Level</b>		<b>Intention:</b>				
High	Fail open of control valve FV 3041  Fail open of control valve LV 6021 A	High level in D3003  Liquid carry over to MP header	LIC 3042 high alarm  LI 3043 high alarm			
Low	Fail close of control valve FV 3041  Fail close of control valve LV 6021 A	Low level in D3003  Overheating of reactor R3001	LIC 3042 low alarm  LI 3043 low alarm  LSAL 3042, IS3 trip of synthesis			*




	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 34 Blow down system	P&ID no.: U16	Intention:	Date: 28.06.2010
	Design P/T: 9.5 barg, 340 C D7002, 5.0 barg, 160 C D7003	Operating P/T: 7.5 barg D7002, 0.0 barg D7003	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (from D2001)	Open blow down valve HV 2385	Higher LP steam production Increased level in D7002	LIC 7251 high alarm			
High (from D3003)	Open blow down valve HV 3054	Higher LP steam production Increased level in D7002	LIC 7251 high alarm			
High (to D7003)	Fail open of LV 7251	Increased level in D7003	Open drain Level determined by gravity			
High (from E2020)	Fail open of HV 2334 or HV2335	Increased level in D7003	Spring/lever operated blow down valve (avoids opening for long time)			
High (from R3001)	Fail open of HV 3087, HV 3090 or HV 3093	Increased level in D7004	Spring/lever operated blow down valve (avoids opening for long time)			
Low		No consequences				
Reverse	No causes					

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 34 Blow down system	P&ID no.: U16	Intention:	Date: 28.06.2010
	Design P/T: 9.5 barg, 340 C D7002, 5.0 barg, 160 C D7003	Operating P/T: 7.5 barg D7002, 0.0 barg D7003	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (D7002)		Not possible	Upstream piping is rated for upstream pressure and temperature conditions. Temperature in D7002 is determined by LP steam pressure			
High (D7003)		Not possible	Upstream piping is rated for upstream pressure and temperature conditions. Temperature in D7003 is determined by atmospheric pressure			
High (D7004)		Not possible	Upstream piping is rated for upstream pressure and temperature conditions. Temperature in D7004 is determined by atmospheric pressure			
High (after E7001)	Cooling water failure	Hot water to drain system Small evaporation from vent				
High (after E7002)	Cooling water failure	Hot water to drain system Small evaporation from vent				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 34 Blow down system	P&ID no.: U16	Intention:	Date: 28.06.2010
	Design P/T: 9.5 barg, 340 C D7002, 5.0 barg, 160 C D7003	Operating P/T: 7.5 barg D7002, 0.0 barg D7003	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (D7002)	Blocked outlet on LP steam by closing manual valve	Increasing pressure, exceeding design pressure	PSV 7253			
High (D7003)	Gas break through from LP header due to fully open FV 7251 or fully open intermittent blow down valve	Increasing pressure (Exceeding design pressure is not possible)	Open vent to atmosphere			
High (D7004)	Fully open intermittent blow down valve	Increasing pressure (Exceeding design pressure is not possible)	Open vent to atmosphere			
Low		No consequences				
<b>Parameter: Level</b>		<b>Intention:</b>				
High (D7002)	Fail close of LIC 7251	Condensate into LP steam system	LIC 7251 high alarm	116. Regular inspection of level gauge on D7002 during operation	MEKPCO	

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 34 Blow down system	P&ID no.: U16	Intention:	Date: 28.06.2010
	Design P/T: 9.5 barg, 340 C D7002, 5.0 barg, 160 C D7003	Operating P/T: 7.5 barg D7002, 0.0 barg D7003	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (D7003/D7004)	Fully open intermittent blow down valve	Liquid build up	Liquid will be removed by gravity flow			
Low (D7002)	Fail open of LIC 7251	See high pressure				

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 35 H <sub>2</sub> recycle system	P&ID no.: U17, P09, P12, P27	Intention:	Date: 28.06.2010
	Design P/T:	Operating P/T:	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (to desulphurization)	Fail open of FV 2150	Decreasing pressure in header, increasing H2 recycle	PIC 2608 PI 2150 low alarm			
High (to reformer, small compared to recycle flow in loop)	Fail open of FIC 2079 during normal operation	Decreasing pressure in header (PIC 2608 not dimensioned for simultaneous opening of FV 2150 and FV 2079) , increasing H2 recycle	PIC 2608 PI 2150 low alarm			
	Shut down of reformer	Decreasing pressure in header (sufficient gas hold up in loop for more than 5 minutes supply)	PIC 2608 PI 2150 low alarm			
High (H2 import)	Fail open of PV 2603	Increasing pressure in header upstream compressor C2002	Design pressure for upstream C2002 corresponds to design pressure of H2 import			
High (recycle from D2005)	No causes					

	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 35 H <sub>2</sub> recycle system	P&ID no.: U17, P09, P12, P27	Intention:	Date: 28.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High (recycle from loop)	Fail open of PC 2608	Increasing pressure in header, exceeding design pressure	PSV 2604	117. Consider adding high alarm on PI 2150	HTAS	
Low (to desulphurization)	Fail close of FV 2150	Increasing pressure in header	PIC 2608 FIC 2150 low alarm, low deviation alarm PSV 2604			
	Trip of compressor C2002 or fail close of PV 2608	Decreasing pressure in header	PI 2150 low alarm FIC 2150 low alarm, low deviation alarm			
Low (to re-former during shut down)	Fail close of FV 2079	Increasing pressure in header	PIC 2608 PSV 2604			
Reverse	Trip of compressor C2002	Back flow	Reciprocating compressor Check valve (at compressor outlet downstream kick back line) Kick back line valve closes			


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 35 H <sub>2</sub> recycle system	P&ID no.: U17, P09, P12, P27	Intention:	Date: 28.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Reverse (from consumers to header)	Loss of H <sub>2</sub> recycle header pressure	Loss of H <sub>2</sub> supply	Check valves (in supply line to desulphurizer and tubular reformer)			
Reverse (to synthesis)	Trip of synthesis compressor and loss of pressure in loop	Back flow	Check valve in recycle line from loop			
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (from recycle compressor C2002)	Loss of cooling	Increasing temperature, exceeding design temperature	TI 2150, indicator	118. Consider increasing design temperature on H <sub>2</sub> recycle header to 200 C corresponding to C2002 discharge temperature	HTAS	
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High (H <sub>2</sub> header)	Fail open of PV 2608	Exceeding design pressure, see high flow				


	 <p>HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran</p>	<p>HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI</p>	
Node: 35 H <sub>2</sub> recycle system	P&ID no.: U17, P09, P12, P27	Intention:	Date: 28.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
High	Failure of compressor discharge pressure control, C2002	Exceeding design pressure	PSV 2604	119. Consider adding high alarm on PI 2150 (previously added, see action no 117)	HTAS	
High	Fail close of FV 2150 or FV 2079	See low flow				
Low (H <sub>2</sub> header)	Fail close of PV 2608	Decreasing pressure in header	PI 2150 low alarm FIC 2150 low alarm, low deviation alarm			
Low (upstream compressor C2002)	Fail close of PV 2603	Decreasing suction pressure Loss of H <sub>2</sub> supply to consumers	Trip of compressor, to be covered by compressor vendor scope PI 2150 low alarm FIC 2150 low alarm, low deviation alarm			




	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 36 Start up blower	P&ID no.: U02	Intention:	Date: 28.06.2010
	Design P/T: 12 barg	Operating P/T: 6 barg	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Flow</b>		<b>Intention:</b>				
High (reformer section)		No consequences				
High (anti surge line)	Fail open of PDV 2575	Reduced flow to reforming section, potentially overheating of reformer	FI 2582 low alarm FSAL 2582, IS 1 trip of reformer			*
Low (reformer section)	Stop of blower, C2001 Open anti surge line	Reduced flow to reforming section, potentially overheating of reformer	FI 2582 low alarm FSAL 2582, IS 1 trip of reformer			*
Reverse (to N2 header)	Trip of blower C2001  Introduction of process gas during start up	Back flow	Check valve on N2 supply line  Check valve  Block valves on N2 supply closed according to operating manual before introduction of process gas			

	 <b>HAZOP</b> 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	<b>HAZOP Group:</b> N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 36 Start up blower	P&ID no.: U02	Intention:	Date: 28.06.2010
	Design P/T: 12 barg	Operating P/T: 6 barg	


Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Pressure</b>		<b>Intention:</b>				
High	Blocked outlet from blower C2001	Surge of blower C2001  Exceeding design pressure	PDIC 2575 high alarm  PI 2579 high alarm  PDAHH 2575, I16 trip of N2 blower C2001  PSV 2581 (designed for blocked outlet)  PDIC 2575 high alarm  PI 2579 high alarm  PDAHH 2575, I16 trip of N2 blower C2001			*       *
High	Maloperation during start up (pressurizing system before isolation of start up circuit)	Exceeding design pressure	PI 2579 high alarm  PSV 2581 (not dimensioned for this case)  Operating manual/start up procedure			

	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri, MEKPCO Søren Toft, Lars Moerner, Lone Johnsen, Hans Pedersen, HTAS Finn Pedersen, Gunilla Kay Christiansen, Birgitte Madsen, COWI	
Node: 36 Start up blower	P&ID no.: U02	Intention:	Date: 28.06.2010
	Design P/T: 12 barg	Operating P/T: 6 barg	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Low	Closed N2 make up and leaks from system	Reduced circulation of N2  Overheating of reformer	PI 2579 low alarm  FI 2582 low alarm (temperature and pressure compensated)	120. Consider installing pressure compensated trip on low flow FSAL 2582	HTAS	
<b>Parameter: Temperature</b>		<b>Intention:</b>				
High (D2005)	Loss of cooling	Reduced circulation of N2	TI 2572 high alarm			
High (discharge C2001)	Loss of cooling	Potential damage of blower C2001	TI 2579 high alarm  TAHH 2579, I16 trip of N2 blower C2001			*
Low		No consequences				
<b>Parameter: Composition</b>		<b>Intention:</b>				
Low Mw of start up circulation gas	Introduction of process gas	Surge and high pressure	PDIC 2575 Antisurge control  PIC 2481 vent (out of D2005)  PI 2579 high alarm			

COWI A/S	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran.	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri (part time), MEKPCO Hans Pedersen, Lars Moerner, Lone Johnsen, HTAS Finn Pedersen, Birgitte Madsen, COWI	
Node: 37 General	P&ID no.:	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
<b>Parameter: Other</b>		<b>Intention:</b>				
PSVs not opening on demand	Block valves around PSVs are closed	Over pressuring system, damage of equipment, rupture, release to atmosphere, potential fire, hazard to personnel		121. HTAS do not recommend block valves around PSVs without interlock  122. Implement mechanical interlock between isolating valves on PSV during detailed engineering (API 520)  123. Add note on PIDs regarding mechanical interlock	HTAS  MEKPCO  HTAS	
External fire		Over pressurising and potential rupture of vessels	Depressurising of systems	124. Consider sprinkler system on major vessels	MEKPCO/detailed engineering	

COWI A/S	 HAZOP 5000 MTPD Methanol Plant Bandar Assaluyeh, Iran.	HAZOP Group: N. Mavadati, S. Shaker, M. Nabian, H. Moayeri (part time), MEKPCO Hans Pedersen, Lars Moerner, Lone Johnsen, HTAS Finn Pedersen, Birgitte Madsen, COWI	
Node: 37 General	P&ID no.:	Intention:	Date: 24.06.2010
	Design P/T:	Operating P/T:	

Deviation	Causes	Consequence	Safeguards	Recommendations	By	SR
Entering equipment under flare pressure	Back flow from flare (through not blinded lines)	Danger to personnel entering equipment	Authorized entry permit to ensure blinding before entering.	125. Assure incorporation in detailed operating manual and maintenance procedure	MEKPCO/detailed engineering	

## Appendix B: List of recommendations

Node	ID	Recommendations	Action by
1	1	Maximum delivery pressure of NG at BL (60 barg) to be assured	MEKPCO / DAMAVAND
1	2	Drain valve to be visible from level gauge	MEKPCO/detailed engineering
2	3	Open false air dampers on IS-1 trip (on shutdown of system)	HTAS
2	4	Check minimum flow rate required	HTAS
2	5	Add high temperature alarm on TIC 2220 (E2004 outlet)	HTAS
2	6	Add high alarm on AI 1045	HTAS
2	7	Consider procedure to ensure operator shut down plant on high alarm AI 1045	HTAS
3-gas	8	Increase design temperature to 290 C	HTAS
3-gas	9	If design temperature is not increased then consider temperature alarms out of T6001	HTAS
3-gas	10	Consider low level alarms on LI 6033 and LI 6034	HTAS
3-gas	11	Consider high alarm on PIC 2073	HTAS
3-gas	12	Ensure operating manual covers H2SO4 is used as regenerator.	HTAS
3 –gas	13	Check / clean tubes to be included in detailed procedure	HTAS
3-gas	14	To be highlighted in operating manual	HTAS
3-liquid	15	Install PSV downstream FV 6031	HTAS
3-liquid	16	Design pressure out of process water streams to be checked against maximum shut off pressure from P2001,	MEKPCO

		P2002, P2003, P5010.	
3-liquid	17	Add LSAL and USV on blow down inlet D6002	HTAS
4	18	Consider additional flow meters for reference	HTAS
4	19	Consider installing specific gravity analyser (2 out of 3) with discrepancy alarm and automatic input to S/C ratio calculation (AST)	HTAS
4	20	Assure correct installation, calibration and function of flow elements and meters for S/C ratio during commissioning	MEKPCO/ detailed engineering contractor
4	21	Consider additional flow meters for reference ( <b>previously added, see action no 18</b> )	HTAS
4	22	Consider installing specific gravity analyser (2 out of 3) with discrepancy alarm and automatic input to S/C ratio calculation (AST) ( <b>previously added, see action no 19</b> )	HTAS
4	23	Consider adding low alarm on TIC 2232	HTAS
5	24	Consider high alarm on AI 2223 1 and AI 2224	HTAS
5	25	Consider installing deviation alarm and high alarm on QIC 2535	HTAS
5	26	Consider LTM (load and temperature management) system for duty control. LTM will include input from LHV analysers.	HTAS
5	27	Procedure to be included in operating manual	HTAS
5	28	Add high alarm on AI 2479	HTAS
5	29	Add rate of change alarm on temperature TI 2295 and TI 2297.	HTAS

6a	30	Add high alarm on AI 2479. ( <b>previously added, see action no. 28</b> )	HTAS
6a	31	Consider automatic O/C ratio control as part of LTM	HTAS
6a	32	Add high alarm on AI 2479. ( <b>previously added, see action no. 28</b> )	HTAS
6a	33	Add note to PID defining water system	HTAS
6a	34	Skimming of cat (change top layer) according to operating manual	MEKPCO
6a	35	When replacing tiles ensure high quality of tiles to avoid ruby formation	MEKPCO
6a	36	High alarm on AI 2479 ( <b>previously added, see action no. 28</b> )	HTAS
6a	37	MEKPCO should supervise detailed design of piping layout according to HTAS requirements as indicated on the PIDs.	MEKPCO
6b	38	Check mechanical design of E2021 1/2 for consequences of high temperature, alternatively include trip on high temp	HTAS
6b	39	Consider one THIC on each boiler operating both sets of dampers, TV 2360 1 and 2 and one THIC for TV 2360 3 and 4. (Post HAZOP meeting HTAS decision as per 08.07.2010: <b>Not recommended</b> )	HTAS
6b	40	Consider high temp alarm on TI 2351 and 2353 (gas out of E2021 1/2) and TI 2355 and 2358 (steam out of E2021 1/2)	HTAS
6b	41	Add failure modes of TV 2360 1/2/3/4 on PID and correct node 8	HTAS
6b	42	Consider cascade control for TIC 2360 and TI 2335 and TI 2336 to prevent uneven flows	HTAS
6b	43	Correct FLO instead of FLC on PV 2363	HTAS
6b	44	Consider LO on block valves before	HTAS



		automatic vents	
6b	45	Consider high alarm on TI 2355 and TI 2356 ( <b>previously added, see action no. 40</b> )	HTAS
8	46	Consider installing PSV on shell side on E2023 for tube rupture as the current PSV 5250, 5251 are on the top of the MP column.  (Post HAZOP meeting HTAS decision as per 08.07.2010: <b>Not recommended</b> )	HTAS
9	47	Consider installing PSV protecting shell side on E2024 for tube rupture as the current PSV 5058, 5059 and 5060 are on the top of the stabilizer column.  (Post HAZOP meeting HTAS decision as per 08.07.2010: <b>Not recommended</b> )	HTAS
10	48	Change design pressure of comp C3001 inlet to 29 barg	HTAS
10	49	Fire and gas detection system (entire plant) to be considered by detailed engineering	MEKPCO
11	50	Detailed HAZOP on compressor C3001/C3002 to be made when documentation is available from compressor vendor (PIDs) for compliance with HTAS process specifications.	MEKPCO/ detailed engineering contractor
12a	51	Add high alarm on TIC 3113 and TIC 3116 and TIC 3118	HTAS
12b	52	Fire and gas detection system (entire plant) to be considered by detailed engineering ( <b>previously added, see action no. 49</b> )	MEKPCO
12b	53	Assure blockages of all connecting pipes including PSVs before entering vessel see, node 37	MEKPCO
13	54	Filters are still under evaluation. HTAS has to specify details	HTAS
13	55	Add heat tracing on instrument piping to/from level transmitters, level gauges and PDT 3200.	HTAS

13	56	Add note on PIDs on Shortening instrument piping as much as possible	HTAS
13	57	Consider tracing of bypass piping	HTAS
14	58	Check PSV 5006 layout to avoid static pressure build up	HTAS
15	59	Consider adding high alarm on LI 5042	HTAS
15	60	Check if system can handle three re-boiler in operation at same time alternative consider blocking in E5001	HTAS
15	61	Consider adding high alarm on LI 5094	HTAS
15	62	Consider adding high alarm on LI 5094 <b>(previously added, see action no. 61)</b>	HTAS
15	63	Check design temperature of tubes in reboiler E5001 (dry running)	HTAS
16	64	Consider adding high alarm on LI 5162	HTAS
16	65	Consider adding high alarm on LI 5204	HTAS
16	66	Consider adding high alarm on LI 5204 <b>(previously added, see action no. 65)</b>	HTAS
16	67	Check set pressure of PSAH 5207 to prevent release of liquid from PV 5207 B (static head)	HTAS
17	68	Consider adding high alarm on LI 5271	HTAS
17	69	Consider deviation alarm on FIC 5441	HTAS
17	70	Check design temperature of reboiler E5003 (dry running)	HTAS
17	71	Consider adding high alarm on LI 5271 <b>(previously added, see action no. 68)</b>	HTAS
17	72	Consider deviation alarm on FIC 5441 <b>(previously added see action no. 69)</b>	HTAS
18	73	Install blinds at individual inlet to polishers.	HTAS
18	74	Consider installing common PI and PG on inlet to polishers	HTAS
19	75	Consider installing a three way control	HTAS

		valve on the return line to ensure direct connection to at least one tank	
19	76	Consider installing common PI with high alarm on discharge line of pump P5008	HTAS
19	77	Consider thermal expansion valve on run down line (note on PID)	HTAS
19	78	Consider separate breather valves on tank TK5002 1/2	HTAS
19	79	Check PSV 5400, 5417 layout to avoid static pressure build up	HTAS
20	80	PSV 5450 to be designed for gas break through from D1001	HTAS
20	81	Consider changing manual drain valve from KO D1001 from 2" to 1"	HTAS
20	82	Consider installing separate shut off valve at low level in D1001	HTAS
20	83	PID to be updated to actual pump type (reciprocating pump)	HTAS
20	84	Consider adding high alarm on TI 5443	HTAS
20	85	Check PSV 5450 layout to avoid static pressure build up	HTAS
23	86	Ensure design temperature of the coils take reduced process gas flow into account	HTAS
23	87	Consider opening of false air damper at low pressure	HTAS
23	88	Assure correct installation of atmospheric leg at pressure instruments according to HTAS hook up drawing J24	MEKPCO
24	89	Add high alarm on AI 2479 ( <b>previously added see action 28</b> ).	HTAS
24	90	Ensure piping layout is in accordance with PIDs (no pockets)	MEKPCO

24	91	Consider if PSV 2014 is necessary	HTAS
24	92	Consider if local analysis point on incoming O2 line is possible from safety point of view	HTAS
24	93	MEKPCO should supervise detailed design of piping layout according to HTAS requirements as indicated on the PIDs ( <b>is added, see action no. 37</b> ).	MEKPCO
24	94	Ensure correct opening sequence of valve in detailed operating manual	MEKPCO
24	95	Alternatively change system to monel	HTAS
28	96	Consider adding low alarm on TIC 2360	HTAS
28	97	Consider high alarm on TI 2355 and TI 2356 ( <b>previously added, see action no. 40</b> )	HTAS
28	98	Correct FLO instead of FLC on PV 2363 ( <b>previously added, see action no. 43</b> )	HTAS
28	99	Consider LO on block valves before automatic vents ( <b>previously added, see action no. 44</b> )	HTAS
28	100	Consider adding low alarm on TIC 2360 ( <b>previously added, see action no. 96</b> )	HTAS
28	101	Consider adding low alarm on TIC 2360 ( <b>previously added, see action no. 96</b> )	HTAS
29	102	Consider adding high alarm on TI 7021	HTAS
29	103	Consider adding low alarm on TI 7021	HTAS
30	104	Consider adding high alarm on PT 7003 or PT 7004	HTAS
30	105	Consider adding low alarm on PT 7003 or PT 7004	HTAS
30	106	Consider adding high alarm on TI 7007	HTAS
30	107	Consider adding low alarm on TI 7007	HTAS

30	108	Consider adding low alarm on TI 7007 <b>(previously added, see action no 107)</b>	HTAS
31	109	Consider adding low alarm on PI 7034	HTAS
31	110	Consider adding high alarm on PI 7034	HTAS
31	111	Consider adding high alarm on TI 7031	HTAS
32	112	Consider adding high alarm on PIC 7056	HTAS
32	113	Consider adding high alarm on TI 7056, 7052, 7053	HTAS
32	114	Consider adding low alarm on TIC 7052, 7053	HTAS
33	115	Check PSV for R3001 tube rupture case	HTAS
34	116	Regular inspection of level gauge on D7002 during operation	MEKPCO
35	117	Consider adding high alarm on PI 2150	HTAS
35	118	Consider increasing design temperature on H2 recycle header to 200 C corre- sponding to C2002 discharge tempera- ture	HTAS
35	119	Consider adding high alarm on PI 2150 <b>(previously added, see action no 117)</b>	HTAS
36	120	Consider installing pressure compen- sated trip on low flow FSAL 2582	HTAS
37	121	HTAS do not recommend block valves around PSVs without interlock	HTAS
37	122	Implement mechanical interlock be- tween isolating valves on PSV during detailed engineering (API 520)	MEKPCO
37	123	Add note on PIDs regarding mechanical interlock	HTAS
37	124	Consider sprinkler system on major vessels	MEKPCO/detailed engineering
37	125	Assure incorporation in detailed operat- ing manual and maintenance procedure	MEKPCO/detailed engineering

