








Contractor:  TIANCHEN CORP. CHINA	PROJECT	MKP Methanol Project			Owner :  شرکت کیمیاوی پارسیس خاورمیانه Middle East Kinulaya Para Co.	
	UNIT	General Technical	PHASE	As Built Drawing		
	DOC. Title	Calculation Sheet for Pressure Safety Valve				
	Owner No.	MKP-11-AS-9000-IN-CAL-009				
	Contractor No.	MKP-11-AS-9000-PS84-CAL-009				
Licenser:	TOPSOE No.	N/A			Rev. : Z01	Page : 1 of 17



CALCULATION SHEET FOR PRESSURE SAFETY VALVE



REV.	DATE	PURPOSE OF ISSUE	PREPARE	CHECK	REVIEW	APPROVE
Z01	30.04.2020	As Built	Xu Yekun	Xu Hang	Liu Shengkai	
0	10.01.2017	Final Issue	Xu Yekun	Xu Hang	Shi Jing	
B	20.12.2016	Issued for Review	Xu Yekun	Xu Hang	Shi Jing	
A	08.11.2016	Issued for Review	Xu Yekun	Xu Hang	Shi Jing	

 TIANCHEN CORP. CHINA		PROJECT		MKP Methanol Project			Owner :		
		UNIT		General Technical	PHASE	As Built Drawing			
		DOC. Title		Calculation Sheet for Pressure Safety Valve					
		Owner NO.		MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.		MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.		N/A			Rev. : Z01	Page: 3 of 17	
Item NO.	PSV-1008 PSV-1009	P&ID NO.	1000-PID-002	Item NO.	PSV-1013 PSV-1014	P&ID NO.	1000-PID-002		
Case	Inadvertent opening of PV-1006			Case	Inadvertent opening of PV-1011				
Equation	$Ws=3171.3(Cv1-Cv2)Ph(Gg/T)^{0.5}$			Equation	-				
Parameter		Unit	Value	Parameter		Unit	Value		
<p>No flow and no venting, since the upstream pressure is only 52 barg, while the setting pressure of PSV-1008/1009 is 55 barg. TOPSOE designed this PSV in the condition that gas station was not exist.</p> <p>So minimum size PSV(1D2) will be choosen.</p> <p>Remark: PSV-1009 is spare PSV.</p>				Rated Cv value(Provided by vendor)			44		
				Venting required (Provided by vendor)		Nm ³ /h	37400		
				Venting required(Provided by TOPSOE)		Nm ³ /h	37000		
				Venting required (Ws)		kg/h	27950		
				<p>Remark: The venting required is decided by the structure of PV-1011. So TCC provided the venting condition to control valve vendor to calculated the flowrate passing through PV-1011 under venting condition. It is a little bigger than TOPSOE's value. So vendor's value is adopted.</p>					
Item NO.	PSV-1015	P&ID NO.	1000-PID-002	Item NO.	PSV-1031	P&ID NO.	1000-PID-003		
Case	Fire- unwetted surface			Case	Fire- unwetted surface				
Equation	$Ws=2.722*(Tw-T)^{1.25}*A*(M*P)^{0.5}/T^{1.1506}$			Equation	$Ws=182*C*A*(M*P*100/(T+273.15))^{0.5}$				
Parameter		Unit	Value	Parameter		Unit	Value		
F'			560.47	F'			69.84		
Wall temperature (Tw)		°C	593.00	Coefficient C			0.025		
Venting temperature (T)		°C	87.00	Operating temperature (T)		°C	380.00		
Exposed area (A)		m ²	16.18	Exposed area (A)		m ²	74.41		
Molecular weight (M)		g/mol	16.74	Molecular weight (M)		g/mol	16.54		
Venting pressure (P)		bara	53.00	Operating pressure (P)		bara	49.80		
Venting required (Ws)		kg/h	3602.31	Venting required (Ws)		kg/h	3824.06		
Remark:				Remark: According to API-521, F' is smaller than 182, then F' is set at 182 during calculation.					
Item NO.	PSV-1038	P&ID NO.	1000-PID-003	Item NO.	PSV-1043	P&ID NO.	1000-PID-003		
Case	Fire- unwetted surface			Case	Fire- unwetted surface				
Equation	$Ws=182*C*A*(M*P*100/(T+273.15))^{0.5}$			Equation	$Ws=182*C*A*(M*P*100/(T+273.15))^{0.5}$				
Parameter		Unit	Value	Parameter		Unit	Value		
F'			69.84	F'			69.84		
Coefficient C			0.025	Coefficient C			0.025		
Venting temperature (T)		°C	375.00	Operating temperature (T)		°C	375.00		
Exposed area (A)		m ²	43.96	Exposed area (A)		m ²	43.96		
Molecular weight (M)		g/mol	16.54	Molecular weight (M)		g/mol	16.54		
Venting pressure (P)		bara	49.30	Operating pressure (P)		bara	49.30		
Venting required (Ws)		kg/h	2256.58	Venting required (Ws)		kg/h	2256.58		
Remark: According to API-521, F' is smaller than 182, then F' is set at 182 during calculation.				Remark: According to API-521, F' is smaller than 182, then F' is set at 182 during calculation.					

 TIANCHEN CORP. CHINA	PROJECT		MKP Methanol Project			Owner :  شركت كيمياء باين خاور ميانه Middle East Technology Para Co.	
	UNIT		General Technical	PHASE	As Built Drawing		
	DOC. Title		Calculation Sheet for Pressure Safety Valve				
	Owner NO.		MKP-11-AS-9000-IN-CAL-009				
	Contractor NO.		MKP-11-AS-9000-PS84-CAL-009				
Licensor:		TOPSOE NO.	N/A			Rev. : Z01	Page: 4 of 17
Item NO.	PSV-2019	P&ID NO.	2000-PID-001	Item NO.	PSV-2121 PSV-2122	P&ID NO.	2000-PID-005
Case	Non-explosive liquified gas drum without insulation, fire case			Case	Outlets valve abnormally closed		
Equation	$Ws=2.55 \cdot 10^5 \cdot F \cdot Ar^{0.82} / q$			Equation	Total incoming steam and vapor plus that generated therein at relieving conditions		
Parameter		Unit	Value	Parameter		Unit	Value
Environment factor (F)		1	1.00				
Heated area (Ar)		m2	8.57				
Letent heat @venting condition (q)		kJ/kg	1600.00				
Venting required (Ws)		kg/h	928.02	Venting required (Ws)		kg/h	27180.00
Remark:				Remark: Rated operation of FT-2002: 27180kg/h; The value will be confirmed by ITT.			
Item NO.	PSV-2171 PSV-2172	P&ID NO.	2000-PID-006	Item NO.	PSV-2354-60	P&ID NO.	2000-PID-012
Case	Outlets valve abnormally closed			Case	Outlets valve abnormally closed		
Equation	Total incoming steam and vapor plus that generated therein at relieving conditions			Equation	Total incoming steam and vapor plus that generated therein at relieving conditions		
Parameter		Unit	Value	Parameter		Unit	Value
Venting required (Ws)		kg/h	48000.00	Venting required (Ws)		kg/h	83693.13
Remark: Rated operation of FT-2001:48000kg/h; The value will be confirmed by ITT.				Remark: The total capacity is 502159kg/h (Normal capacity is 456508 considering 1.1 times) which is shared by PSV-2354, PSV-2355, PSV-2356, PSV-2357, PSV-2358, PSV-2359; PSV-2360 is spare and its capacity is the same as PSV-2354-59.			
Item NO.	PSV-2354-60	P&ID NO.	2000-PID-012	Item NO.	PSV-2365	P&ID NO.	2000-PID-012
Case	Heat exchange E 2020 tube rupture (Liquid)			Case	Outlets valve abnormally closed		
Equation	$Ws=\min\{1.68 \cdot \rho \cdot d^2 \cdot (\Delta P / \rho)^{0.5}, F\}$			Equation	Superheater minimum flow protection.		
Parameter		Unit	Value	Parameter		Unit	Value
Heat exchange tube inner diameter (d)		mm	48.26	Venting required (Ws)		kg/h	110000.00
Liquid density (ρ)		kg/m3	683.00				
Differential pressure of high pressure side and low side (ΔP)		bar	74.70				
Flow rate @high pressure side (F)		kg/h	64721.50				
Venting required (Ws)		kg/h	883801				
Final Venting required (Ws)		kg/h	64721.50				
Remark: Just for the fluid at high pressure side is liquid phase. Comparing the normal flow rate for high pressure side (388329kg/h) and the calculation value (5302806kg/h), and choose the smaller value as the final venting required;The value is shared by six (PSV-2354-59), and PSV-2360 is spare and its capacity is the same as PSV-2354-59.				Remark: Superheater minimum flow protection.			

 TIANCHEN CORP. CHINA		PROJECT		MKP Methanol Project			Owner :  شركت كيمياء پارس خاور ميانه Middle East Technology Para Co.		
		UNIT		General Technical	PHASE	As Built Drawing			
		DOC. Title		Calculation Sheet for Pressure Safety Valve					
		Owner NO.		MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.		MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.		N/A			Rev. : Z01 Page: 5 of 17		
Item NO.	PSV-2376~80	P&ID NO.	2000-PID-013	Item NO.	PSV-2458	P&ID NO.	2000-PID-015		
Case	Outlets valve abnormally closed			Case	Heat exchange E 2025 tube rupture (Gas)				
Equation	Total incoming steam and vapor plus that generated therein at relieving conditions			Equation	$W_s=2.463*d^2*(\Delta P*\rho V/10)^{0.5}$				
Parameter		Unit	Value	Parameter		Unit	Value		
Environment factor (F)		1	1.00	Tube inner diameter (d)		mm	22.10		
Heated area (Ar)		m2	8.57	Gas density (ρV)		kg/m3	9.09		
Letent heat @venting condition (q)		kJ/kg	1600.00	Differential pressure of high pressure side and low side (ΔP)		bar	20.30		
Venting required (Ws)		kg/h	107500.00	Venting required (Ws) in E2025 shell side		kg/h	5167.48		
Remark: The total capacity is 430000kg/h (Normal capacity is 388329 considering 1.1 times) which is shared by PSV-2376, PSV-2377, PSV-2378, and PSV-2379; PSV-2380 is spare and its capacity is the same as PSV-2376~79.				Remark: Just for the fluid at high pressure side is gas phase. Choose the bigger value as Ws after comparing the value in datasheet of HTAS (13200Nm3/h or 7107kg/h) with the calculation.					
Item NO.	PSV-2494	P&ID NO.	2000-PID-016	Item NO.	PSV-2546 PSV-2555	P&ID NO.	2000-PID-017		
Case	Heat exchange E 2027 tube rupture (Gas)			Case	Inadvertent opening of PCV-2545				
Equation	$W_s=2.463*d^2*(\Delta P*\rho V/10)^{0.5}$			Equation	-				
Parameter		Unit	Value	Parameter		Unit	Value		
Tube inner diameter (d)		mm	15.75	Venting required (Provided by vendor)		Nm3/h	2900.00		
Gas density (ρV)		kg/m3	10.7	Venting required(Provided by TOPSOE)		Nm3/h	1350.00		
Differential pressure of high pressure side and low side (ΔP)		bar	22.70	Venting required (Ws)		kg/h	3625.00		
Venting required (Ws) in E2027 shell side		kg/h	3011.14	Remark: The venting required is decided by the structure of PCV-2545. So TCC provided the venting condition to control valve vendor to calculated the flowrate passing through PCV-2545 under venting condition. It is bigger than TOPSOE's value. So vendor's value is adopted.PSV-2555 is spare.					
Remark: Just for the fluid at high pressure side is gas phase. Choose the bigger value as Ws after comparing the value in datasheet of HTAS (6000Nm3/h or 3011kg/h) with the									
Item NO.	PSV-2604 PSV-2605	P&ID NO.	2000-PID-019	Item NO.	PSV-2581	P&ID NO.	2000-PID-018		
Case	Inadvertent opening of PV-2608			Case	Outlets valve abnormally closed				
Equation	-			Equation	Total incoming steam and vapor plus that generated therein at relieving conditions				
Parameter		Unit	Value	Parameter		Unit	Value		
Rated Cv value(Provided by vendor)			6.50						
Venting required (Provided by vendor)		Nm3/h	6350.00						
Venting required(Provided by TOPSOE)		Nm3/h	9500.00						
Venting required (Ws)		kg/h	3973.88						
Remark: The venting required is decided by the structure of PV-2608. So TCC provided the venting condition to control valve vendor to calculated the flowrate passing through PV-2608 under venting condition. It is smaller than TOPSOE's value. So TOPSOE's value is adopted.				Venting required (Ws)		kg/h	39000.00		
				Remark: The rated capacity is 31200Nm3/h or 39000kg/h. The capacity will be confirmed by C2001 vendor.					

 TIANCHEN CORP. CHINA		PROJECT			MKP Methanol Project			Owner :  شركة الشرق الأوسط للتكنولوجيا Middle East Technology Park Co.	
		UNIT		General Technical	PHASE	As Built Drawing			
		DOC. Title			Calculation Sheet for Pressure Safety Valve				
		Owner NO.			MKP-11-AS-9000-IN-CAL-009				
		Contractor NO.			MKP-11-AS-9000-PS84-CAL-009				
Licensor:		TOPSOE NO.		N/A			Rev. : Z01 Page : 6 of 17		
Item NO.	PSV-3047, PSV-3048, PSV-3057	P&ID NO.	3000-PID-002	Item NO.	PSV-3143, PSV-3146, PSV-3149	P&ID NO.	3000-PID-005		
Case	The outlet valve closing, the maximum steam production of D3003 (Blocked outlet)			Case	Heat exchange (E3003 1/2/3) tube rupture				
Equation	$Ws=H/q$			Equation	$Ws=2.463*d^2*(\Delta P*\rho V/10)^{0.5}$				
Parameter		Unit	Value	Parameter		Unit	Value		
Venting required (Ws)		kg/h	281464	Tube inner diameter (d)		mm	22.1		
				Gas density (ρV)		kg/m3	35.1		
				Differential pressure of high pressure side and low side (ΔP)		bar	81.20		
				Venting required (Ws)		Nm3/h	45175		
				Venting required (Ws)		kg/h	20309		
Remark:				Remark:					
Item NO.	PSV-3163	P&ID NO.	3000-PID-006	Item NO.	PSV-3173, PSV-3174	P&ID NO.	3000-PID-006		
Case	Gas vessel with unwetted area, external fire (Open pool fire)			Case	Gas pipe, inlet valve FV-3169 unnormally open, high pressure gas flow into low pressure equipment				
Equation	$Ws=2.722*(Tw-T)^{1.25}*A*(M*P)^{0.5}/T^{1.1506}$			Equation	-				
Parameter		Unit	Value	Parameter		Unit	Value		
F'			295	Rated Cv value(Provided by vendor)			72.0		
Wall temperature (Tw)		°C	593	Venting required (Provided by vendor)		Nm3/h	107000		
Venting temperature (T)		°C	229	Venting required(Provided by TOPSOE)		Nm3/h	100000		
Exposed area (A)		m2	113	Venting required (Ws)		kg/h	44758		
molecular weight (M)		g/mol	11.60	Remark: The venting required is decided by the structure of FV-3169. So TCC provided the venting condition to control valve vendor to calculated the flowrate passing through FV-3169 under venting condition. It is a little bigger than TOPSOE's value. So vendor's value is adopted.					
Venting pressure (P)		bara	120.80						
Venting required (Ws)		kg/h	14269						
Remark:									
Item NO.	PSV-3196, PSV-3197, PSV-3206	P&ID NO.	3000-PID-007	Item NO.	RD-3001	P&ID NO.	3000-PID-021		
Case	Gas pipe, inlet valve LV-3161 A/B unnormally open, high pressure gas flow into low pressure			Case	Heat exchange (E3012) tube rupture				
Equation	Preliminarily calculated by Sinet			Equation	$Ws=2.463*d^2*(\Delta P*\rho V/10)^{0.5}$				
Parameter		Unit	Value	Parameter		Unit	Value		
Venting required (Ws)		Nm3/h	125000	Tube inner diameter (d)		mm	15.75		
				Gas density (ρV)		kg/m3	10.8		
				Differential pressure of high pressure side and low side (ΔP)		bar	19.80		
				Venting required (Ws)		Nm3/h	17961		
				Venting required (Ws)		kg/h	2825		



 TIANCHEN CORP. CHINA	PROJECT	MKP Methanol Project			Owner :  شرکت تکنولوژی پارک خاور میانه Middle East Technology Park Co.	
	UNIT	General Technical	PHASE	As Built Drawing		
	DOC. Title	Calculation Sheet for Pressure Safety Valve				
	Owner NO.	MKP-11-AS-9000-IN-CAL-009				
	Contractor NO.	MKP-11-AS-9000-PS84-CAL-009				
Licensors:	TOPSOE NO.	N/A			Rev. :Z01	Page : 7 of 17



Item NO.	RD-3002	P&ID NO.	3000-PID-021	Item NO.	RD-3003	P&ID NO.	3000-PID-021
Case	Heat exchange (E3013) tube rupture			Case	Heat exchange (E3014) tube rupture		
Equation	$Ws=2.463*d^2*(\Delta P*pV/10)^{0.5}$			Equation	$Ws=2.463*d^2*(\Delta P*pV/10)^{0.5}$		
Parameter		Unit	Value	Parameter		Unit	Value
Tube inner diameter (d)		mm	15.8	Tube inner diameter (d)		mm	15.8
Gas density (ρV)		kg/m3	35.4	Gas density (ρV)		kg/m3	20.9
Differential pressure of high pressure side and low side (ΔP)		bar	79.00	Differential pressure of high pressure side and low side (ΔP)		bar	42.50
Venting required (Ws)		Nm3/h	24426	Venting required (Ws)		Nm3/h	11652
Venting required (Ws)		kg/h	10217	Venting required (Ws)		kg/h	5795



Remark:


Item NO.		P&ID NO.		Item NO.		P&ID NO.	
Case				Case			
Equation				Equation			
Parameter		Unit	Value	Parameter		Unit	Value



Item NO.		P&ID NO.		Item NO.		P&ID NO.	
Case				Case			
Equation				Equation			
Parameter		Unit	Value	Parameter		Unit	Value



 TIANCHEN CORP. CHINA		PROJECT	MKP Methanol Project			Owner :  شركة التكنولوجيا الشرق الأوسط Middle East Technology Park Co.		
		UNIT	General Technical	PHASE	As Built Drawing			
		DOC. Title	Calculation Sheet for Pressure Safety Valve					
		Owner NO.	MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.	MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.	N/A			Rev. : Z01	Page: 8 of 17	
Item NO.	PSV-4001	P&ID NO.	4000-PID-001	Item NO.		P&ID NO.		
Case	Hydraulic expansion in the pipe that are blocked in while they are filled with liquid at near-ambient temperatures and are heated by direct solar radiation.			Case				
Equation	API 521 section 4.4.12.1 causes c)			Equation				
Parameter		Unit	Value	Parameter		Unit	Value	
Cubic expansion coefficient, α_v		1/°C	0.00145					
Radiation surface of pipe, S		m ²	215					
Solar radiation, Φ (Based on solar constant, 1376W)		W	296309					
Relative density referred to water, d			0.766					
Specific heat capacity, c		J/kg K	2695					
Venting required (Ws)		kg/h	567					
Remark:								
Item NO.	PSV-1015	P&ID NO.	1000-PID-002	Item NO.	PSV-1031	P&ID NO.	1000-PID-003	
Case				Case				
Equation				Equation				
Parameter		Unit	Value	Parameter		Unit	Value	
Remark:				Remark:				
Item NO.		P&ID NO.		Item NO.		P&ID NO.		
Case				Case				
Equation				Equation				
Parameter		Unit	Value	Parameter		Unit	Value	
Remark:				Remark:				

 TIANCHEN CORP. CHINA		PROJECT			MKP Methanol Project			Owner :  شركت كيمياء باين خاور ميانه Middle East Technology Para Co.			
		UNIT		General Technical	PHASE	As Built Drawing					
		DOC. Title								Calculation Sheet for Pressure Safety Valve	
		Owner NO.								MKP-11-AS-9000-IN-CAL-009	
		Contractor NO.								MKP-11-AS-9000-PS84-CAL-009	
Licensor:		TOPSOE NO.			N/A			Rev. :Z01	Page: 9 of 17		
Item NO.	PSV-5058,5059,5060,5061	P&ID NO.	5000-PID-002		Item NO.	PSV-5058, 5059, 5060, 5061	P&ID NO.	5000-PID-002			
Case	Reflux Failure				Case	Heat exchange (E5024 1/2) tube rupture					
Equation	Equal to the amount into condenser				Equation	$Ws=2.463*d^2*(\Delta P*pV/10)^{0.5}$					
					Parameter			Unit	Value		
Venting required (Ws)	1. The overall relieve amount of the T5001 overhead is equal to the amount into condenser AE5004 which is 112490kg/h, and the MW is 29.92, thus the overall amount is around 84217 Nm3/h. 2. This overall amount is shared by 3 PSVs which are PSV-5058,5058 and 5060. And one PSV-5061 is a spare one.				Tube inner diameter (d)		mm	28.45			
					Gas density (ρV)		kg/m3	9.50			
					Differential pressure of high pressure side and low side (ΔP)		bar	20.74			
					Venting required (Ws) in E5024 1/2 shell side		kg/h	8847			
					Venting required (Ws) in E5024 1/2 shell side		m3/h	4795			
					Venting required (Ws) in T5001 top		kg/h	21641			
Remark:					Remark: E5024 1/2 tube side relief density is 1.845 kg/m3 which is using to calculate E5024 1/2 shell side real volumetric						
Item NO.	PSV-5058,5059,5060,5061	P&ID NO.	5000-PID-002		Item NO.	PSV-5058, 5059, 5060, 5061	P&ID NO.	5000-PID-002			
Case	Heat exchange (E5001) tube rupture				Case	Non-explosive liquified gas with insulation, fire case					
Equation	$Ws=2.463*d^2*(\Delta P*pV/10)^{0.5}$				Equation	$Ws=255000*Ar^{0.82}/q*\lambda*(904-t)/66570/\delta$					
Parameter			Unit	Value	Parameter			Unit	Value		
Tube inner diameter (d)			mm	27.53	Heat conductivity of insulation layer (λ)			W/m•K	0.25		
Gas density (ρV)			kg/m3	3.37	Heated area (Ar)			m2	144.75		
Differential pressure of high pressure side and low side (ΔP)			bar	2.44	Letent heat @venting condition (q)			kJ/kg	1219.23		
Venting required (Ws) in E5001 shell side			kg/h	1693	Insulation thickness (δ)			m	0.06		
Venting required (Ws) in E5001 shell side			m3/h	674	Saturated Temperature @venting pressure (t)			°C	122.38		
Venting required (Ws) in T5001 top			kg/h	3044	Venting required (Ws)			kg/h	604.88		
Remark: E5001 tube side relief density is 2.51kg/m3 which is using to calculate E5001 shell side real volumetric rate. E5001 tube rupture case only consider steam pressure accidently increased to the none					Remark: The wetted surface which is heated area in equation included: The high-high level in column part , the overall shell side liquid level in reboilers(E5024 1/2) flow to column bottom part, and all column trays fluid flow to column bottom part.						
Item NO.	PSV-5085	P&ID NO.	5000-PID-003		Item NO.	PSV-5108	P&ID NO.	5000-PID-004			
Case	Hydraulic Expansion				Case	Hydraulic Expansion					
Equation	$m=q*(d*1000)*3600$, where $q=\alpha_v*\Phi/(1000*d*c)$				Equation	$m=q*(d*1000)*3600$, where $q=\alpha_v*\Phi/(1000*d*c)$					
Parameter			Unit	Value	Parameter			Unit	Value		
Cubic expansion coefficient (α _v)			1/°C	0.00044	Cubic expansion coefficient (α _v)			1/°C	0.00044		
Total heat transfer rate (Φ)			MW	3.5100	Total heat transfer rate (Φ)			MW	0.3000		
Relative density to water (d)			N/A	0.989	Relative density to water (d)			N/A	0.989		
Specific heat capacity of trapped fluid (c)			kJ/kg•K	4.18	Specific heat capacity of trapped fluid (c)			kJ/kg•K	4.18		
Expansion volume amount (q)			m ³ /s	0.00037	Expansion volume amount (q)			m ³ /s	0.00003		
Expansion mass amount (m)			kg/h	1329.79	Expansion mass amount (m)			kg/h	113.68		
Remark: Total heat transfer rate use heat exchanger data sheet duty. Relative density and specific heat capacity is based on fluid on hot side temperature condition.					Remark: Total heat transfer rate use heat exchanger data sheet duty. Relative density and specific heat capacity is based on fluid on hot side temperature condition.						

 TIANCHEN CORP. CHINA		PROJECT			MKP Methanol Project			Owner :	
		UNIT		General Technical	PHASE	As Built Drawing		 شرکت کیمیاوی پارس خاور میانه Parsa Chemicals Co.	
		DOC. Title			Calculation Sheet for Pressure Safety Valve				
		Owner NO.			MKP-11-AS-9000-IN-CAL-009				
		Contractor NO.			MKP-11-AS-9000-PS84-CAL-009				
Licensor:		TOPSOE NO.		N/A			Rev. : Z01		Page: 10 of 17
Item NO.	PSV-5073	P&ID NO.	5000-PID-003	Item NO.	PSV-5179,5180	P&ID NO.	5000-PID-006		
Case	Non-explosive liquified gas with insulation, fire case			Case	Reflux Failure				
Equation	$W_s=255000 \cdot Ar^{0.82} \cdot q^{\lambda} \cdot (904-t) / 66570 \cdot \delta$			Equation	Equal to the amount into condenser				
Parameter		Unit	Value	Parameter		Unit	Value		
Heat conductivity of insulation layer (λ)		W/m·K	0.25	Venting required (Ws)	1. The overall relieve amount of the T5002 overhead is equal to the amount into condenser AE5005 which is 418559kg/h, and the MW is 29.08, thus the overall amount is around 332411 Nm3/h. 2. TCC has consulted Topsoe about why reflux failure condition is not used for PSV sizing, and Topsoe reply is: <div style="border: 1px solid black; padding: 5px; background-color: #e0ffe0; margin-top: 10px;"> Reflux failure was also considered but due to higher pressure no additional gas phase needs to be relieved. </div>				
Heated area (Ar)		m2	12.13						
Letent heat @venting condition (q)		kJ/kg	2023.42						
Insulation thickness (δ)		m	0.06						
Saturated Temperature @venting pressure (t)		°C	190.00						
Venting required (Ws)		kg/h	43.59						
Remark:				Remark: Topsoe reply please check 30% model review Topsoe reply document.					
Item NO.	PSV-5179,5180	P&ID NO.	5000-PID-006	Item NO.	PSV-5179,5180	P&ID NO.	5000-PID-006		
Case	Heat exchange (E5002 1/2/3/4) tube rupture			Case	Non-explosive liquified gas with insulation, fire case				
Equation	$W_s=2.463 \cdot d^2 \cdot (\Delta P \cdot \rho V / 10)^{0.5}$			Equation	$W_s=255000 \cdot Ar^{0.82} \cdot q^{\lambda} \cdot (904-t) / 66570 \cdot \delta$				
Parameter		Unit	Value	Parameter		Unit	Value		
Tube inner diameter (d)		mm	21.18	Heat conductivity of insulation layer (λ)		W/m·K	0.25		
Gas density (ρV)		kg/m3	7.35	Heated area (Ar)		m2	600.28		
Differential pressure of high pressure side and low side (ΔP)		bar	1.71	Letent heat @venting condition (q)		kJ/kg	1204.13		
Venting required (Ws) in E5002 shell side		kg/h	1239	Insulation thickness (δ)		m	0.06		
Venting required (Ws) in E5002 shell side		m3/h	226	Saturated Temperature @venting pressure (t)		°C	121.00		
Venting required (Ws) in T5002 top		kg/h	1086	Venting required (Ws)		kg/h	1969.65		
Remark: E5002 tube side relief density is 5.493kg/m3 which is using to calculate E5002 shell side real volumetric rate. E5002 tube rupture case only consider steam pressure accidently increased near to the T5003 PSV relief pressure.				Remark: Normal calculation is, the wetted surface which is heated area in equation included: The high-high level in column part , the overall shell side liquid level in reboilers(E5002 1/2/3/4) flow to column bottom part, and all column trays fluid flow to column bottom part. However, this liquid level is higher than 7.6m, thus use 7.6m to calculate wetted surface directly. The result relieve rate is around 578 Nm3/h.					
Item NO.	PSV-5220	P&ID NO.	5000-PID-008	Item NO.	PSV-5444	P&ID NO.	5000-PID-009		
Case	Hydraulic Expansion			Case	Hydraulic Expansion				
Equation	$m=q \cdot (d \cdot 1000) \cdot 3600$, where $q=\alpha_v \cdot \Phi / (1000 \cdot d \cdot c)$			Equation	$m=q \cdot (d \cdot 1000) \cdot 3600$, where $q=\alpha_v \cdot \Phi / (1000 \cdot d \cdot c)$				
Parameter		Unit	Value	Parameter		Unit	Value		
Cubic expansion coefficient (α_v)		1/°C	0.00044	Cubic expansion coefficient (α_v)		1/°C	0.00044		
Total heat transfer rate (Φ)		MW	1.6000	Total heat transfer rate (Φ)		MW	0.1600		
Relative density to water (d)		N/A	0.956	Relative density to water (d)		N/A	0.989		
Specific heat capacity of trapped fluid (c)		kJ/kg·K	4.18	Specific heat capacity of trapped fluid (c)		kJ/kg·K	4.18		
Expansion volume amount (q)		m³/s	0.00018	Expansion volume amount (q)		m³/s	0.00002		
Expansion mass amount (m)		kg/h	606.32	Expansion mass amount (m)		kg/h	60.63		
Remark: Total heat transfer rate use heat exchanger data sheet duty. Relative density and specific heat capacity is based on fluid on hot side temperature condition.				Remark: Total heat transfer rate use heat exchanger data sheet duty. Relative density and specific heat capacity is based on fluid on hot side temperature condition.					

 TIANCHEN CORP. CHINA		PROJECT		MKP Methanol Project			Owner :		
		UNIT		General Technical	PHASE	As Built Drawing			
		DOC. Title		Calculation Sheet for Pressure Safety Valve					
		Owner NO.		MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.		MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.		N/A			Rev. :Z01	Page: 11 of 17	
Item NO.	PSV-5308	P&ID NO.	5000-PID-011	Item NO.	PSV-5250,5251,5261	P&ID NO.	5000-PID-012		
Case	Hydraulic Expansion			Case	Heat exchange (E5003 1/2) tube rupture				
Equation	$m=q*(d*1000)*3600$, where $q=\alpha_v*\Phi/(1000*d*c)$			Equation	$Ws=2.463*d^2*(\Delta P*\rho V/10)^{0.5}$				
Parameter		Unit	Value	Parameter		Unit	Value		
Cubic expansion coefficient (α_v)		1/°C	0.00044	Tube inner diameter (d)		mm	14.83		
Total heat transfer rate (Φ)		MW	15.7000	Gas density (ρV)		kg/m3	3.99		
Relative density to water (d)		N/A	0.989	Differential pressure of high pressure side and low side (ΔP)		bar	0.50		
Specific heat capacity of trapped fluid (c)		kJ/kg*K	4.18	Venting required (Ws) in E5003 1/2 shell side		kg/h	242		
Expansion volume amount (q)		m ³ /s	0.00167	Venting required (Ws) in E5003 1/2 shell side		m3/h	65		
Expansion mass amount (m)		kg/h	5949.47	Venting required (Ws) in T5003 top		kg/h	389		
Remark: Total heat transfer rate use heat exchanger data sheet duty. Relative density and specific heat capacity is based on fluid on hot side temperature condition.				Remark: E5003 tube side relief density is 3.738kg/m3 which is using to calculate E5003 shell side real volumetric rate.					
Item NO.	PSV-5250,5251,5261	P&ID NO.	5000-PID-010	Item NO.	PSV-5250,5251,5261	P&ID NO.	5000-PID-010		
Case	Heat exchange (E5023) tube rupture			Case	Reflux Failure				
Equation	$Ws=2.463*d^2*(\Delta P*\rho V/10)^{0.5}$			Equation	Equal to the amount into condenser				
Parameter		Unit	Value	Parameter		Unit	Value		
Tube inner diameter (d)		mm	22.10	Venting required (Ws)	<p>1. The overall relieve amount of the T5003 overhead is equal to the amount into condenser E5002 1/2/3/4 which is 440751kg/h, and the MW is 32.04, thus the overall amount is around 308333 Nm3/h. However, normally we think maybe just one reboiler of E5002 1/2/3/4 will fail to cause reflux failure, thus the amount should be 77084 Nm3/h.</p> <p>2. This amount is shared by 2 PSVs which are PSV-5250 and 5251. And one PSV-5161 is a spare one.</p>				
Gas density (ρV)		kg/m3	9.74						
Differential pressure of high pressure side and low side (ΔP)		bar	18.84						
Venting required (Ws) in E5023 shell side		kg/h	5153						
Venting required (Ws) in E5023 shell side		m3/h	1768						
Venting required (Ws) in T5003 top		kg/h	10617						
Remark: E5023 tube side relief density is 2.914kg/m3 which is using to calculate E5023 shell side real volumetric rate.				Remark:					
Item NO.	PSV-5250,5251,5261	P&ID NO.	5000-PID-010	Item NO.	PSV-5339	P&ID NO.	5000-PID-012		
Case	Non-explosive liquified gas with insulation, fire case			Case	Hydraulic Expansion				
Equation	$Ws=255000*Ar^{0.82}/q*\lambda*(904-t)/66570/\delta$			Equation	$m=q*(d*1000)*3600$, where $q=\alpha_v*\Phi/(1000*d*c)$				
Parameter		Unit	Value	Parameter		Unit	Value		
Heat conductivity of insulation layer (λ)		W/m*K	0.25	Cubic expansion coefficient (α_v)		1/°C	0.00044		
Heated area (Ar)		m2	454.28	Total heat transfer rate (Φ)		MW	3.6000		
Letent heat @venting condition (q)		kJ/kg	1327.02	Relative density to water (d)		N/A	0.989		
Insulation thickness (δ)		m	0.06	Specific heat capacity of trapped fluid (c)		kJ/kg*K	4.18		
Saturated Temperature @venting pressure (t)		°C	147.38	Expansion volume amount (q)		m ³ /s	0.00038		
Venting required (Ws)		kg/h	1374.22	Expansion mass amount (m)		kg/h	1364.21		
Remark: Normal calculation is, the wetted surface which is heated area in equation included: The high-high level in column part , the overall shell side liquid level in reboilers(E5003 1/2&E5023) flow to column bottom part, and all column trays fluid flow to column bottom part. However, this liquid level is higher than 7.6m, thus use 7.6m to calculate wetted surface directly. The result relieve rate is around 460 Nm3/h.				Remark: Total heat transfer rate use heat exchanger data sheet duty. Relative density and specific heat capacity is based on fluid on hot side temperature condition.					

 TIANCHEN CORP. CHINA		PROJECT	MKP Methanol Project			Owner :  شرکت کیمیاها و پارس خاور میانه Methanex Case Management Persa Co.		
		UNIT	General Technical	PHASE	As Built Drawing			
		DOC. Title	Calculation Sheet for Pressure Safety Valve					
		Owner NO.	MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.	MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.	N/A			Rev. :Z01	Page: 12 of 17	
Item NO.	PSV-5370	P&ID NO.	5000-PID-013	Item NO.	PSV-5384,5386	P&ID NO.	5000-PID-014	
Case	Hydraulic Expansion			Case	Non-explosive liquified gas drum without insulation, fire case			
Equation	$m=q*(d*1000)*3600$, where $q=\alpha_v*\Phi/(1000*d*c)$			Equation	$V=Ws/MW*22.414$, where $Ws=255000*F*Ar^{0.82}/q$			
Parameter		Unit	Value	Parameter		Unit	Value	
Cubic expansion coefficient (α_v)		1/°C	0.00044	Environment factor (F)		1	1.00	
Total heat transfer rate (Φ)		MW	0.1600	Heated area (Ar)		m ²	72.39	
Relative density to water (d)		N/A	0.989	Letent heat @venting condition (q)		kJ/kg	832.60	
Specific heat capacity of trapped fluid (c)		kJ/kg*K	4.18	Venting required (Ws)		kg/h	10257.08	
Expansion volume amount (q)		m ³ /s	0.00002	Molar Weight(MW)		kg/kmol	32.00	
Expansion mass amount (m)		kg/h	60.63	Venting required (V)		Nm ³ /h	7184.44	
Remark: Total heat transfer rate use heat exchanger data sheet duty. Relative density and specific heat capacity is based on fluid on hot side temperature condition.				Remark: Topsoe has updated X5001 data sheet thus the length of equipment is longer which caused the relieve capacity is higher than PDP PSV data sheet.				
Item NO.		P&ID NO.		Item NO.		P&ID NO.		
Case				Case				
Equation				Equation				
Remark:				Remark:				
Item NO.		P&ID NO.		Item NO.		P&ID NO.		
Case				Case				
Equation				Equation				
Remark:				Remark:				

 TIANCHEN CORP. CHINA	PROJECT	MKP Methanol Project			Owner :  شرکت تکنولوژی پارسیان خاورمیانه Middle East Technology Para Co.
	UNIT	General Technical	PHASE	As Built Drawing	
	DOC. Title	Calculation Sheet for Pressure Safety Valve			
	Owner NO.	MKP-11-AS-9000-IN-CAL-009			
	Contractor NO.	MKP-11-AS-9000-PS84-CAL-009			
Licensors:	TOPSOE NO.	N/A			Rev. : Z01 Page: 13 of 17

Item NO.	PSV-6021 PSV-6022	P&ID NO.	6000-PID-002
Case 1	Inadvertent opening of FV-6031		Case 2 Inadvertent opening of FV-5367
Equation			Equation
Parameter	Unit	Value	Parameter Unit Value
At relieving conditions there is almost no flow, so minimum size PSV(1D2) is chosen		At relieving conditions there is almost no flow, so minimum size PSV(1D2) is chosen	


Remark: PSV-6021 is spare PSV.



Item NO.	PSV-6027	P&ID NO.	6000-PID-002	Item NO.	PSV-6053	P&ID NO.	6000-PID-003	
Case	Fire- wetted surface			Case	Fire- wetted surface			
Equation	$Ws=255000 \cdot Ar^{0.82}/q$			Equation	$Ws=255000 \cdot Ar^{0.82}/q$			
Parameter	Unit	Value	Parameter Unit Value	Parameter	Unit	Value	Parameter Unit Value	
Heated area (Ar)	m2	19.58	Heated area (Ar)	m2	60.05	Letent heat @venting condition (q)	kJ/kg	1500.83
Letent heat @venting condition (q)	kJ/kg	1601.87	Letent heat @venting condition (q)	kJ/kg	1500.83	Venting required (Ws)	kg/h	4881.91
Venting required (Ws)	kg/h	1824.73	Venting required (Ws)	kg/h	4881.91			


Remark: It is smaller than TOPSOE's value. So TOPSOE's value(2560 kg/h) is adopted.



Item NO.	PSV-6085	P&ID NO.	6000-PID-004	Item NO.	P&ID NO.
Case	Hydraulic expansion			Case	
Equation				Equation	
Parameter	Unit	Value	Parameter Unit Value	Parameter	Unit Value
For liquid hydraulic expansion case, at relieving conditions the relieving flow rate is very very small, so minimum size PSV(3/4 D 1) is chosen.					

Remark:

 TIANCHEN CORP. CHINA		PROJECT		MKP Methanol Project			Owner :		
		UNIT		General Technical	PHASE	As Built Drawing			
		DOC. Title		Calculation Sheet for Pressure Safety Valve					
		Owner NO.		MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.		MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.		N/A			Rev. :Z01	Page: 14 of 17	
Item NO.	PSV-7010 PSV-7011 PSV-7012	P&ID NO.	7000-PID-006	Item NO.	PSV-7023 PSV-7024	P&ID NO.	7000-PID-007		
Case	Gas pipe, inlet valve unnormally open, high pressure gas flow into low pressure equipment			Case	Gas pipe, inlet valve unnormally open, high pressure gas flow into low pressure equipment				
Equation	Ws=Ws(Maximum Upstream Steam)+Ws(Maximum Upstream BFW)-Ws(Normal Downstream Steam)			Equation	Ws=Ws(Maximum Upstream Steam)+Ws(Maximum Upstream BFW)-Ws(Normal Downstream Steam)				
Parameter		Unit	Value	Parameter		Unit	Value		
Maximum Upstream Steam Flow		kg/h	388258	Maximum Upstream Steam Flow		kg/h	282156		
Maximum Upstream BFW Flow(TV7002)		kg/h	38015	Maximum Upstream BFW Flow(TV7026)		kg/h	1182		
Maximum Upstream BFW Flow(TV7003)		kg/h	38015	Maximum Upstream BFW Flow(TV7027)		kg/h	1182		
Maximum Upstream BFW Flow(TV7004)		kg/h	3801	Normal Downstream Steam		kg/h	78254		
Normal Downstream Steam		kg/h	147347						
Venting required (Ws)		kg/h	320742	Venting required (Ws)		kg/h	206266		
Remark: (1) The Maximum Upstream Steam Flow is in EOR-LEAN case and the Maximum Upstream BFW Flow is decided by TV7002/03/04 provided by vendor, Normal Downstream Steam is decided by FT7001AB FT2001 FT2002 FT0500-1/2 (2) 320742 is split by PSV-7010/7011 (3) The capacity of PSV provided by topsoe is 254500kg/h and the capacity will be chosen as 254500kg/h				Remark: (1) The Maximum Upstream Steam Flow is decided by PV7025 A/B provided by vendor and the Maximum Upstream BFW Flow is decided by TV7026/27 provided by vendor, Normal Downstream Steam is for export. (2) The capacity of PSV provided by topsoe is 267300kg/h and the capacity will be chosen as 267300kg/h					
Item NO.	PSV-7036 PSV-7037	P&ID NO.	7000-PID-008	Item NO.	PSV-7057 PSV-7058 PSV-7059 PSV-7060 PSV-7061	P&ID NO.	7000-PID-009		
Case	Gas pipe, inlet valve unnormally open, high pressure gas flow into low pressure equipment			Case	Gas pipe, inlet valve unnormally open, high pressure gas flow into low pressure equipment				
Equation				Equation	Ws=Ws(Maximum Upstream Steam)+Ws(Maximum Upstream BFW)-Ws(Normal Downstream Steam)				
Parameter		Unit	Value	Parameter		Unit	Value		
				Maximum Upstream Steam Flow		kg/h	240911		
				Maximum Upstream BFW Flow(TV7052)		kg/h	17377		
				Maximum Upstream BFW Flow(TV7053)		kg/h	17377		
Venting required (Ws)		kg/h	0	Venting required (Ws)		kg/h	275665		
Remark: (1) No flow at relieving condition so min. size PSV choosen				Remark: (1) The Maximum Upstream Steam Flow is in EOR-RICH case and the Maximum Upstream BFW Flow is decided by TV7052/53 provided by vendor (2) 275665 is split by PSV-7057/7058/7059/7060 (3) The capacity of PSV provided by topsoe is 320250kg/h and the capacity will be chosen as 320250kg/h					

 TIANCHEN CORP. CHINA		PROJECT	MKP Methanol Project			Owner :		
		UNIT	General Technical	PHASE	As Built Drawing			
		DOC. Title	Calculation Sheet for Pressure Safety Valve					
		Owner NO.	MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.	MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.	N/A			Rev. :Z01	Page: 15 of 17	
Item NO.	PSV-7095 PSV-7096 PSV-7097	P&ID NO.	7000-PID-012	Item NO.	PSV-7132 PSV-7134 PSV-7136 PSV-7137	P&ID NO.	7000-PID-013	
Case	Valve unnormally closed			Case	Valve unnormally closed			
Rated Cv value(Provided by vendor)			1050	Equation				Ws=Ws(Maximum Upstream Steam)
Venting required (Provided by vendor)		Nm3/h	51000	Parameter		Unit	Value	
Venting required(Provided by TOPSOE)		Nm3/h	64000	Maximum Upstream Steam Flow		kg/h	28130	
Venting required (Ws)		kg/h	32000	Venting required (Ws)		kg/h	28130	
Remark: (1) The venting required is decided by the structure of PV-7094. So TCC provided the venting condition to control valve vendor to calculated the flowrate passing through PV-7094 under venting condition. (2) The capacity of PSV provided by topsoe is 64000kg/h and the capacity will be chosen as 64000kg/h (3) 64000 is split by PSV-7095/7096,7097 is spare				Remark: (1) The capacity of PSV will be confirmed by FT7001A/B vendor				
Item NO.	PSV-7130 PSV-7131 PSV-7135	P&ID NO.	7000-PID-013	Item NO.	PSV-7142 PSV-7143	P&ID NO.	7000-PID-014	
Case 12				Case 12	Control Vavle failure			
Equation			Ws=Wsmax-Wsnor	Equation			Ws=Wsmax-Wsnor	
Parameter		Unit	Value	Parameter		Unit	Value	
				Wsmax=		kg/h	279000	
				Wsnor=		kg/h	24000.00	
Venting required (Ws)		kg/h	28200	Venting required (Ws)		kg/h	255000	
Remark: (1) The capacity of PSV will be chosen as 10% of P 7001.				Remark: (1) The capacity of PSV provided by topsoe is 255000kg/h and the capacity will be chosen as 255000kg/h				

 TIANCHEN CORP. CHINA		PROJECT		MKP Methanol Project			Owner :		
		UNIT		General Technical	PHASE	As Built Drawing			
		DOC. Title		Calculation Sheet for Pressure Safety Valve					
		Owner NO.		MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.		MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.		N/A			Rev. : Z01	Page: 16 of 17	
Item NO.	PSV-7253 PSV-7254	P&ID NO.	7000-PID-026	Item NO.		P&ID NO.			
Case	Valve unnormally closed / Blocked outlet			Case					
Equation	Ws=H/q			Equation					
Parameter		Unit	Value	Parameter		Unit	Value		
Heat input (H)		kJ/h	5132755.00						
Letent heat @venting condition (q)		kJ/kg	2038.00						
Venting required (Ws)		kg/h	2518.53						
Remark: According to TOPSOE, the vapor mass rate is 3700 kg/h.				Remark:					
Item NO.	PSV-7256	P&ID NO.	7000-PID-026	Item NO.		P&ID NO.			
Case	Hydraulic expansion			Case					
Equation				Equation					
				Parameter		Unit	Value		
Remark: According to TOPSOE, the liquid mass rate is 190 kg/h. The calculated relief orifice area is 2 mm ² , while the choosed orifice area is the minimum size of 71 mm ²				Remark:					
Item NO.		P&ID NO.		Item NO.		P&ID NO.			
Case				Case					
Equation				Equation					
Parameter		Unit	Value	Parameter		Unit	Value		
Remark:				Remark:					

 TIANCHEN CORP. CHINA		PROJECT		MKP Methanol Project			Owner :  شرکت کیمیاوی پارس خاور نیژاد Parsa Chemical Engineering Parsa Co.		
		UNIT		General Technical	PHASE	As Built Drawing			
		DOC. Title		Calculation Sheet for Pressure Safety Valve					
		Owner NO.		MKP-11-AS-9000-IN-CAL-009					
		Contractor NO.		MKP-11-AS-9000-PS84-CAL-009					
Licensor:		TOPSOE NO.		N/A			Rev. :Z01	Page: 17 of 17	
Item NO.	PSV-0532A PSV-0532B	P&ID NO.	0500-PID-002 0500-PID-003	Item NO.		P&ID NO.			
Case	Valve unnormally closed			Case					
Equation	Ws=Ws(Maximum Upstream Steam)			Equation					
Parameter		Unit	Value	Parameter		Unit	Value		
Maximum Upstream Steam Flow		kg/h	16210						
Venting required (Ws)		kg/h	16210						
Remark:				Remark:					
Item NO.		P&ID NO.		Item NO.		P&ID NO.			
Case				Case					
Equation				Equation					
Parameter		Unit	Value	Parameter		Unit	Value		
Remark:				Remark:					
Item NO.		P&ID NO.		Item NO.		P&ID NO.			
Case				Case					
Equation				Equation					
Parameter		Unit	Value	Parameter		Unit	Value		
Remark:				Remark:					