



# Certificate / Certificat Zertifikat / 合格証

ASC 1301001 C005

*exida* hereby confirms that the:

## Series 551 and 553 Pilot Operated Inline Spool Valves

**ASCO Numatics  
Lucé, France**

Have been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A, Route 2<sub>H</sub> Device**

**PFD<sub>AVG</sub> and Architecture Constraints  
must be verified for each application**

### Safety Function:

The Valve will move to the designed safe position when de-energized within the specified safety time.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer  
may use the mark:




Revision 2.0 June 30, 2016  
Surveillance Audit Due  
April 1, 2019



ANSI Accredited Program  
PRODUCT CERTIFICATION  
#1004



  
Evaluating Assessor

  
Certifying Assessor

# Certificate / Certificat / Zertifikat / 合格証

ASC 1301001 C005

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A, Route 2<sub>H</sub> Device**

**PFD<sub>AVG</sub> and Architecture Constraints must be verified for each application**

### Systematic Capability :

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with these products must not be used at a SIL level higher than stated.

### Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2<sub>H</sub>.

### IEC 61508 Failure Rates in FIT<sup>1</sup> (LP Coil options)

Failure Category	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
3/2 Single	0	178	0	347
3/2 Single NAMUR	0	273	0	371
3/2 Single, w/NF Operator	0	292	0	333
3/2 Single NAMUR, w/NF Operator	0	389	0	358
3/2 Single w/PVST <sup>2</sup>	0	178	343	3
3/2 Single NAMUR w/PVST	0	273	367	4
3/2 Single, w/NF Operator w/PVST	0	292	330	3
3/2 Single NAMUR, w/NF Operator w/PVST	0	389	354	4
3/2 Redundant	0	205	0	387
3/2 Redundant w/PVST	0	205	383	4
5/2 Single	0	278	0	357
5/2 Single NAMUR	0	275	0	389
5/2 Single, w/NF Operator	0	392	0	343
5/2 Single NAMUR w/NF Operator	0	388	0	376
5/2 Single w/PVST	0	278	353	4
5/2 Single NAMUR w/PVST	0	275	385	4
5/2 Single, w/NF Operator w/PVST	0	392	340	3
5/2 Single NAMUR w/NF Operator w/PVST	0	388	372	4
5/2 Redundant	0	265	0	397
5/2 Redundant w/PVST	0	265	393	4

<sup>1</sup> FIT = 1 failure / 10<sup>9</sup> hours

<sup>2</sup> PVST = Partial Valve Stroke Test of a final element Device

### Applications

Series 551 & 553 Spool Valves	De-energize To Trip, Normally Closed Valves
-------------------------------	---

### SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** ASC Q1301001 R003 V1R2

**Safety Manual:** V9629R4 (or later)

Series 551 and 553  
Pilot Operated Spool  
Valves



64 N Main St  
Sellersville, PA 18960

T-061, V1R9