



Tower Design



Tower Data Input

Maximum Load in different Zones

Vapor Load in Zone 1

Performance point	Design
Temperature	102
Gas flow	440752
Gas density	4,07
Gas viscosity	0,012
Gas molecular weight	32,04

Vapor Load in Zone 1

Performance point	Design
Temperature	109
Gas flow	422422
Gas density	4,23
Gas viscosity	0,013
Gas molecular weight	30,52

Vapor Load in Zone 1

Performance point	Design
Temperature	116
Gas flow	402338
Gas density	4,3
Gas viscosity	0,013
Gas molecular weight	29,70

Liquid Load in Zone 1

Performance point	Design
Temperature	104
Liquid flow	359831
Liquid density	709
Liquid viscosity	0,225
Liquid surface tension	15

Liquid Load in Zone 1

Performance point	Design
Temperature	111
Liquid flow	460397
Liquid density	727
Liquid viscosity	0,221
Liquid surface tension	17

Liquid Load in Zone 1

Performance point	Design
Temperature	116
Liquid flow	406821
Liquid density	751
Liquid viscosity	0,221
Liquid surface tension	20



Tower ID Sizing

1. Use C-factor method or Koch-Glitsch diagram for first estimation of Diameter

$$g_m = C \sqrt{\frac{\rho_l - \rho_v}{\rho_v}}$$

- V_m = maximum acceptable vapor velocity in the space below one tray, (m/h),
- ρ_l = liquid density at operating temp. and pressure of the tray (kg/m³),
- ρ_v = vapor density at operating temp. and pressure of the tray (kg/m³),
- C = Souders-Brown factor given by figure 12, in m/h versus tray spacing in cm and liquid surface tension in N/m,

Service	Tray spacing		
	18 in (46 cm)	24 in (61 cm)	30 in (76 cm)
Absorbers glycol	-	153	168
Absorbers amine	-	107	120
Fractionators	134	165	183




$$D = \sqrt{\frac{Q}{(0.7854)g_m}}$$

- D = inside diameter of the column in meters,
- Q = vapor flowrate at actual tray conditions (m³/h),
- This method was originally developed for bubble cap trays and gives a rough diameter value, especially for other types of trays.
- Koch-Glitsch diagram

$$V_{\text{load}} = Q_v \sqrt{\frac{\rho_v}{\rho_l - \rho_v}}$$

- Q_v = vapour flow rate (m³/s),
 ρ_l = liquid density at operating temperature and pressure of the tray (kg/m³),
 ρ_v = vapour density at operating temperature and pressure of the tray (kg/m³),
 V_{load} = vapour load (m³/s) used in figure 13 (Glitsch nomograph for Ballast type valve tray).





Results for C-factor Method for T-5003

Tray Spacing	C	V-max	Diameter	V-Load	V-Liquid
600 mm	165	2156.8	7.67 m	2.12	10.54

2. Determine Flow Path Length

$$(FPL) = 0.75 \frac{(DT)}{(NP)}$$

(FPL) = flow path length (m),
(DT) = internal diameter of the column (m),
(NP) = number of pass


3. Determination of Vapor Capacity Factor (CAF)

Figure 14 allows to determine the vapour capacity factor (CAFo) in meter per second, versus vapor density and tray spacing for nonfoaming fluids. For foaming fluids this vapour capacity factor must be corrected by the system factor value indicated in the table of figure 15.



$$(\text{CAF}) = (\text{SF}) (\text{CAF}_o)$$

(CAF) = vapour capacity factor (m/s),
(SF) = system factor (dimensionless),
(CAF_o) = vapour capacity factor for non foaming fluids (m/s)





Systems with foaming tendencies are taken into account by using a factor to derate the capacity of a given tray design. A list of the more common foaming systems and their recommended factor is below.

System	Factor
Absorbers (over -18°C)	0.85
Absorbers (below -18°C)	0.80
Amine Contactor	0.80
Vacuum Towers	0.85
Amine Stills (Amine Regenerator)	0.85
H ₂ S Stripper	0.85
Furfural Fractionator	0.85
Top Section of Absorbing Type Demethanizer/ Deethanizer	0.85
Glycol Contactors	0.50
Glycol Stills	0.65
CO ₂ Absorber	0.80
CO ₂ Regenerator	0.85
Caustic Wash	0.65
Caustic Regenerator, Foul Water, Sour Water Stripper	0.60
Alcohol Synthesis Absorber	0.35
Hot Carbonate Contactor	0.85
Hot Carbonate Regenerator	0.90
Oil Reclaimer	0.70

The capacity of a given tray design used in *high pressure fractionation service* with a vapor density of 28.8 kg/m³ and higher should be derated by a system factor calculated by the following formula:

$$\text{System factor} = \frac{2.93}{(\rho_v)^{0.32}}$$



Results for FPL and CAF

$$\text{FPL} = 0.75 * 7.67 / 2 = 2.87$$

Note that 2 pass has been selected

$$\text{CAF} = \text{CAF0} * \text{SF} = 0.14 * 1 = 0.14$$

Note that CAF0 is determined by Diagram on last page

3. Determination of the Downcomer Velocity (VD_{dsg})

The procedure used in this method for establishing downcomer area is based on a "design " velocity in meter per hour given by figure 16 for non-foaming fluid or by equation as follows:

$$(VD_{dsg}) = (0,909) \sqrt{(TS)} \sqrt{(\rho_l - \rho_v)} (SF) = (SF) (VD_{dsg}^*)$$

- (VD_{dsg}) = downcomer velocity (m/h),
- (TS) = tray spacing (mm),
- ρ_l = liquid density at operating temperature and operating pressure of the tray (kg/m³),
- ρ_v = vapour density at operating temperature and operating pressure of the tray (kg/m³),
- (SF) = system factor,
- (VD_{dsg}^{*}) = downcomer velocity for non foaming fluids (m/h) (given by figure 16).



4. Determination of Active Area (AAM)

- The minimum active area is a function of vapor and liquid loads, system properties, flood factor and flow path length.
- The flood factor (FF) is used in certain equations for purpose of estimating column size. It is the “design percent of flood” expressed as a fraction.
- A value of not more than 0.77 is normally used for vacuum columns and a value not more than 0.82 is used for other services.
- For demethanisers and near critical point values, it is recommended to adopt a value in the range 0.6 to 0.7.
- These values are intended to give not more than approximately 10 % entrainment.
- Higher flood factors may result in excessive entrainment and/or a column sized too small for effective operation.
- Flood factor of 0.65 to 0.75 should be used for column diameters under 36" (90 cm).
- The minimum active area is determined with equation as follows:

$$(AAM) = \frac{V_{load} + (Q_L)(FPL) / 44.14}{(CAF)(FF)}$$

(AAM)	=	minimum active area (m ²)
Q _L	=	actual liquid flow rate through the tray (m ³ /min),
(FPL)	=	flow path length (m),
(CAF)	=	vapour capacity factor (m/s),
(FF)	=	flood factor (dimensionless) (usual value = 0.82),
V _{load}	=	vapour load of the tray (m ³ /s).



5. Determination of the Downcomer area (ADM)

The minimum downcomer area is a function of liquid rate, downcomer design velocity and flood factor.

$$(ADM_m) = \frac{60 \times Q_L}{(VD_{dsg})(FF)}$$

Q_L = actual liquid flow rate through the tray (m³/min),
 VD_{dsg} = downcomer velocity calculate in 3th step (m/h),
 FF = flood factor defined in 4th step (dimensionless),
 (ADM_m) = minimum downcomer area (m²).

If the downcomer area calculated by this equation is less than 11 % of the active area (AAM) adopt for (ADM) the smaller value of relations as follows:

$$\begin{aligned}
 (ADM) &= (0.11) (AAM) \\
 \text{or } (ADM) &= 2 (ADM_m)
 \end{aligned}$$

Results for Vd and AAM

Vd	AAM	ADMm	ADMsel
598.6	24.45	1.28	2.57

Note that FF = 82%

Note that since ADMm is less than 11% AAM, 2.57 has been selected



6. Determination of the minimum inside diameter (DC) of the column

The approximate column cross sectional area is calculated by equations as follows:

$$(ATM) = (AAM) + 2 (ADM)$$
$$\text{or } (ATM) = \frac{V_{load}}{(0.78) (CAF) (FF)}$$

The higher value is adopted.

Minimum inside diameter of the column (DC) in meters is calculated with relation:

$$(DC) = \sqrt{\frac{(ATM)}{0.7854}}$$

Results for calculated ATM and Tower Diameter


ATM	Diamater
29.61	6.15

Note that 2 ATM are calculated and the higher one is selected



7. KG TOWER Confirmation

Open the software and select a new case





- Fill-up box 1 and 2 and then click **Tray**

MG LOADINGS

File Edit Units Window Help

Project Name Date 21-Jul-22
Tower Name By
Case Name Revision

	Load 1	Load 2	Load 3	Load 4	Load 5
Zone	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Description	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Tray or Bed Number	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Vapor					
Mass Rate lb/hr	0	0	0	0	0
Density lb/ft3	0.0735	0.0735	0.0735	0.0735	0.0735
Actual Vol.Flow ACFS	0.00	0.00	0.00	0.00	0.00
Viscosity cP	0.0070	0.0070	0.0070	0.0070	0.0070
Min. Rate %	0.00	0.00	0.00	0.00	0.00
Max. Rate %	0.00	0.00	0.00	0.00	0.00
Liquid					
Mass Rate lb/hr	0	0	0	0	0
Density lb/ft3	62.428	62.428	62.428	62.428	62.428
Volume Rate gpm	0.000	0.000	0.000	0.000	0.000
Surface Tension dyne/cm	18.713	18.713	18.713	18.713	18.713
Viscosity cP	0.9963	0.9963	0.9963	0.9963	0.9963
Min. Rate %	0.00	0.00	0.00	0.00	0.00
Max. Rate %	0.00	0.00	0.00	0.00	0.00
System Factor	1.00	Load not active	Load not active	Load not active	Load not active
Select Design :	TRAYS	PACKINGS	DEMISTER® ME	Comments	Close



T-5003 Input

LOADINGS

File Edit Units Window Help

Project Name: Date: 22-Jul-22
 Tower Name: By:
 Case Name: Revision:

	Load 1	Load 2	Load 3	Load 4	Load 5
Zone	15-42	43-80	1-14		
Description					
Tray or Bed Number					

Vapor

	Load 1	Load 2	Load 3	Load 4	Load 5
Mass Rate kg/hr	422000	440000	402000	0	0
Density kg/m ³	4.2300 <input type="button" value="Calc"/>	4.0700 <input type="button" value="Calc"/>	4.3000 <input type="button" value="Calc"/>	1.1774 <input type="button" value="Calc"/>	1.1774 <input type="button" value="Calc"/>
Std. Actual Vol.Flow m ³ /hr	99763.59	108108.11	93488.37	0.00	0.00
Viscosity cP	0.0130	0.0120	0.0130	0.0070	0.0070
Min. Rate %	40.00	40.00	40.00	0.00	0.00
Max. Rate %	110.00	110.00	110.00	0.00	0.00

Liquid

	Load 1	Load 2	Load 3	Load 4	Load 5
Mass Rate kg/hr	460000	359000	406000	0	0
Density kg/m ³	727.000	709.000	751.000	1000.000	1000.000
Volume Rate m ³ /hr	632.737	506.347	540.613	0.000	0.000
Surface Tension dyne/cm	17.000	15.000	20.000	18.713	18.713
Viscosity cP	0.2210	0.2250	0.2210	0.9963	0.9963
Min. Rate %	40.00	40.00	40.00	0.00	0.00
Max. Rate %	110.00	110.00	110.00	0.00	0.00

System Factor: 1.00

Rates:

Select Design:



Fill-up tray type, number of passes and Koch valve type

TRAY DESIGN


File Tools Units Window Help

Project Name: Date: 21-Jul-22

Tower Name: By:

Case Name: Revision:


Tray Information

Tray Type: **VALVE** 

Tower Diameter: mm

Number of Passes: **2**

Active Area

Valve Type: **MV-1 MINIVAL** 

Valve Quantity: 8496

Valve Density: 370.77 #/m2

Active Area: 22.914 m2

Open Area: 14.00 %

Tray No. Tray Spacing mm

Tray No.	Tray Spacing mm
Load 1	600.00
Load 2	600.00
Load 3	600.00

Design O.K.

Tray Details Results

Comments Close

Downcomers and Weirs

	Side	Center	
Width Top	730.34	641.69	mm
Kickback	0.00	0.00	mm
Width Bottom	730.34	641.69	mm
Swept Back Weir	0.00		mm
Swept Weir Clearance	0.00		mm
Sump Depth	0.00	0.00	mm
Sump Width	0.00	0.00	mm
Weir Height	63.50	63.50	mm
Downcomer Clearance	57.15	57.15	mm
Downcomer Radius	0.00	0.00	mm

Downcomer Areas

	Side	Center	
Net Top Area	4.022	4.022	m2
Gross Top Area	4.022	4.022	m2
Net Bottom Area	4.022	4.022	m2
Exit Area	0.230	0.357	m2
Receive Area	4.022	4.022	m2

Weir Lengths

	Side	Center	
Top Weir Length	4025.85	6245.39	mm
Override Weir Length	4025.85	6245.39	mm
% Blocked	0.00	0.00	%
Bottom Edge Length	4025.85	6245.39	mm
Override Edge Length	4025.85	6245.39	mm
% Blocked	0.00	0.00	%

Inlet Weirs

	Side	Center	
Height	0.00	0.00	mm
Inlet Width	730.34	641.69	mm

Panels parameters

	A	B	
Active Area	11.46	11.46	m2
Flow Path Length	2087.95	2087.95	mm



Go to TOOL and select "Estimate Tower Diameter"

HG Tray Optimization

Design based on:

☒ % DC Area % DC Area **12.00**

☐ Flood limits

Note: Floods are calculated at maximum rates.

Types of Downcomer:

☒ **Straight**

☐ Sloped (% slope given)

OK Cancel



Check the Results

MG TRAY DESIGN

File Tools Units Window Help

Project Name

Tower Name

Case Name

Date 21-Jul-22

By

Revision

Tray Information

Tray Type **VALVE**

Tower Diameter **6332.86** mm

Number of Passes **2**

Active Area

Valve Type **Type-A (V-1)**

Valve Quantity 3702

Valve Density 150.65 #/m2

Active Area 24.574 m2

Open Area 13.66 %

Tray No. Tray Spacing

mm

Load 1 **600.00**

Load 2 600.00

Load 3 600.00

Design O.K.

Tray Details **Results**

Comments Close

Downcomers and Weirs

Sketch

	Side	Center	
Width Top	657.27	547.42	mm
Kickback	0.00	0.00	mm
Width Bottom	657.27	547.42	mm
Swept Back Weir	0.00		mm
Swept Weir Clearance	0.00		mm
Sump Depth	0.00	0.00	mm
Sump Width	0.00	0.00	mm
Weir Height	63.50	63.50	mm
Downcomer Clearance	57.15	57.15	mm
Downcomer Radius	0.00	0.00	mm

Downcomer Areas

	Side	Center	
Net Top Area	3.462	3.462	m2
Gross Top Area	3.462	3.462	m2
Net Bottom Area	3.462	3.462	m2
Exit Area	0.221	0.361	m2
Receive Area	3.462	3.462	m2

Weir Lengths

	Side	Center	
Top Weir Length	3862.85	6309.15	mm
Override Weir Length	3862.85	6309.15	mm
% Blocked	0.00	0.00	%
Bottom Edge Length	3862.85	6309.15	mm
Override Edge Length	3862.85	6309.15	mm
% Blocked	0.00	0.00	%

Inlet Weirs

	Side	Center	
Height	0.00	0.00	mm
Inlet Width	657.27	547.42	mm

Panels parameters

	A	B	
Active Area	12.29	12.29	m2
Flow Path Length	2235.45	2235.45	mm



TRAY RESULTS

File Units Window Help

		Load 1	Load 2	Load 3
Zone		15-42	43-80	1-14
Description				
Tray Number				
Jet Flood	%	77.12	77.21	70.14
Downcomer Flood	%	30.53	24.74	25.66
Downcomer Backup	mm liq	208.39	191.89	185.71
DC Exit Velocity	m/s	0.40	0.32	0.34
Dry Tray DP	mm liq	59.52	68.78	51.56
Total Tray DP	mm liq	121.08	122.00	109.22
Total Tray DP	mm Hg	6.48	6.37	6.04
Cf, Active Area	m/s	0.0863	0.0929	0.0802
Weir Load	m3/h/m	81.90	65.54	69.98
Crest	mm liq	53.37	46.00	48.06
DC Backup % (TS+W)		31.4	28.9	28.0
Max DC Loading	m3/hr/m2	182.75	146.24	156.14
Head Loss Under DC	mm liq	25.25	16.17	18.44
DC Residence Time	sec	13.1	16.3	15.3
Blow Rating	%	N/A	N/A	N/A
System Limit	%	44	49	40
Turndown	%	41	42	45
Unit Reference	%	151	160	143
Equation 13	%	78	80	72

Rates:

Min
 Design
 Max

Show High Performance Tray Results :

TRITON®
 SUPERFRAC®
 ULTRA-FRAC®

Application Regimes
 Print Results
 Print Report
 Comments
 Close



Comparison

Haldor Topsoe	Koch-Glitsch Excell	KG Tower
6350 mm	6140 mm	6332 mm